

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8507170230 DOC. DATE: 85/07/15 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public 05000528
 AUTH. NAME AUTHOR AFFILIATION
 VAN BRUNT, E.E. Arizona Public Service Co.
 RECIP. NAME RECIPIENT AFFILIATION
 KNIGHTON, G. Licensing Branch 3

SUBJECT: Application for amend to License NPF-41, requesting emergency one-time only change of Tech Spec 3.4.5.2 re RCS operational leakage to allow for addl 72 h in Mode 2 in order to identify RCS leakage which began 850711. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4+2
 TITLE: OR Submittal: General Distribution

NOTES: Standardized plant.
 OL: 12/31/84

05000528

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	NRR	LB3 BC	01	7	7				
INTERNAL:	ACRS		09	6	6	ADM/LFMB		1	0
	ELD/HDS3			1	0	NRR/DE/MTEB		1	1
	NRR/DL DIR			1	1	NRR/DL/ORAB		1	0
	NRR/DL/TSRG			1	1	NRR/DSI/METB		1	1
	NRR/DSI/RAB			1	1	REG FILE	04	1	1
	RGNS			1	1				
EXTERNAL:	24X			1	1	EG&G BRUSKE, S		1	1
	LPDR		03	1	1	NRC PDR	02	1	1
	NSIC		05	1	1				

Rec'd w/ check \$150⁰⁰
 # 001602



Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

Director of Nuclear Reactor Regulation
Attention: Mr. George Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

July 15, 1985
ANPP-33030

Subject: Palo Verde Nuclear Generating Station
Unit 1
Docket No. STN 50-528 (License No. NPF-41)
Request for Emergency Technical Specification Change
File: 85-056-026; G.1.01.10

Reference: Letter from E. E. Van Brunt, Jr., APS, to G. W. Knighton, NRC, dated July 12, 1985 (ANPP-33008); Subject: Request for Emergency Technical Specification Change.

Dear Mr. Knighton:

Per conversation with your staff on July 12, 1985, submitted herewith is a supplement to the referenced one-time only Emergency Technical Specification Change. This change is required expeditiously due to the nature of the unidentified leak which we have experienced in order to provide the most effective manner in which to determine the leak. Enclosed within this package request is:

- a. Description of the Proposed Change Request
- b. Marked-up Technical Specification Change Page
- c. Justification for Emergency Classification
- d. Safety Evaluation of the Proposed Amendment Request
- e. Significant Hazards Consideration Determination
- f. Environmental Impact Consideration Determination
- g. Proposed Compensatory Measures

In accordance with 10CFR 170.12(c), the license amendment application fee of \$150.00 is also enclosed.

If you have any questions, please contact Mr. W. F. Quinn of my staff.

Very truly yours,

E. E. Van Brunt / ABK

E. E. Van Brunt, Jr.
Executive Vice President
Project Director

8507170230 850715
PDR ADDCK 05000528
PDR

EEVB/WFQ/slh
Enclosure

cc: E. A. Licitra (all w/a)
R. P. Zimmerman
A. C. Gehr
C. F. Tedford, Arizona Radiation Regulatory Agency

Acc 1/1

*Rec'd w/ check \$150.00
#001602*



G. W. Knighton
Request for Emergency Technical Specification Change
ANPP-33030
Page 2

bcc: D. B. Karner (all w/a)
R. M. Butler
T. F. Quan
O. J. Zeringue
J. R. Bynum
S. R. Frost
D. Cannady
J. Haynes
A. C. Rogers



1941
1942
1943
1944
1945
1946
1947
1948
1949
1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025

DESCRIPTION OF PROPOSED AMENDMENT REQUEST

Technical Specification 3.5.4.2, Action Statement b was entered into on July 11, 1985, based on the determination of unidentified Reactor Coolant System leakage of 1.2 gpm. The plant has been taken to Mode 2 and will enter Mode 5 within 30 hours as required by the Action Statement. However, for a one time only change, we request that we be allowed an additional 72 hours in Mode 2 prior to entering Mode 5 in order to: 1) allow additional "at-pressure" time for ascertaining the location of the leak (if one exists), and 2) provide additional time for collecting additional RCS inventory data to verify the RCS inventory calculations. If the RCS leakage is determined to increase to greater than 2 gpm within the requested 72 hour extension, based on inventory surveillance at least every 8 hours, PVNGS Unit 1 will proceed immediately to Mode 5. Attached marked-up Technical Specification page 3/4 4-19 indicates this proposed one-time only change.

JUSTIFICATION FOR EMERGENCY CLASSIFICATION

The unidentified leakage which has been determined to exist has not been located at this time. It is speculated that the leakage may be intersystem. In order to locate the leakage, the system must be at some pressure to produce the pressure differential to promote the leakage. Therefore, it is necessary to remain above Mode 5 to ensure positive identification of the leakage can be ascertained. In addition, verification of RCS inventory calculations require that reproducible data and leakage paths remain constant. In order to achieve the above, a suspension of the pre-noticing requirements of 10CFR50.91 is required and expeditious granting of the proposed one-time only change be effected.

SAFETY EVALUATION OF PROPOSED AMENDMENT REQUEST

The requested one-time only change to the time requirements of Technical Specification 3.5.4.2, Action Statement b will not increase the probability or consequences of any accident or malfunction of equipment, nor will it reduce any margin of safety as defined in the basis to any Technical Specification. The RCS activity at the time of our discussions was $2.1 \times 10^{-2} \mu\text{Ci/cc}$ which is approximately 200 times less than that assumed in the accident analyses (refer to CESSAR Section 15.6.3.1.3.2 which assumes a primary activity of $4.6 \mu\text{Ci/gm}$). Therefore, the margin of safety is maintained and the probability and consequences of any accident is not increased.

SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

The proposed one-time only amendment request does not involve a Significant Hazards Consideration because:

- A) Operation of PVNGS Unit 1 in accordance with this change would not:
1. Involve a significant increase in the probability or consequences of an accident previously analyzed; or
 2. Create the possibility of a new or different kind of accident from any accident previously analyzed; or

3. Involve a significant reduction in the margin of safety; and
- B) The change does not allow exiting from the design basis envelopes for any accident analyses based on the plant specific primary coolant activity which will be experienced during the time period that the one-time only Technical Specification change will be in effect.

ENVIRONMENTAL IMPACT CONSIDERATION DETERMINATION

The proposed amendment request does not involve an unreviewed environmental question because operation of PVNGS Unit 1 in accordance with this change would not:

1. Result in a significant increase in any adverse environmental impact previously evaluated in the Final Environmental Statement (FES) as modified by staff's testimony to the Atomic Safety and Licensing Board, Supplements to the FES, Environmental Impact appraisals, or in any decisions of the Atomic Safety and Licensing Board; or
2. Result in a significant change in effluents or power levels; or
3. Result in matters not previously reviewed in the licensing basis for PVNGS which may have a significant environmental impact.

PROPOSED COMPENSATORY MEASURES

There are no other compensatory measures proposed which are not already cited in the request for change. The upper limit on unidentified RCS leakage during the requested time extension in conjunction with the RCS sampling frequency to be imposed during this period provide sufficient compensatory measures to maintain protection of the public health and safety.



Handwritten marks and characters in the top right corner.

Main body of the document containing extremely faint and illegible text, possibly bleed-through from the reverse side.