

10 CFR 50.55a

October 26, 2017

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

James A. FitzPatrick Nuclear Power Plant  
Renewed Facility Operating License No. DPR-59  
NRC Docket No. 50-333

Subject: Relief Requests Associated with Fifth Ten-Year Inservice Testing Interval –  
Supplement for Relief Request PRR-01

Reference Letter from D. Gudger (Exelon Generation Company, LLC) to U.S. Nuclear  
Regulatory Commission, "Relief Requests Associated with Fifth Ten-Year  
Inservice Testing Interval," dated August 3, 2017 (ADAMS Accession No.  
ML17219A123)

In the referenced letter, Exelon Generation Company, LLC (Exelon) submitted relief requests associated with the fifth ten-year Inservice Testing (IST) Interval for James A. FitzPatrick Nuclear Power Plant (JAFNPP). One of these relief requests is PRR-01, "Core Spray Pump Suction Pressure Gauge Range." During a clarification call between the NRC staff and Exelon conducted on October 23, 2017, Exelon agreed to submit this supplement to revise the proposed 10 CFR 50.55a(z) alternative category for relief request PRR-01. Relief request PRR-01 was originally submitted requesting NRC approval under 10 CFR 50.55a(z)(2), "Hardship without a compensating increase in quality and safety." This supplement changes the relief category to 10 CFR 50.55a(z)(1), "Acceptable level of quality and safety." The remaining information submitted for relief request PRR-01 in the reference letter remains accurate and unchanged.

There are no regulatory commitments contained within this letter.

If you have any questions concerning this letter, please contact Mr. David Neff at (610) 765-5631.

Sincerely,



---

David T. Gudger  
Manager - Licensing & Regulatory Affairs  
Exelon Generation Company, LLC

cc: USNRC Region I, Regional Administrator  
USNRC Senior Resident Inspector, JAFNPP  
Project Manager USNRC, JAFNPP  
NYSERDA