

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8710190322 DOC. DATE: 87/10/01 NOTARIZED: NO DOCKET #
 FACIL: STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530
 AUTH. NAME AUTHOR AFFILIATION
 VAN BRUNT, E. E. Arizona Nuclear Power Project (formerly Arizona Public Serv
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Region 5, Office of Director

SUBJECT: Certifies that all sys required for initial entry into
 Mode 4 demonstrated by successfully meeting acceptance
 criteria in Tech Specs, per Item 1.b of Attachment 1 to
 License NPF-65.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: Standardized plant.

05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 PD	1	LICITRA, E	2
	DAVIS, M	2		
INTERNAL:	ACRS	2	AEOD	1
	DEDRO	1	NRR MORISSEAU, D	1
	NRR/DOEA DIR	1	NRR/DREP/EPB	1
	NRR/DREP/RPB	2	NRR/DRIS DIR	1
	NRR/PMAS/ILRB	1	OE LIEBERMAN, J	1
	OGC/HDS1	1	REG FILE	1
	RES DEPY GI	1	RGN5 FILE 01	1
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		
NOTES:		1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 0



Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

RECEIVED
NRC
REGION V

1987 OCT -5 A 10: 28

058-02313-EEVB/JRB

October 1, 1987

Mr. John B. Martin
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission, Region V
1450 Maria Lane - Suite 210
Walnut Creek, California 94596

Dear Mr. Martin:

Subject: Certification of the Operability of All
Required Systems for Initial Entry Into Mode 4
Palo Verde Unit 3

Ref.: PVNGS Unit 3 Operating License - NPF-65
File: 87-056-026

As required by Item 1.b of Attachment 1 to the Palo Verde Nuclear Generating Unit 3 Operating License, NPF-65, I am hereby certifying that Item 1.a of Attachment 1 to the License has been completed for the initial entry into Mode 4.

The operability of all systems required for the initial entry into Mode 4 has been demonstrated by successfully meeting the acceptance criteria in the PVNGS Technical Specifications. This has been accomplished by the completion of the applicable surveillance tests or by preoperational testing which verifies meeting the requirements of the Technical Specifications which were performed within the required surveillance interval or by operability as demonstrated for Modes 5 and 6.

Very truly yours,

E. E. Van Brunt, Jr.
Executive Vice President
Project Director

EEVB/JRB/bsc

cc: Gaston Fiorelli
Art Gehr

8710170322 871001
PDR ADOCK 05000530
P PDR

USNRC-DS

1987 OCT 20 A 10: 01

1/0
IE-01