

CONTAINMENT SYSTEMS

SPRAY ADDITIVE SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)


- d. At least once per five years by verifying a minimum sodium hydroxide (NaOH) flow rate of 10.5 gpm from the spray additive tank to a drain connection immediately downstream of the tank outlet valve, and a minimum demineralized water flow rate of 18 gpm from that same drain connection to each containment spray pump with a pressure of 19 ± 2 psig at the upstream tap of FI-07-2.

STATE OF FLORIDA)
)
COUNTY OF DADE) ss.

J. W. Williams, Jr. being first duly sworn, deposes and says:

That he is a Group Vice President of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.



J. W. Williams, Jr.

Subscribed and sworn to before me this

 day of , 19 .

NOTARY PUBLIC, in and for the County
of Dade, State of Florida

My Commission expires: _____

NOTARY PUBLIC STATE OF FLORIDA AT LARGE
MY COMMISSION EXPIRES DEC 8 1984
BONDED THRU GENERAL INS. UNDERWRITERS