



REVISIONS				
NO	DATE	DESCRIPTION	BY	CH
21	7/25/95		CM	HS
22	10/24/95		PAB	HS
23	1/8/96		PAB	CM
24	6/10/96		DC	DW
25	6/21/96		CM	HS
26	10/4/96		CM	HS
27	11/5/96		CM	HS
28	19/16/98		CM	HS
29	2/2/00		CM	HS

NOTES

- FOR FIELD (UP TURBINE) TEST CONNECTIONS SEE 2998-101, 104 THRU 107.
- NOT USED.
- TURBINE COIN NO ON DWG 2998-21 (WESTINGHOUSE DWG NO 732-1-042).
- FOR TURB - GEN PURCHASER'S PIPE COINGS SEE PIPING - STEAM GRAB & GLAND DIAG, DWG 2998-2104 & TURB OUTLINE SUPPLEMENT (PVC) - DWG.
- HH - TURBINE TRIP - FW PUMP TRIP.
- M - FW REC VLV - CLOSURE (FWCS).
- CONDENSER COIN NO ON DWG 2998-445 TO 448 (WESTINGHOUSE DWG NO 736-1-709, 4 SHEETS).

REFERENCE DRAWINGS

PIPE VALVES & INSTRUMENT SYMBOLS 2998-G-078 SH 100  
 VALVE LIST 2998-A-001  
 LINE LIST 2998-B-002  
 INSTRUMENT INSTALLATION DETAILS 2998-B-029A  
 INSTRUMENT LIST 2998-B-231  
 AUX FEEDWATER PUMP DC 2998-3432  
 STEAM GENERATOR PROTECTIVE CHANNEL BLOCK DIAGRAM 2998-8342

REVISION OF THIS DRAWING MAY REQUIRE UPDATE OF THE FOLLOWING DOCUMENT: FSAR FIGURE 10.1-10

**NUCLEAR SAFETY RELATED IN PART ONLY**

FLORIDA POWER & LIGHT COMPANY  
 ST LUCIE PLANT  
 1883 - 890 MW EXTENSION - UNIT 2  
 FLOW DIAGRAM  
 MAIN STEAM SYSTEM

RAYTHEON ENGINEERS & CONSTRUCTORS, INC.

SCALE: NONE APPROVAL DATE: 2998-G-079  
 DW: MECJ  
 CH: J. CHERRY  
 DR: R. SLOAN

**INFORMATION ONLY**  
 VERIFY WITH A CONTROLLED COPY BEFORE USE.

DRAWING NUMBER  
**2998-G-079**  
 SH 1

DRAWING NUMBER  
**2998-G-079**  
 SH 1

DRAWING NUMBER  
**2998-G-079**  
 SH 1

DRAWING NUMBER  
**2998-G-079**  
 SH 1

9712040015 -39 E