Docket Nos.: 50-528, 50-529 and 50-530

Mr. E. E. Van Brunt, Jr. Executive Vice President Arizona Nuclear Power Project Post Office Box 52034 Phoenix, Arizona 85072-2034

Dear Mr. Van Brunt:

Distribution
Docket_File
PD5 Plant File
GMHolahan
JLee
EALicitra/MJDavis
AToalston/OGC-Bethesda
EJordan
JPartlow
ACRS (10)

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - PALO VERDE RESPONSE TO GENERIC LETTER 83-28, ITEM 2.1, PART 2 AND ITEM 2.2

In order to complete our review of your responses to Item 2.1, Part 2 and Item 2.2 of Generic Letter 83-28, we require additional information. The specific information needed is identified in the enclosure.

We ask that you provide the requested information and that within two weeks of receipt of this letter, you inform us of the date when the information will be provided.

If you have any questions regarding this request, please let me know.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Original signed by: E. A. Licitra

E. A. Licitra, Senior Project Manager Project Directorate V Division of Reactor Projects - III, IV, V and Special Projects

Enclosure: As stated

cc: See next page

*See previous concurrence *DRSP/PDV DRSP/D:PDV EALicitra:cd GWKn\ghton 6/30/87 7/1/87

OFFICIAL RECORD COPY

B707130172 B70701 PDR ADDCK 05000528

14.2

The Control of the Co

The second secon

and the state of t

A CONTRACT OF THE STATE OF THE

, · · · · ·

And the second s

•

Mr. E. E. Van Brunt, Jr. Arizona Nuclear Power Project

cc: Arthur C. Gehr, Esq. Snell & Wilmer 3100 Valley Center Phoenix, Arizona 85073

Mr. James M. Flenner, Chief Counsel Arizona Corporation Commission 1200 West Washington Phoenix, Arizona 85007

Charles R. Kocher, Esq. Assistant Council James A. Boeletto, Esq. Southern California Edison Company P. O. Box 800 Rosemead, California 91770

Mr. Mark Ginsberg
Energy Director
Office of Economic Planning
and Development
1700 West Washington - 5th Floor
Phoenix, Arizona 85007

Mr. Wayne Shirley Assistant Attorney General Bataan M. Morial Building Santa Fe, New Mexico 87503

Mr. Roy Zimmerman U.S. Nuclear Regulatory Commission P. O. Box 239 Arlington, Arizona 85322

Ms. Patricia Lee Hourihan 6413 S. 26th Street Phoenix, Arizona 85040

Regional Administrator, Region V U. S. Nuclear Regulatory Commission 1450 Maria Lane Suite 210 Walnut Creek, California 94596 Palo Verde

Kenneth Berlin, Esq. Winston & Strawn Suite 500 2550 M Street, NW Washington, DC 20037

Ms. Lynne Bernabei Government Accountability Project of the Institute for Policy Studies 1901 Que Street, NW Washington, DC 20009

Mr. Ron Rayner P. O. Box 1509 Goodyear, AZ 85338

Mr. Charles B. Brinkman, Manager Washington Nuclear Operations Combustion Engineering, Inc. 7910 Woodmont Avenue Suite 1310 Bethesda, Maryland 20814 Ü

Request for Additional Information Palo Verde Units 1, 2 and 3 Generic Letter 83-28

1. Item 2.1, Part 2 - Vender Interfaces

Your response does not specifically identify CE "Infobulletins" or that return receipts are required for those bulletins. Provide additional information which addresses whether you receive such bulletins and if return receipts are required.

2. Item 2.2.1.3 - Use of the Equipment Classification Listing

Your response has not confirmed that criteria and procedures exist which govern the use of the information handling system to determine that an activity is safety-related and what procedures apply to safety-related components for maintenance, surveillance, parts replacement and other activities defined in the introduction to 10 CFR 50, Appendix B. Provide additional information which addresses such criteria and procedures.

3. Item 2.2.1.4 - Management Controls

Your response has not confirmed how management determines that the management controls utilized to verify that the procedures for preparation, validation and routing utilization of the information system have been followed. Provide additional information which addresses how management makes this determination.

