




TITLE/DESCRIPTION

TRANSIENT TEMPERATURE STUDY
FOR MAIN CONTROL ROOM
QUALITY CLASS Q :
SAFETY RELATED

881123018

△						
△						
△						
△						
△						
△						
△						
△						
△						
△						
△						
△	8811230018 881109 PIR ADOCK 05000528 PDC					
△	ISSUED FOR USE	BECHTEL	BECHTEL	Henry Riley 6/22/88	N/A	N/A
REV	REVISION DESCRIPTION	ORIGINATOR DATE	CHECKER DATE	RS DATE	QA DATE	HEM/PEM DATE





INTERNAL CONTROL NO.
18601-200-CALC-001

CALCULATION COVER SHEET

SHEET 1

PROJECT ANPP PVNGS JOB NO. 18601-200 CALC. NO. 13-MC-H.I-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR THE MAIN CONTROL FILE NO. _____

ROOM _____ PROJECT QUALITY CLASS QR DISCIPLINE MECH

COMPUTER PROGRAM	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	SCP	PROGRAM NO.(S) <u>ME-204</u>	VERSION/RELEASE NO. <u>A1</u>
------------------	---	-----	---------------------------------	----------------------------------

RECORD OF ISSUES

NO.	DESCRIPTION	TOTAL NO. OF SHEETS	LAST SHEET NO.	ORIG	CKR	GL	GS	CHEF	DATE
<u>0</u>	<u>ORIGINAL ISSUE</u>	<u>51</u>	<u>51</u>	<u>PSS</u>	<u>JA</u>	<u>-</u>	<u>TJB</u>	<u>-</u>	<u>APPR. 6-13-84</u> <u>FILM</u>
<u>△</u>									<u>APPR.</u> <u>FILM</u>
<u>△</u>									<u>APPR.</u> <u>FILM</u>
<u>△</u>									<u>APPR.</u> <u>FILM</u>
<u>△</u>									<u>APPR.</u> <u>FILM</u>
<u>△</u>									<u>APPR.</u> <u>FILM</u>


- INFORMATION ENTERED IN THIS SPACE:
- SHOW PROFESSIONAL ENGINEER STAMP, IF REQUIRED.
 - ENTER REFERENCE TO INCLUSION OF CHECKER'S ALTERNATE CALCULATIONS, IF USED.
 - PROVIDE ANY NOTES TO ASSIST CHECKING AND APPROVAL

NOTICE

APS ACKNOWLEDGES THAT THESE DESIGN CALCULATIONS ARE ONLY AN ISOLATED PART OF THE COMPLETE DESIGN FOR THE SYSTEM THEY CONCERN, AND ARE SUBJECT TO BEING TAKEN OUT OF CONTEXT, MISINTERPRETED OR MISCONSTRUED IF USED WITHOUT BECHTEL POWER CORPORATION'S DIRECT PARTICIPATION.

PP-6346 (10407) 2/84

NOTICE: Utilization of these calculations by persons without access to pertinent facts and without proper regard for their purpose could lead to erroneous conclusions. Bechtel cannot assume responsibility for the use of these calculations not under its direct control.





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 2

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE	REV. INDICATOR
0	PSS	6-13-88	J. B. M. C.	6/13/88	△					△
△					△					△

Table of Contents

		<u>Page No.</u>
I.	Purpose	4
II.	Design Criteria	5
III.	Study Assumptions	6
IV.	References	11
V.	Summary of Results	13
VI.	Room Heat-Up Computer Model	
	A. Model Description	15
	B. Required Input	17
	C. Assumptions	18
	D. Limitations	18
	E. Output	18
VII.	Study	
	A. Heat Loads	
	1. Essential AHU Fan Motors Heat Load	19
	2. Main Control Room Complex Heat Loads	20
	3. Total Heat Loads	23
	B. Main Control Room Complex Surface Area & Volume	23
	C. Input Data	26
	D. Results	28
	E. Discussion of Results	29
	F. Effect of Outside Makeup Air	30

1
2
3
4
5
6
7
8
9
10
11
12
13
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
33
34
35
36

REV. INDICATOR
△





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 3

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PJJ	6-13-88	J. Roman	6/13/88	△				
△					△				

REV. INDICATED

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

VIII. Figures:

- 1. Main Control Room Complex Transient Temperature Plot 33

IX. Appendix:

- A. Computer Transient Temperature Run for the Main Control Room Complex (with both ESF AHU fans running) 34
- B. Computer Transient Temperature Run for the Main Control Room Complex (with one ESF AHU fan running) 39
- C. Computer Transient Temperature Run for the Main Control Room Complex (with no ESF AHU fans running) 44
- D. Temperature Measurements by ANPP 49





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 4

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PJJ	6-13-88	<i>W. M. W.</i>	6/13/88	△				
△					△				

REV. INDI. ↓

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

I. PURPOSE

The design basis for cooling the Main Control Room Complex uses Essential Air Handling Unit (AHU) and the Essential Chilled Water System (ECWS) for cooling. In the event that either the AHU or ECWS fails, the room temperature will rise rapidly. The purpose of this study is to determine the transient air temperature for 24 hours in the Main Control Room Complex for the following case:

- o Large break LOCA
- o Normal offsite power is available and all normally operating equipment continues to generate heat
- o Normal HVAC stops and does not operate
- o Essential chilled water system is not operating
- o Essential air handlers/fans are operating
- o Doors and other HVAC barriers remain in their normal closed position during the entire period of the study

Standard room heat-up (RMHTUP) computer program, ME 204, version A1, is used to study the room air heat-up by the equipment and other heat loads in the Main Control Room Complex.

The heat generated in the room is transferred to the room ambient air, stored in the room enclosure concrete (heat sink) and transferred to the air outside the room. The transient temperature for the Main Control Room Complex is calculated for a time period of 24 hours for the above mentioned conditions. The emphasis of this study is to estimate the room air temperature more accurately in the first 1 1/2 hours rather than the later part of the problem.





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 5

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Normal	6/13/88	△				
△					△				


REV. INDICATED

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

II. DESIGN CRITERIA:

This is a study of the effect of certain equipment failures which are, strictly speaking, beyond the specific design basis for the affected systems. The results will be used as input for a response to EER 88-EC-018 being done by others.

The systems involved in this study are the control room HVAC (Normal and Essential), and Essential Chilled Water. Their design criteria are references 10 and 11.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 7

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PJN	6-13-88	J. Nomir	6/13/88	△				
△					△				

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36


5. The main control room complex model is simplified as an enclosed space bounded by the same thickness of walls, ceiling and floor. Most of the room walls are 1'-9" thick (Ref 5). The floor and the walls around the cable shafts are 1'-0" thick (Ref 5), while the ceiling is 11" thick, (Ref 6). For this study, all surfaces are considered to be 1'-0" thick. No credit is taken for the wall thickness being more than 1'-0", except that the ceiling is also considered as 1'-0" thick for computer modeling.

The emphasis in this calculation is to improve the accuracy of the calculation in the initial 90 minutes. Thus, heat sinks are modeled in a way that takes credit for thinner heat sink walls than would be used in modeling for accuracy in the 12 to 24 hour time frame.

Due to the low heat load generated during the first 1 1/2 hours compared to the thermal capacity of the existing walls to absorb the heat, additional thickness does not appreciably affect the room ambient air temperature.

6. The walls, ceiling and floor are used as a heat sink. For details, refer to Section VI.C of this study.

7. The heat generated within the room is considered as being constant. This is due to the fact that the heat load equipment continues to operate during this study. In addition, a constant heat load is required for the computer model as shown in section VI.D.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 8

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. B. M. W.	6/13/88	△				
△					△				

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

- 8. The dimensions of the Main Control Room Complex for all three units are essentially identical. In addition, the chillers, fans, other equipment, the lighting and the room dimensions are virtually the same for all of these rooms. This study is performed for the Main Control Room Complex for Unit 1 and is applicable to the Main Control Rooms for all three units.
- 9. Per assumption 3 above, the essential chilled water is not available during the time period of this study. For a conservative approach, the AHU fans are assumed running, without chilled water through the essential coils as indicated in Section I.
- 10. This study is performed for a time period of 24 hours. The computer model can provide details for a maximum of 720 steps (Refer Section VI.D). Therefore, each step or time increment is 2 minutes.
- 11. The room walls are required to be divided into a number of layers for computation of temperature distribution in the concrete walls by the computer model. The required input for the thickness of the first layer and the multiplication factor for thickness of other layers are selected as 0.01 ft (approximately 1/8") and 1.41 respectively. For details, see sections VI.A and B.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 9

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Norma	6/13/88					

REV. 4 INDI-

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

12. Concrete has the following properties:

- A. Density 144 lbs/ft³ (Ref 12, table A-2)
- B. Thermal conductivity 0.54 (Ref 12, table A-2)
- C. Specific heat 0.2 btu/lb-°F (Ref 12, table A-2)

W: 8/1/88

13. The net Control Room Complex volume is required as input to the computer model. For calculation of net room volume, the volume of the HVAC equipment, the control panels and other electrical equipment in the Main Control Room Complex is insignificant and is neglected.

Most equipment in the main control room complex is control panels and instrument racks. These items are mostly air (i.e. approximately 90+% of the gross volume occupied by the panel is air. Much less than 10% is actually metal, wire, circuit boards, terminal boards, etc.).

In addition, the air has low thermal capacity. A small difference in the room volume does not have significant effect on the room temperature as shown by volume sensitivity analysis Case B of Reference 17.

14. All miscellaneous metal items (e.g. structural steel, platforms, cold piping) which could be considered as heat sinks are conservatively ignored. This is due to the computer program limitation which allows for a single heat sink to be included in the model.





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 10

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Brown	6/13/88	△				
△					△				


REV. INDI-

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

15. At the start of this study, both trains of the Essential Control Room Complex HVAC will be started. For calculation of heat loads, both of these trains continue to operate during the entire period of this calculation. This assumption complies with Section I.

16. The temperature of the outside makeup air is 101.3°F. This is based on the actual measurements made by ANPP at the operating unit (Ref. 16). The walls around the outside air chase are neglected for calculation of the heat sink effect. These walls effectively act as a heat source during initial period but act as a heat sink during the later period. The amount of heat added during the initial stages is insignificant because the structural steel and the thin metal items (e.g. cabinet sheet metal) act as a heat sink, the effect of which has been excluded (see Assumption 14 and Section VII.F).

17. Room surface area adjustment for panels etc. mounted on the concrete floor and walls is not done because the panels, instrument racks, etc. generate heat internally and generally have open bottoms which allow the heat to have ready access to the heat sink.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 11

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	<i>J. Brown</i>	6/13/88	△				
△					△				

REV. FIND. DATE

IV. REFERENCES:

1. ASHRAE Handbook of Fundamentals, 1972..
2. Control Room Complex - Heat Load Calculations, Calculation number 13-MC-HJ-051, Rev. 2.
3. P & I diagram, Control Building HVAC, drawing number 01-M-HJP-001, Rev. 12.
4. Basic Flow Diagram, HVAC Control Room - Control Building, drawing number 13-M-HJF-001, Rev. 3
5. Control Building Plan at Elevation 140'-0", drawing number 13-C-ZJS-140, Rev. 19.
6. Control Building Plan at Elevation 160'-0", drawing number 13-C-ZJS-150, Rev..14.
7. Control Building, Control Room Plan and Interior Elevations, drawing number 13-A-ZJD-503, Rev. 14:
8. User's and Theoretical Manuals Verification Report, program RMHTUP-Room Heat-Up, program number ME.204, version A1, Bechtel Power Corporation, San Francisco Power Division.
9. Updated Final Safety Analysis Report, Palo Verde Nuclear Generating Station, Revision 0.
10. Detailed Design Criteria, Part III, System HJ, HVAC Control Building, Rev.5:
11. Detailed Design Criteria, Part III, System EC, Essential Chilled Water System, Rev. 3.
12. Principles of heat transfer, third edition, Frank Kreith, Intext Education Publishers, table A-1, Properties of Metals and Alloys, page 634 and table A-2, Physical Properties of Some Nonmetals, page 635.
13. Operation and Maintenance Manual for Control Room Essential Air Handling Units, CTI Nuclear Inc., SDR Log M721B-582-4

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 12

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE	REV. INDICATOR
0	PSS	6-13-88	Norman	9/13/88	△					↓
△					△					

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

- 14. Control Room Complex Essential Cooling System Equipment Sizing Calculations, Number 13-MC-HJ-251, Rev 2.
- 15. Project General Design Criteria, Part II, Rev. 19.
- 16. Actual Temperature Measurement Data by ANPP for an operating unit, June 10, 1988 (3 pages attached).
- 17. Transient Temperature Study for Essential Cooling Water Pump Rooms, Calculation Number 13-MC-HA-253, Rev. 0.





CALCULATION SHEET

PROJECT ANPPJOB NO. 18601..- 200CALC. NO. 13-MC-HJ-253SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOMSHEET NO. 13

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
△	PSS	6-13-88	W. M. M.	6/13/88	△				
△					△				


REV. INDI-
C

V. SUMMARY OF RESULTS:

The calculated transient room temperature summary for the Main Control Room Complex is shown below. The transient room air temperature for the Main Control Room Complex obtained from the computer output, is shown in Figure 1. The transient temperature output, Appendix A, shows that with both essential AHU fans of Trains A & B operating under conditions outlined in Section I, the calculated temperature in the pump room will be as shown below. For cases with one or no fans running, the transient temperature outputs, Appendices B and C, are also presented:

Time Period	Appendix A	Appendix B	Appendix C
	Control Room w/2 ESF Fans Temp. °F	Control Room w/1 ESF Fan Temp. °F	Control Room w/No ESF Fans Temp. °F
0 min	75.5	75.5	75.5
2 min	86.07	83.79	81.49
4 min	93.65	89.78	85.86
6 min	99.00	94.06	89.02
12 min	107.43	100.95	94.23
36 min	115.21	107.38	99.19
60 min	118.50	110.00	101.12
84 min	121.05	112.03	102.60
96 min	122.18	112.92	103.25
2 hr	124.21	114.52	104.42
4 hr	132.05	120.73	108.95
6 hr	138.02	125.45	112.38
8 hr	143.03	129.40	115.26
12 hr	151.46	136.06	120.10
24 hr	171.00	151.48	131.31

1
2
3
4
5
6
7
8
9
10
11
12
13
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 14


REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Brown	9/17/88	△				
△					△				

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

It is readily apparent that the ESF AHU fan motors (100 bhp each) dramatically affect the control room temperature. Stopping at least one fan quickly should be a high priority.

As shown in section VII.F, after the control room temperature exceeds the outside makeup air temperature, the control room temperature is slightly over estimated because the ventilation cooling effect of the 1000 CFM per train flowing through the control room from the control room pressurization is neglected.





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 15

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Monus	6/13/88	△				
△					△				

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

VI. ROOM HEAT-UP COMPUTER MODEL


A. Model Description: (Reference 8)

The room heat-up computer program, RMHTUP, program number ME 204, version A1, can be used to study the room ambient air heat-up by the equipment heat or any other heat sources in the room.

The temperature of room ambient air increases with time, due to the heat released from the equipment and other sources. The heat generated within the room is transferred to the ambient room air, stored in the room enclosure (walls, ceiling, and floor) and transferred to the air outside the room.

The room walls are divided into a number of layers with incremental thicknesses for numerical computation by the computer program. In this study, the value of imaginary thickness of first layer of concrete wall is selected as 0.01 ft and the multiplication factor of imaginary thickness of other layers is taken as 1.41. In other words, the first concrete layer thickness is 0.01 ft (approximately 1/8"), the second layer thickness is 0.0141 ft (approximately 3/16"), third layer 0.01 x (1.41)² ft, etc.

The transient room temperature is determined from the heat balance equation, which balances the heat generated within the room and the heat transferred to the ambient room air, stored in the room enclosure and transferred to the outside air, as shown below:





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253


SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 16

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Norma	6/13/88	△				
△					△				

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36



$$Q_{EQUIP} = Q_{AMB AIR} + Q_{WALL} + Q_{OUTSIDE AIR}$$


WHERE Q_{EQUIP} = Heat generated from equipment or any other source in the room, BTU/HR

$Q_{AMB AIR}$ = Heat transferred to the ambient room air, BTU/HR

Q_{WALL} = Heat stored in room walls, ceiling and floor, BTU/HR.

$Q_{OUTSIDE AIR}$ = Heat transferred to the outside air, BTU/HR

The room ambient temperature and the wall temperature distribution are calculated at fixed time intervals. In addition, total heat stored in the ambient air and in the concrete walls and heat transferred to the outside air are provided for each time interval.





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 17

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Brown	6/13/88					

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

B. Input Required for the Computer Model:

The following information is required as input for transient temperature study in the Main Control Room Complex:

1. Initial room ambient temperature, degrees F
2. Initial outside ambient temperature, degrees F
3. Equipment and other heat generated in the room, BTU/HR
4. Net room surface area, ft²
5. Net room volume, ft³
6. Thickness of room enclosure, ft
7. Density of room enclosure material, lbs/ft³
8. Thermal conductivity of room material, BTU/HR-ft-F
9. Specific heat of room enclosure material, BTU/lb-F
10. One period of time increment for calculation, min
11. Imaginary thickness of first layer of room enclosure, ft
12. Multiplication factor of imaginary thickness of other layers





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 18

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Womers	6/13/88					

REV. INDI.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

C. Assumptions for the Computer Model

1. The room is simplified as an enclosed space bounded by the same thickness of walls, ceiling, and floor.
2. The gross room volume is corrected for the volume occupied by piping and equipment (see Assumption 13). "
3. The gross room surface area of the room enclosure is corrected for the area occupied by equipment (see Assumption 17).
4. The enclosure walls, ceiling and floor are taken as a heat sink.

D. Computer Model Limitations

1. The room enclosure walls, ceiling and floor must be considered as having the same thickness and of the same homogeneous material.
2. The air temperatures outside the room must be considered as being the same and remaining constant.
3. The heat generated within the room must be considered as being constant. No heat generated outside the room can be considered.
4. The program is limited to 720 time period calculations.

E. Computer Model Output

The following information is provided in the computer model output:

- TAF = Final room air temperature at each period, °F
- QAT = Heat stored in the ambient air, BTU
- QST = Total heat stored in the concrete, BTU
- QOT = Heat transferred to the outside air, BTU





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 19

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Flowers	6/13/88					

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

VII. STUDY:

This study is performed for the following case:
Control Room Complex operates at the design flow. Normal HVAC and Essential Chillers are not available. However, both essential air handling unit fans are operating. "

A. Heat Loads:

Design basis cooling for the Control Room Complex is provided by the Essential Air Handling Unit HJA-F04 or HJB-F04. Essential chilled water is recirculated through the AHU cooling coils. In the event that either the essential AHU or the essential chilled water system fails, the control room temperature will rise rapidly.

1. Essential AHU Fan Motors Heat Load:

This heat load consists of the heat generated by the Air Handling Units (HJA-F04 and HJB-F04) vaneaxial fan motors. Both essential AHU fans are running without the essential chilled water through the essential AHU cooling coils (See Assumption 9).

Essential AHU Fan Motor BHP = 100 hp (Ref. 13)
(125 hp nameplate)

Motor efficiency at full load = 92.9% (Ref. 13)

All the fan motor energy is transmitted to the Control Room Complex, although the motor is physically located, at floor elevation 74'-0". However, it is located entirely within the recirculated air stream.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 20

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	<i>[Signature]</i>	6/13/88					

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

From ref 1, chap 22, table 30, page 417,

$$\text{Heat gain from Essential AHU fan motor} = \frac{\text{Bhp} \times 2545}{\% \text{ eff}}$$

$$= \frac{100 \times 2545}{0.929}$$

$$= 273,950 \text{ BTU/HR}$$


AHU Fan motors for both essential trains are in operation during time period of this study (Refer to assumption 15).

Therefore, essential AHU Fan motors heat load for Trains A & B = 2 x 273,950 BTU/HR = 547,900 BTU/HR

2. Main Control Room Complex Heat Loads:

The Control Room normal HVAC and essential cooling system are designed to maintain the required "environment" for personnel occupancy and equipment operation during normal and emergency operations.

The heat loads in the Main Control Room Complex are different during normal and emergency conditions. The following Table 1 compares the heat loads during these two situations. The greater of each load is selected to satisfy the scenario of Section I. These heat loads include the lighting and personnel occupancy in the Main Control Room Complex and are taken from pages 6 and 7 of Reference 2.






CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-25


SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 21

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Masman	6/13/88					



SYSTEM LAYOUT

36
35
34
33
32
31
30
29
28
27
26
25
24
23
22
21
20
19
18
17
16
15
14
13
12
11
10
9
8
7
6
5
4
3
2
1





CALCULATION SHEET

PROJECT ANPP SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 22
JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

TABLE 1

CONTROL ROOM COMPLEX HEAT LOADS


	NORMAL OPERATION HEAT LOAD BTU/HR	ESSENTIAL OPERATION HEAT LOAD BTU/HR	MAX OF NORMAL/ESSENTIAL OPERATION HEAT LOAD BTU/HR
OPERATOR CONSOLE	77,127	64,385	77,127
CABINET AREA	358,185	280,000	358,185
COMPUTER ROOM	90,110	90,110	90,110
CORRIDOR	7,195	7,195	7,195
SHIFT SUPERVISOR	5,775	5,775	5,775
KITCHEN & PANTRY	9,660	9,660	9,660
OFFICE #1	4,200	4,200	4,200
OFFICE #2 & 3	13,300	13,300	13,300
INSTRUMENT REPAIR	16,000	16,000	16,000
CONFERENCE ROOM	13,875	13,875	13,875
MEN'S TOILET	2,335	2,335	2,335
WOMEN'S TOILET	2,085	2,085	2,085
RETURN AIR PLENUM	68,028	68,028	68,028
COMMUNICATIONS 120' LEVEL	22,500		22,500
SUBTOTAL	690,375	576,948	690,375
MARGIN		35,052	
TOTAL	690,375	612,000	690,375

- NOTE:
1. The heat load data is taken from the calculation 13-MC-HJ-051, Rev. 2 (Reference 2).
 2. The lighting loads are included in these heat loads.
 3. The personnel occupancy heat loads are included in the above shown heat loads.

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-58	Johnson	6/13/58	✓				

REV. INDICATOR

36 35 34 33 32 31 30 29 28 27 26 25 24 23 22 21 20 19 18 17 16 15 14 13 12 11 10 9 8 7 6 5 4 3 2 1





CALCULATION SHEET

PROJECT 20mcr ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 23

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Novak	6/13/88					

3. Total Heat Loads:

Summary of the heat loads in the Control Room Complex:

Essential AHU fan motors heat load

for Train A & B = 547,900 BTU/HR [see section VII.A.1]

Main Control Room Complex

heat load = 690,375 BTU/HR [see section VII.A.2]

Total Heat Load = 1,238,275 BTU/HR

B. MAIN CONTROL ROOM COMPLEX SURFACE AREA AND VOLUME:

Main Control Room Complex Surface Area:

Slab thickness at elevation 140'-0" = 1'-0" [Ref. 5]


Slab thickness at elevation 160'-0" = 11" [Ref. 5]

Height of the control room = 160'-140'-(0'-11") = 19'-1"

Conservatively, use room height = 19'-0"

Thickness of the control room outside walls = 1'-9" [Ref. 5]

Thickness of the control room inside walls around cable shafts and HVAC chase = 1'-0" [Ref. 5]





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 24

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Brown	6/13/88					

REV. INDICATOR

The following wall lengths are shown in Reference 5.

For 1'-9" thick wall

Length of East Side Wall =

$$(82'-6") - (8'-3") - (10'-3") = 64'-0"$$

Length of North Wall =

$$(110'-6") - (13'-3") - (20'-3") = 77'-0"$$

Length of West Wall =

$$(82'-6") - (13'-3") - (7'-3") = 62'-0"$$

Length of South Wall =

$$(110'-6") - (12'-9") - (24'-3") = 73'-6"$$

$$\begin{aligned} \text{Total Wall length} &= (64'-0") + (77'-0") + (62'-0") \\ &+ (73'-6") = 276'-6" \end{aligned}$$

$$\text{Wall Surface Area } (276'-6") \times (19'-0") = 5253.5 \text{ ft}^2$$

$$\begin{aligned} \text{Door area} &= (7'-4 \frac{1}{2}") \times (11'-0") + (3'-4 \frac{1}{2}") \\ &\times (7'-2 \frac{1}{4}") = 81.13 + 24.26 = 105.39 \text{ ft}^2 \end{aligned}$$

$$\text{Net wall surface area} = 5253.5 - 105.39 = 5148.11 \text{ ft}^2$$


For 1'-0" Thick Walls:

The walls around the outside air chase are neglected because these walls act as a heat source during the initial period and act as a heat sink during the later period (Refer to Assumption 16).

The length of the walls around the cable shafts and HVAC chases in contact with the control room

$$\begin{aligned} &= (13'-3") + (10'-3") + (13'-3") + (20'-3") + (12'-9") + \\ &(7'-3") + (17'-3") \end{aligned}$$

$$= 94'-3"$$





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 25

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Brown	6/13/88	△				
△					△				

REV. INDICATOR
↓

1
2
3
4
5
6
7
8
9
10
11
12
13
14
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

$$\begin{aligned} \text{Wall surface area} &= (94'-3") \times (19'-0") \\ &= 1790.75 \text{ ft}^2 \end{aligned}$$

$$\begin{aligned} \text{Less door area} &= (3'-4 \frac{1}{2}") \times (7'-2 \frac{1}{4}") \\ &= 24.26 \text{ ft}^2 \end{aligned}$$

$$\text{Net wall surface area} = 1790.75 - 24.26 = 1766.49 \text{ ft}^2$$

$$\begin{aligned} \text{Floor area} &= [(110'-6") \times (82'-6")] - [(13'-3") \times (10'-3")] \\ &\quad + (20'-3") \times (13'-3") + (12'-9") \times (7'-3") \\ &\quad + (24'-3") \times (8'-3") \\ &= 9116.25 - 696.63 = 8419.62 \text{ ft}^2 \end{aligned}$$

$$\text{Ceiling area (same as the floor area)} = 8419.62 \text{ ft}^2$$


$$\begin{aligned} \text{Therefore net surface area} &= 5148.11 + 1766.49 + 8419.62 + \\ &8419.62 = 23,753.84 \text{ ft}^2 \end{aligned}$$

$$\text{Use net surface area} = 23,754 \text{ ft}^2$$

As we are interested in short term results, all the heat transfer surfaces will be considered 1'-0" thick. The heat sink effect of the walls thicker than 1'-0" is significant only for the longer term. (Assumption 5).

Main Control Room Complex Volume

$$\begin{aligned} \text{Floor area} &= 8419.62 \text{ ft}^2 & \text{Height} &= 19'-0" \\ \text{Volume} &= 8419.62 \times 19 = 159,973 \text{ ft}^3 \end{aligned}$$





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 26

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	MEMD	6/13/88	△				
△					△				


REV. INDICATOR

C. Input Data:

The following input data for the computer model is used:

1. Initial room ambient temp. = 75.5° F [Assumption 1]
2. Initial outside ambient temp. = 75.5° F [Assumption 2]
3. Equipment and other net heat generated in the room = 1,238,275 BTU/HR [See Section VII.A.3]
4. Net room surface area = 23,754 FT² [See Section VII.B]
5. Net room volume = 159,973 FT³ [See Section VII.B]
6. Thickness of room enclosure = 1'-0" FT [Ref 5 and Assumption 5]
7. Density of room enclosure material = 144 LBS/FT³ [Ref 12]
8. Thermal conductivity of room enclosure material = 0.54 BTU/HR-FT-°F [Ref 12]
9. Specific heat of room enclosure material = 0.2 BTU/LB-°F [Ref 12]
10. One period of increment for calculation = 2 min [Assumption 10]
11. Imaginary thickness of first layer of concrete enclosure = 0.01 FT [Assumption 11]
12. Multiplication factor of imaginary thickness of other layers = 1.41 [Assumption 11]

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36





CALCULATION SHEET

24mcr
PROJECT

ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 27

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	<i>Yezna</i>	6/13/88	△				
△					△				

REV. 4 INDI.


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

Effect of AHUs on Control Room Complex Temperature

The two ESF AHU fans are 44% of the total heat load. To evaluate this sensitivity two additional computer runs are made for the cases where only one or none of the two ESF AHU fan motors are running. Only input data item #3 in the above table is changed.

For one ESF AHU fan motor running, the heat load is
 $1,238,275 - 273,950 = 964,325$ BTU/HR.

For no ESF AHU fans running, the heat load is
 $1,238,275 - 2 \times 273,950 = 690,375$ BTU/HR.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 2B

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Power	6/13/88					


REV. INDICATOR

D. RESULTS:

The transient room air temperature for the Main Control Room Complex obtained from the computer output, is shown in Figure 1. The transient temperature output, Appendix A, shows that with both essential AHU fans of Trains A & B, operating under conditions outlined in Section I, the calculated temperature in the pump room will be as shown below. For cases with one or no fans running, the transient temperature outputs, Appendices B and C, are also presented:

Time Period	Appendix A	Appendix B	Appendix C
	Control Room w/2 ESF Fans	Control Room w/1 ESF Fan	Control Room w/No ESF Fans
	Temp. °F	Temp. °F	Temp. °F
0 min	75.5	75.5	75.5
2 min	86.07	83.79	81.49
4 min	93.65	89.78	85.86
6 min	99.00	94.06	89.02
12 min	107.43	100.95	94.23
36 min	115.21	107.38	99.19
60 min	118.50	110.00	101.12
84 min	121.05	112.03	102.60
96 min	122.18	112.92	103.25
2 hr	124.21	114.52	104.42
4 hr	132.05	120.73	108.95
6 hr	138.02	125.45	112.38
8 hr	143.03	129.40	115.26
12 hr	151.46	136.06	120.10
24 hr	171.00	151.48	131.31

1
2
3
4
5
6
7
8
9
10
11
12
13
14
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
33
34
35
36





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 29


REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE	REV. INDICATOR
0	PSS	6-13-88	Donna	6/13/88						

E. DISCUSSION of RESULTS:

As shown in Appendix A, the temperature inside the Main Control Room Complex is lower than the outside temperature of 101.3°F (Reference 16) for the first 6 to 8 minutes (for the base case of 2 fans running) and is higher after this time period. Therefore, a small percentage of the total heat will be added to the Control Room Complex by the outside makeup air during the first few minutes, while it will provide a very small amount of cooling after this time interval. The initial heat source effect is insignificant as shown in Section VII.F and is excluded.

Reviewing the above results, it is concluded that the temperature after the first 6 to 8 minutes (for the base case) is slightly overestimated due to the ventilation cooling effect of the two essential control room pressurization trains. Each of these two trains has a flow of 1000 cfm through the Main Control Room Complex (Ref. 14, page 2). The total ventilation cooling effect would only be on the order of 5% of the control room heat load when the control room temperature reached 130°F.

As can be readily seen by looking at the results of the cases with less than two ESF AHU fans operating, stopping one of the fans as soon as possible will dramatically decrease the rate of temperature rise in the control room complex. Stopping both fans may be undesirable, because "hot spots" could result in the various small rooms within the complex. Further evaluation would be required to assess this effect. Stopping both fans also is not consistent with the LOCA scenario described in section I.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 30

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
△	PSS	6-13-88	Nonu	6/17/88	△				
△					△				

REV. INDICATOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

F. EFFECT OF OUTSIDE MAKEUP AIR

Outside makeup air flow for each ESF AHU train = 1000 cfm
[Ref. 14, page 2]

Outside makeup air temperature = 101.3°F [Ref. 16]

Time required for the Main Control Room Complex to reach
101.3°F, when both ESF AHU fans are operating = 6 to 8 minutes
[Ref. Appendix A]

The makeup air flow will act as a heat source initially and
later as a heat sink.

The average rate of heat added to the Main Control Room Complex
due to both essential makeup trains before the control room
temperature equals the outside makeup air temperature is


$$= 1.08 \times \text{cfm} \times \frac{\Delta T}{2} \text{ [Reference 1, Chapter 19, Page 343, Equation 5]}$$

$$= 1.08 \times (2 \times 1000) \times \frac{101.3 - 75.5}{2} \text{ BTU/HR}$$

$$= 27,864 \text{ BTU/HR}$$

Therefore, heat load added to the Main Control Room Complex

$$= \frac{27,864}{60} \times 8 \text{ minutes} = 3715 \text{ BTU}$$





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 31

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. H. M. L.	6/13/88	△				
△					△				

REV. AMEND.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

Specific heat of steel = 0.104 BTU/lb - °F [Ref. 12, table A-1]

Weight of steel required to absorb the added heat load

$$= \frac{3715 \text{ BTU}}{0.104 \text{ BTU/lb} - ^\circ\text{F} \times (101.3 - 75.5) ^\circ\text{F}} = 1385 \text{ lb}$$

Similarly, for the cases of one and no ESF AHU fans running, the times at which the control room temperature equals the outside air temperature are approximately 15 minutes and 60 minutes respectively. The heat load added to the control room are 6,966 and 27,864 BTU requiring approximately 2,600, and 10,400 lb of steel, respectively, to absorb that heat.

By inspection, it is obvious that the Main Control Room has a large amount of steel consisting of panels, cabinets, beams, reinforcements, etc. that is many times more than the required weight of 10,400 lb.

Therefore, the heat source effect of the outside makeup air is insignificant and does not need to be included.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601. - 200 CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 32

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Demus	4/13/88	△				
△					△				

REV. INDI.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

In order to obtain slightly more accurate transient temperatures for the main control room, the Bechtel Computer Program NE-100 (COPPATTA-7) may be used instead of ME-204. The computer program NE-100 has the following advantages over ME-204:

1. Heat Sink Model:


The metal items (e.g. cabinets, cable trays, structural steel and concrete) in the main control room can be modeled with much more complexity and accuracy rather than consideration as a lump sum mass. This will lead to higher accuracy in predicting long term (e.g. 24 hours) room temperatures.

2. Effect of Outside Air:

The effect of the outside air in terms of the flow and temperature is accounted for in NE-100 and, therefore, represents a better temperature profile over the short term (e.g. 90 minutes).

3. Air Handling Units On and Off Simulation:

AHU performance is used as an input in the computer program NE-100. The temperature transient can be determined at any given time following the restoration of the chilled water through the AHU.





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 33

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
△	PSS	6-13-88	W. W. W.	6/13/88	△				
△					△				





FIGURE 1





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 34

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
△	PSS	6-13-88	Z/MOR	6/13/88	△				
△					△				

REV. 4/10/81

APPENDIX A

- INITIAL INTERNAL ROOM AMBIENT TEMPERATURE, DEG. F=?
- >75.5
- INITIAL ADJACENT ROOM AMBIENT TEMPERATURE, DEG. F=?
- >75.5
- EQUIPMENT HEAT GENERATED IN THE INTERNAL ROOM, BTU/HR=?
- >1238275
- NET INTERNAL ROOM SURFACE AREA, SQ. FT.=?
- >23754
- NET INTERNAL ROOM VOLUME, CU.FT.=?
- >159973
- THICKNESS OF ROOM ENCLOSURE, FT.=?
- >1
- DENSITY OF ROOM ENCLOSURE MATERIAL, LBS/CU.FT.=?
- >144
- THERMAL CONDUCTIVITY OF ROOM ENCLOSURE MATERIAL, BTU/HR-FT-F=?
- >.54
- SPECIFIC HEAT OF ROOM ENCLOSURE MATERIAL, BTU/LB-F=?
- >.2
- ONE PERIOD OF TIME INCREMENT FOR CALCULATION, MIN.=?
- >2
- IMAGINARY THICKNESS OF FIRST LAYER OF ROOM ENCLOSURE, FT.=?
- >.01
- MULTIPLICATION FACTOR OF IMAGINARY THICKNESS OF OTHER LAYERS=?
- >1.41

 * COPYRIGHT 1976, 1979 BECHTEL POWER CORPORATION. ALL RIGHTS RESERVED. *

M=NUMBER OF IMAGINARY LAYER= 11

DX1, DX2, DX3, -----DX(M)					
1.00000-02	1.41000-02	1.98810-02	2.80322-02	3.95254-02	5.57308-02
7.85805-02	.11080	.15623	.22028	.26685	


2 MIN

1 PERIOD QAT= 30146. QST= 11130. QOT= 0. HCI=1.4057 HCO= .0000
 TAF= 86.07

T1, T2, T3, -----T(M+1)					
76.073	75.889	75.729	75.612	75.542	75.512
75.502	75.500	75.500	75.500	75.500	75.500

2 PERIOD QAT= 51331. QST= 31219. QOT= 0. HCI=1.5099 HCO= .0000
 TAF= 93.65

T1, T2, T3, -----T(M+1)					
76.845	76.484	76.135	75.845	75.648	75.547
75.510	75.501	75.500	75.500	75.500	75.500





CALCULATION SHEET

PROJECT ANPPJOB NO. 18601 - 200CALC. NO. 13-MC-HJ-253SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOMSHEET NO. 35

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE	REV. INDICATOR
0	PSS	6-13-88	Merit	6/13/88	△					
△					△					

1
2
3
4
5
6
7
8
9
10
11
12
13
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
34
35
36

3 PERIOD QAT= 66090. QST= 57736. QOT= 0. HCI=1.5694 HCO= .0000
 TAF= 99.00
 T1, T2, T3, -----T(M+1)
 77.659 77.158 76.639 76.169 75.817 75.612
 75.527 75.504 75.500 75.500 75.500 75.500

6 PERIOD QAT= 89025. QST= 158627. QOT= 0. HCI=1.6490 HCO= .9473
 TAF= 107.43
 T1, T2, T3, -----T(M+1)
 79.875 79.138 78.287 77.394 76.583 75.984
 75.654 75.531 75.504 75.500 75.500 75.500

12 PERIOD QAT= 103455. QST= 391850. QOT= 0. HCI=1.6893 HCO= .9538
 TAF= 112.81
 T1, T2, T3, -----T(M+1)
 83.033 82.172 81.091 79.817 78.450 77.182
 76.237 75.721 75.540 75.504 75.500 75.500

18 PERIOD QAT= 109848. QST= 633106. QOT= 2. HCI=1.7039 HCO= .9621
 TAF= 115.21
 T1, T2, T3, -----T(M+1)
 85.286 84.396 83.246 81.827 80.195 78.516
 77.063 76.091 75.643 75.519 75.501 75.501

24 PERIOD QAT= 114581. QST= 876017. QOT= 9. HCI=1.7141 HCO= .9718
 TAF= 116.99
 T1, T2, T3, -----T(M+1)
 87.117 86.214 85.031 83.535 81.751 79.808
 77.973 76.582 75.818 75.555 75.504 75.502


IHR 30 PERIOD QAT= 118574. QST= 1119654. QOT= 30. HCI=1.7226 HCO= .9823
 TAF= 118.50
 T1, T2, T3, -----T(M+1)
 88.702 87.792 86.587 85.042 83.156 81.027
 78.900 77.145 76.058 75.616 75.510 75.507

36 PERIOD QAT= 122103. QST= 1363727. QOT= 80. HCI=1.7301 HCO= .9930
 TAF= 119.84
 T1, T2, T3, -----T(M+1)
 90.121 89.205 87.985 86.405 84.446 82.176
 79.818 77.750 76.349 75.704 75.521 75.514

42 PERIOD QAT= 125301. QST= 1608083. QOT= 177. HCI=1.7370 HCO=1.0039
 TAF= 121.05
 T1, T2, T3, -----T(M+1)
 91.417 90.497 89.266 87.659 85.643 83.263
 80.716 78.377 76.680 75.817 75.538 75.526

48 PERIOD QAT= 128247. QST= 1852622. QOT= 345. HCI=1.7433 HCO=1.0147
 TAF= 122.18
 T1, T2, T3, -----T(M+1)
 92.617 91.694 90.454 88.826 86.764 84.295
 81.590 79.015 77.043 75.956 75.564 75.542

2HR 60 PERIOD QAT= 133569. QST= 2341939. QOT= 1007. HCI=1.7548 HCO=1.0358
 TAF= 124.21





CALCULATION SHEET

PROJECT ANPPJOB NO. 18601 - 200CALC. NO. 13-MC-HJ-25SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOMSHEET NO. 36

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	5-13-88	Norma	5/13/88	1				
1					2				

REV. 4

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

T1, T2, T3, -----T(M+1)
 94.801 93.873 92.619 90.959 88.828 86.221
 83.266 80.298 77.832 76.295 75.641 75.593

72 PERIOD QAT= 138328. QST= 2831166. QOT= 2323. HCI=1.7652 HCO=1.0559
 TAF= 126.03

T1, T2, T3, -----T(M+1)
 96.766 95.835 94.571 92.888 90.705 87.995
 84.849 81.568 78.675 76.702 75.757 75.669

84 PERIOD QAT= 142670. QST= 3319877. QOT= 4572. HCI=1.7747 HCO=1.0749
 TAF= 127.69

T1, T2, T3, -----T(M+1)
 98.568 97.634 96.363 94.661 92.440 89.650
 86.351 82.811 79.548 77.161 75.914 75.770

96 PERIOD QAT= 146687. QST= 3807692. QOT= 8043. HCI=1.7836 HCO=1.0928
 TAF= 129.24

T1, T2, T3, -----T(M+1)
 100.24 99.305 98.028 96.312 94.059 91.204
 87.781 84.024 80.435 77.661 76.110 75.896

108 PERIOD QAT= 150441. QST= 4294262. QOT= 13019. HCI=1.7919 HCO=1.1097
 TAF= 130.69

T1, T2, T3, -----T(M+1)
 101.81 100.87 99.591 97.863 95.584 92.675
 89.147 85.204 81.326 78.193 76.344 76.045

4HR 120 PERIOD QAT= 153976. QST= 4779273. QOT= 19773. HCI=1.7999 HCO=1.1256
 TAF= 132.05

T1, T2, T3, -----T(M+1)
 103.29 102.35 101.07 99.330 97.029 94.074
 90.456 86.351 82.215 78.749 76.612 76.215

132 PERIOD QAT= 157325. QST= 5262439. QOT= 28557. HCI=1.8075 HCO=1.1406
 TAF= 133.35

T1, T2, T3, -----T(M+1)
 104.70 103.76 102.47 100.73 98.405 95.410
 91.715 87.466 83.099 79.326 76.912 76.403

144 PERIOD QAT= 160514. QST= 5743502. QOT= 39605. HCI=1.8147 HCO=1.1547
 TAF= 134.59


T1, T2, T3, -----T(M+1)
 106.05 105.11 103.81 102.06 99.721 96.692
 92.927 88.552 83.976 79.920 77.239 76.607

156 PERIOD QAT= 163563. QST= 6222226. QOT= 53131. HCI=1.8217 HCO=1.1681
 TAF= 135.78

T1, T2, T3, -----T(M+1)
 107.34 106.39 105.10 103.34 100.98 97.924
 94.099 89.610 84.844 80.526 77.592 76.826

168 PERIOD QAT= 166488. QST= 6698404. QOT= 69327. HCI=1.8284 HCO=1.1808
 TAF= 136.92

T1, T2, T3, -----T(M+1)
 108.57 107.63 106.33 104.57 102.20 99.113
 95.233 90.642 85.704 81.144 77.966 77.057





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM


SHEET NO. 37

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
△	PSS	6-13-88	Y. B. M. S.	6/13/88	△				
△					△				

REV. 4-INDI-

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

6 HR	180 PERIOD	QAT= 169303.	QST= 7171850.	QOT= 88365.	HCI=1.8350	HCO=1.1929
	TAF= 138.02					
	T1, T2, T3, -----T(M+1)					
	109.77	108.82	107.52	105.75	103.38	100.26
	96.333	91.649	86.554	81.770	78.359	77.299
	192 PERIOD	QAT= 172017.	QST= 7642399.	QOT= 110400.	HCI=1.8413	HCO=1.2043
	TAF= 139.08					
	T1, T2, T3, -----T(M+1)					
	110.92	109.98	108.68	106.90	104.51	101.38
	97.402	92.634	87.395	82.403	78.769	77.549
	204 PERIOD	QAT= 174642.	QST= 8109906.	QOT= 135567.	HCI=1.8474	HCO=1.2153
	TAF= 140.11					
	T1, T2, T3, -----T(M+1)					
	112.04	111.09	109.79	108.01	105.61	102.46
	98.443	93.598	88.227	83.042	79.193	77.807
	216 PERIOD	QAT= 177186.	QST= 8574241.	QOT= 163986.	HCI=1.8534	HCO=1.2257
	TAF= 141.11					
	T1, T2, T3, -----T(M+1)					
	113.13	112.18	110.87	109.09	106.68	103.51
	99.458	94.543	89.049	83.684	79.628	78.071
	228 PERIOD	QAT= 179655.	QST= 9035290.	QOT= 195762.	HCI=1.8593	HCO=1.2356
	TAF= 142.08					
	T1, T2, T3, -----T(M+1)					
	114.18	113.23	111.93	110.14	107.72	104.53
	100.45	95.469	89.864	84.330	80.074	78.340
8 HR	240 PERIOD	QAT= 182056.	QST= 9492960.	QOT= 230985.	HCI=1.8650	HCO=1.2451
	TAF= 143.03					
	T1, T2, T3, -----T(M+1)					
	115.21	114.26	112.95	111.16	108.74	105.53
	101.42	96.379	90.669	84.977	80.528	78.613
	264 PERIOD	QAT= 186678.	QST=10397839.	QOT= 312073.	HCI=1.8761	HCO=1.2630
	TAF= 144.85					
	T1, T2, T3, -----T(M+1)					
	117.19	116.24	114.93	113.13	110.70	107.47
	103.30	98.151	92.255	86.274	81.455	79.167
	288 PERIOD	QAT= 191087.	QST=11288342.	QOT= 407749.	HCI=1.8868	HCO=1.2795
	TAF= 146.60					
	T1, T2, T3, -----T(M+1)					
	119.09	118.14	116.83	115.02	112.58	109.32
	105.10	99.868	93.809	87.570	82.400	79.727
	312 PERIOD	QAT= 195315.	QST=12164094.	QOT= 518358.	HCI=1.8971	HCO=1.2947
	TAF= 148.27					
	T1, T2, T3, -----T(M+1)					
	120.91	119.96	118.65	116.84	114.39	111.11
	106.85	101.54	95.332	88.858	83.354	80.290
	336 PERIOD	QAT= 199385.	QST=13024844.	QOT= 644126.	HCI=1.9072	HCO=1.3089





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-2^E

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 38

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Norman	6/3/88					

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

TAF= 149.89
 T1, T2, T3, -----T(M+1)
 122.67 121.72 120.41 118.59 116.13 112.84
 108.54 103.16 96.825 90.137 84.311 80.850

12 HR 360 PERIOD QAT= 203316. QST=13870448. QOT= 785179. HCI=1.9169 HCO=1.3221
 TAF= 151.46
 T1, T2, T3, -----T(M+1)
 124.38 123.43 122.11 120.29 117.82 114.51
 110.19 104.74 98.290 91.402 85.265 81.406

432 PERIOD QAT= 214410. QST=16316066. QOT= 1300238. HCI=1.9450 HCO=1.3570
 TAF= 155.91
 T1, T2, T3, -----T(M+1)
 129.21 128.25 126.93 125.11 122.62 119.27
 114.87 109.26 102.52 95.099 88.083 83.032

504 PERIOD QAT= 224648. QST=18626323. QOT= 1951468. HCI=1.9714 HCO=1.3863
 TAF= 160.05
 T1, T2, T3, -----T(M+1)
 133.69 132.74 131.42 129.59 127.08 123.70
 119.23 113.50 106.50 98.624 90.790 84.574

576 PERIOD QAT= 234181. QST=20805265. QOT= 2734703. HCI=1.9966 HCO=1.4113
 TAF= 163.92
 T1, T2, T3, -----T(M+1)
 137.89 136.94 135.61 133.78 131.26 127.86
 123.33 117.48 110.27 101.97 93.361 86.022

648 PERIOD QAT= 243095. QST=22858263. QOT= 3644503. HCI=2.0206 HCO=1.4331
 TAF= 167.56
 T1, T2, T3, -----T(M+1)
 141.84 140.89 139.56 137.72 135.19 131.76
 127.18 121.24 113.82 105.12 95.787 87.376

24 HR 720 PERIOD QAT= 251449. QST=24791227. QOT= 4674899. HCI=2.0435 HCO=1.4522
 TAF= 171.00
 T1, T2, T3, -----T(M+1)
 145.56 144.60 143.27 141.43 138.89 135.44
 130.81 124.77 117.16 108.10 98.070 88.640

REV.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-21

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 39

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
△	PSS	6-13-88	Tomal	6/13/88	△				
△					△				

APPENDIX B

- INITIAL INTERNAL ROOM AMBIENT TEMPERATURE, DEG. F=?
- >75.5
- INITIAL ADJACENT ROOM AMBIENT TEMPERATURE, DEG. F=?
- >75.5
- EQUIPMENT HEAT GENERATED IN THE INTERNAL ROOM, BTU/HR=?
- >964325
- NET INTERNAL ROOM SURFACE AREA, SQ. FT.=?
- >23754
- NET INTERNAL ROOM VOLUME, CU.FT.=?
- >159973
- THICKNESS OF ROOM ENCLOSURE, FT.=?
- >1
- DENSITY OF ROOM ENCLOSURE MATERIAL, LBS/CU.FT.=?
- >144
- THERMAL CONDUCTIVITY OF ROOM ENCLOSURE MATERIAL, BTU/HR-FT-F=?
- >.54
- SPECIFIC HEAT OF ROOM ENCLOSURE MATERIAL, BTU/LB-F=?
- >.2
- ONE PERIOD OF TIME INCREMENT FOR CALCULATION, MIN.=?
- >2
- IMAGINARY THICKNESS OF FIRST LAYER OF ROOM ENCLOSURE, FT.=?
- >.01
- MULTIPLICATION FACTOR OF IMAGINARY THICKNESS OF OTHER LAYERS=?
- >1.41


 * COPYRIGHT 1976, 1979 BECHTEL POWER CORPORATION. ALL RIGHTS RESERVED. *

M=NUMBER OF IMAGINARY LAYER= 11

DX1, DX2, DX3, -----DX (M)					
1.00000-02	1.41000-02	1.98810-02	2.80322-02	3.95254-02	5.57308-02
7.85805-02	.11080	.15623	.22028	.26685	

2 MIN 1 PERIOD QAT= 23648. QST= 8495. QOT= 0. HCI=1.3656 HCO= .0000
 TAF= 83.79
 T1, T2, T3, -----T(M+1)
 75.937 75.797 75.675 75.585 75.532 75.509
 75.502 75.500 75.500 75.500 75.500 75.500

2 PERIOD QAT= 40472. QST= 23816. QOT= 0. HCI=1.4593 HCO= .0000
 TAF= 89.78
 T1, T2, T3, -----T(M+1)
 76.526 76.251 75.984 75.763 75.613 75.536
 75.507 75.501 75.500 75.500 75.500 75.500





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601.- 200

CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 40

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Jones	6/13/88					

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

3 PERIOD QAT= 52355. QST= 44076. QOT= 0. HCI=1.5129 HCO= .0000
 TAF= 94.06
 T1, T2, T3, -----T(M+1)
 77.149 76.766 76.370 76.011 75.742 75.585
 75.520 75.503 75.500 75.500 75.500 75.500

6 PERIOD QAT= 71261. QST= 121600. QOT= 0. HCI=1.5848 HCO= .9468,
 TAF= 100.95
 T1, T2, T3, -----T(M+1)
 78.859 78.292 77.637 76.951 76.329 75.871
 75.618 75.524 75.503 75.500 75.500 75.500

12 PERIOD QAT= 83423. QST= 302301. QOT= 0. HCI=1.6211 HCO= .9530
 TAF= 105.43
 T1, T2, T3, -----T(M+1)
 81.327 80.658 79.820 78.832 77.775 76.795
 76.066 75.670 75.531 75.503 75.500 75.500

18 PERIOD QAT= 88687. QST= 489897. QOT= 1. HCI=1.6331 HCO= .9607
 TAF= 107.38
 T1, T2, T3, -----T(M+1)
 83.089 82.397 81.503 80.400 79.133 77.832
 76.707 75.956 75.610 75.515 75.501 75.500

24 PERIOD QAT= 92522. QST= 678918. QOT= 7. HCI=1.6412 HCO= .9696
 TAF= 108.80
 T1, T2, T3, -----T(M+1)
 84.520 83.817 82.896 81.733 80.346 78.837
 77.414 76.336 75.746 75.542 75.503 75.502

1HR

30 PERIOD QAT= 95742. QST= 868542. QOT= 23. HCI=1.6479 HCO= .9791
 TAF= 110.00
 T1, T2, T3, -----T(M+1)
 85.757 85.048 84.111 82.909 81.442 79.787
 78.136- 76.774 75.931 75.589 75.507 75.505

36 PERIOD QAT= 98585. QST= 1058523. QOT= 61. HCI=1.6538 HCO= .9890
 TAF= 111.07
 T1, T2, T3, -----T(M+1)
 86.863 86.150 85.201 83.972 82.447 80.683
 78.850 77.244 76.157 75.657 75.516 75.511

42 PERIOD QAT= 101160. QST= 1248735. QOT= 136. HCI=1.6591 HCO= .9990
 TAF= 112.03
 T1, T2, T3, -----T(M+1)
 87.874 87.158 86.199 84.949 83.380 81.529
 79.549 77.732 76.415 75.746 75.530 75.520

48 PERIOD QAT= 103530. QST= 1439096. QOT= 265. HCI=1.6640 HCO=1.0090
 TAF= 112.92
 T1, T2, T3, -----T(M+1)
 88.810 88.091 87.126 85.859 84.254 82.333
 80.230 78.228 76.696 75.853 75.549 75.533

2HR

60 PERIOD QAT= 107814. QST= 1820025. QOT= 776. HCI=1.6729 HCO=1.0284
 TAF= 114.52

REV.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-25SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 41

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Donal	6/13/88					

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

T1, T2, T3, -----T(M+1)
 90.512 89.789 88.813 87.521 85.862 83.834
 81.535 79.227 77.310 76.116 75.609 75.572

72 PERIOD QAT= 111645. QST= 2200903. QOT= 1789. HCI=1.6809 HCO=1.0469
 TAF= 115.97

T1, T2, T3, -----T(M+1)
 92.043 91.318 90.334 89.024 87.325 85.216
 82.768 80.215 77.966 76.433 75.699 75.631

84 PERIOD QAT= 115140. QST= 2581397. QOT= 3522. HCI=1.6882 HCO=1.0644
 TAF= 117.28

T1, T2, T3, -----T(M+1)
 93.447 92.720 91.731 90.406 88.677 86.505
 83.938 81.184 78.646 76.790 75.821 75.710

96 PERIOD QAT= 118374. QST= 2961211. QOT= 6196. HCI=1.6950 HCO=1.0808
 TAF= 118.51

T1, T2, T3, -----T(M+1)
 94.751 94.022 93.028 91.692 89.938 87.716
 85.052 82.128 79.336 77.179 75.973 75.809

108 PERIOD QAT= 121397. QST= 3340078. QOT= 10028. HCI=1.7014 HCO=1.0963
 TAF= 119.65

T1, T2, T3, -----T(M+1)
 95.974 95.244 94.246 92.901 91.126 88.861
 86.116 83.047 80.030 77.593 76.155 75.925

4 HR 120 PERIOD QAT= 124245. QST= 3717751. QOT= 15228. HCI=1.7075 HCO=1.1109
 TAF= 120.73

T1, T2, T3, -----T(M+1)
 97.129 96.398 95.396 94.043 92.252 89.951
 87.135 83.940 80.722 78.026 76.364 76.058

132 PERIOD QAT= 126944. QST= 4094013. QOT= 21991. HCI=1.7133 HCO=1.1247
 TAF= 121.76

T1, T2, T3, -----T(M+1)
 98.227 97.494 96.490 95.130 93.324 90.992
 88.115 84.809 81.410 78.475 76.597 76.205

144 PERIOD QAT= 129514. QST= 4468658. QOT= 30494. HCI=1.7188 HCO=1.1377
 TAF= 122.74

T1, T2, T3, -----T(M+1)
 99.274 98.541 97.534 96.169 94.349 91.990
 89.060 85.655 82.093 78.937 76.851 76.365


156 PERIOD QAT= 131972. QST= 4841512. QOT= 40902. HCI=1.7241 HCO=1.1500
 TAF= 123.68

T1, T2, T3, -----T(M+1)
 100.28 99.544 98.535 97.164 95.333 92.950
 89.972 86.478 82.769 79.409 77.126 76.536

168 PERIOD QAT= 134331. QST= 5212414. QOT= 53363. HCI=1.7292 HCO=1.1617
 TAF= 124.58

T1, T2, T3, -----T(M+1)
 101.24 100.51 99.497 98.122 96.281 93.876
 90.856 87.282 83.438 79.890 77.417 76.718

REV.





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 42

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE	REV.
0	PSS	6-13-88	Norma	6/13/88						

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

6 HR

180 PERIOD QAT= 136601. QST= 5581218. QOT= 68007. HCI=1.7342 HCO=1.1727
 TAF= 125.45
 T1, T2, T3, -----T(M+1)
 102.17 101.44 100.42 99.045 97.195 94.772
 91.712 88.066 84.100 80.377 77.723 76.907

192 PERIOD QAT= 138791. QST= 5947801. QOT= 84954. HCI=1.7390 HCO=1.1832
 TAF= 126.29
 T1, T2, T3, -----T(M+1)
 103.07 102.34 101.32 99.938 98.080 95.639
 92.545 88.834 84.755 80.870 78.042 77.104

204 PERIOD QAT= 140909. QST= 6312049. QOT= 104308. HCI=1.7437 HCO=1.1932
 TAF= 127.10
 T1, T2, T3, -----T(M+1)
 103.94 103.21 102.19 100.80 98.938 96.481
 93.356 89.584 85.403 81.367 78.372 77.307

216 PERIOD QAT= 142961. QST= 6673865. QOT= 126159. HCI=1.7482 HCO=1.2028
 TAF= 127.89
 T1, T2, T3, -----T(M+1)
 104.79 104.05 103.03 101.64 99.771 97.300
 94.146 90.320 86.043 81.867 78.712 77.514

228 PERIOD QAT= 144955. QST= 7033162. QOT= 150589. HCI=1.7526 HCO=1.2119
 TAF= 128.65
 T1, T2, T3, -----T(M+1)
 105.61 104.87 103.85 102.46 100.58 98.099
 94.918 91.041 86.677 82.370 79.059 77.726

8 HR


240 PERIOD QAT= 146893. QST= 7389865. QOT= 177666. HCI=1.7570 HCO=1.2206
 TAF= 129.40
 T1, T2, T3, -----T(M+1)
 106.41 105.67 104.65 103.26 101.37 98.877
 95.672 91.750 87.305 82.874 79.413 77.941

264 PERIOD QAT= 150626. QST= 8095242. QOT= 239995. HCI=1.7653 HCO=1.2370
 TAF= 130.84
 T1, T2, T3, -----T(M+1)
 107.95 107.22 106.19 104.80 102.90 100.38
 97.135 93.130 88.540 83.884 80.137 78.378

288 PERIOD QAT= 154188. QST= 8789580. QOT= 313526. HCI=1.7734 HCO=1.2520
 TAF= 132.22
 T1, T2, T3, -----T(M+1)
 109.43 108.69 107.67 106.27 104.36 101.83
 98.543 94.467 89.750 84.893 80.874 78.820

312 PERIOD QAT= 157605. QST= 9472593. QOT= 398527. HCI=1.7812 HCO=1.2660
 TAF= 133.54
 T1, T2, T3, -----T(M+1)
 110.85 110.11 109.09 107.68 105.77 103.22
 99.903 95.765 90.936 85.897 81.619 79.264

316 PERIOD QAT= 160896 QST= 10144086 QOT= 495171 HCI=1.7897 HCO=1.2780





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 43

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. Jones	6/13/88	△				
△					△				

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

TAF= 134.82

T1, T2, T3, -----T(M+1)

112.22	111.48	110.46	109.05	107.13	104.57
101.22	97.028	92.099	86.893	82.367	79.708

12 HR

360 PERIOD QAT= 164075. QST=10803951. QOT= 603557. HCI=1.7960 HCO=1.2910

TAF= 136.06

T1, T2, T3, -----T(M+1)

113.55	112.81	111.78	110.37	108.45	105.87
102.50	98.259	93.240	87.880	83.113	80.148

432 PERIOD QAT= 173055. QST=12713487. QOT= 999325. HCI=1.8170 HCO=1.3229

TAF= 139.57

T1, T2, T3, -----T(M+1)

117.31	116.57	115.54	114.12	112.19	109.58
106.15	101.78	96.533	90.763	85.319	81.437

504 PERIOD QAT= 181352. QST=14519037. QOT= 1499768. HCI=1.8368 HCO=1.3495

TAF= 142.83

T1, T2, T3, -----T(M+1)

120.81	120.07	119.03	117.61	115.66	113.03
109.55	105.09	99.643	93.516	87.441	82.664

576 PERIOD QAT= 189088. QST=16223610. QOT= 2101749. HCI=1.8555 HCO=1.3723

TAF= 145.89

T1, T2, T3, -----T(M+1)

124.08	123.34	122.31	120.88	118.92	116.27
112.74	108.19	102.58	96.128	89.458	83.818

648 PERIOD QAT= 196333. QST=17831216. QOT= 2801153. HCI=1.8733 HCO=1.3921

TAF= 148.77

T1, T2, T3, -----T(M+1)

127.16	126.42	125.38	123.95	121.98	119.31
115.75	111.12	105.35	98.597	91.366	84.899

24 HR


720 PERIOD QAT= 203133. QST=19346347. QOT= 3593460. HCI=1.8903 HCO=1.4095

TAF= 151.48

T1, T2, T3, -----T(M+1)

130.06	129.32	128.28	126.85	124.87	122.18
118.58	113.88	107.97	100.93	93.163	85.911

>





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-25
 SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 44

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	J. M. M.	6/13/88	△				
△					△				

APPENDIX C

- INITIAL INTERNAL ROOM AMBIENT TEMPERATURE, DEG. F=?
>75.5
- INITIAL ADJACENT ROOM AMBIENT TEMPERATURE, DEG. F=?
>75.5
- EQUIPMENT HEAT GENERATED IN THE INTERNAL ROOM, BTU/HR=?
>690375
- NET INTERNAL ROOM SURFACE AREA, SQ. FT.=?
>23754
- NET INTERNAL ROOM VOLUME, CU.FT.=?
>159973
- THICKNESS OF ROOM ENCLOSURE, FT.=?
>1
- DENSITY OF ROOM ENCLOSURE MATERIAL, LBS/CU.FT.=?
>144
- THERMAL CONDUCTIVITY OF ROOM ENCLOSURE MATERIAL, BTU/HR-FT-F=?
>.54
- SPECIFIC HEAT OF ROOM ENCLOSURE MATERIAL, BTU/LB-F=?
>.2
- ONE PERIOD OF TIME INCREMENT FOR CALCULATION, MIN.=?
>2
- IMAGINARY THICKNESS OF FIRST LAYER OF ROOM ENCLOSURE, FT.=?
>.01
- MULTIPLICATION FACTOR OF IMAGINARY THICKNESS OF OTHER LAYERS=?
>1.41

 * COPYRIGHT 1976, 1979 BECHTEL POWER CORPORATION. ALL RIGHTS RESERVED. *


M=NUMBER OF IMAGINARY LAYER= 11

DX1, DX2, DX3, -----DX (M)					
1.00000-02	1.41000-02	1.98810-02	2.80322-02	3.95254-02	5.57308-02
7.85805-02	.11080	.15623	.22028	.26685	

2 MIN

1 PERIOD	QAT= 17078.	QST= 5934.	QOT=	0. HCI=1.3185	HCO= .0000
TAF= 81.49					
T1, T2, T3, -----T (M+1)					
75.805	75.708	75.622	75.560	75.523	75.506
75.501	75.500	75.500	75.500	75.500	75.500

2 PERIOD	QAT= 29400.	QST= 16624.	QOT=	0. HCI=1.4002	HCO= .0000
TAF= 85.86					
T1, T2, T3, -----T (M+1)					
76.216	76.024	75.838	75.684	75.579	75.525
75.505	75.501	75.500	75.500	75.500	75.500





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-25

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 45

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Donna	6/13/88					

1
2
3
4
5
6
7
8
9
10
11
12
13
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

3 PERIOD QAT= 38244. QST= 30792. QOT= 0. HCI=1.4468 HCO= .0000
 TAF= 89.02
 T1, T2, T3, -----T(M+1)
 76.652 76.385 76.108 75.857 75.669 75.560
 75.514 75.502 75.500 75.500 75.500 75.500

6 PERIOD QAT= 52704. QST= 85368. QOT= 0. HCI=1.5099 HCO= .9468
 TAF= 94.23
 T1, T2, T3, -----T(M+1)
 77.863 77.463 77.002 76.519 76.081 75.760
 75.583 75.517 75.502 75.500 75.500 75.500

12 PERIOD QAT= 62267. QST= 213877. QOT= 0. HCI=1.5417 HCO= .9520
 TAF= 97.71
 T1, T2, T3, -----T(M+1)
 79.635 79.158 78.562 77.859 77.108 76.415
 75.899 75.620 75.522 75.502 75.500 75.500

18 PERIOD QAT= 66301. QST= 347915. QOT= 1. HCI=1.5512 HCO= .9589
 TAF= 99.19
 T1, T2, T3, -----T(M+1)
 80.904 80.409 79.771 78.984 78.081 77.154
 76.355 75.822 75.577 75.510 75.501 75.500

24 PERIOD QAT= 69175. QST= 483108. QOT= 5. HCI=1.5573 HCO= .9669
 TAF= 100.24
 T1, T2, T3, -----T(M+1)
 81.933 81.430 80.772 79.941 78.950 77.874
 76.860 76.093 75.674 75.530 75.502 75.501

IHR 30 PERIOD QAT= 71574. QST= 618769. QOT= 16. HCI=1.5622 HCO= .9754
 TAF= 101.12
 T1, T2, T3, -----T(M+1)
 82.821 82.314 81.643 80.784 79.736 78.554
 77.376 76.405 75.806 75.563 75.505 75.504


36 PERIOD QAT= 73687. QST= 754700. QOT= 43. HCI=1.5664 HCO= .9843
 TAF= 101.90
 T1, T2, T3, -----T(M+1)
 83.615 83.105 82.426 81.546 80.457 79.196
 77.887 76.741 75.967 75.612 75.511 75.508

42 PERIOD QAT= 75600. QST= 890807. QOT= 96. HCI=1.5703 HCO= .9932
 TAF= 102.60
 T1, T2, T3, -----T(M+1)
 84.340 83.827 83.142 82.247 81.125 79.802
 78.387 77.090 76.151 75.675 75.521 75.514

48 PERIOD QAT= 77360. QST= 1027027. QOT= 187. HCI=1.5738 HCO=1.0021
 TAF= 103.25
 T1, T2, T3, -----T(M+1)
 85.011 84.496 83.806 82.899 81.752 80.378
 78.875 77.445 76.352 75.751 75.535 75.523

2 HR 60 PERIOD QAT= 80540. QST= 1299630. QOT= 548. HCI=1.5801 HCO=1.0194
 TAF= 104.42

REV.





CALCULATION SHEET


PROJECT ANPPJOB NO. 18601 - 200CALC. NO. 13-MC-HJ-25SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOMSHEET NO. 46

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	Janus	6/13/88					

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

T1, T2, T3, -----T(M+1)									
86.230	85.713	85.015	84.091	82.904	81.453				
79.809	78.160	76.791	75.939	75.578	75.552				
72 PERIOD QAT= 83383. QST= 1572213. QOT= 1264. HCI=1.5858 HCO=1.0360									
TAF= 105.47									
T1, T2, T3, -----T(M+1)									
87.328	86.809	86.105	85.167	83.952	82.443				
80.692	78.867	77.260	76.165	75.642	75.594				
84 PERIOD QAT= 85978. QST= 1844538. QOT= 2488. HCI=1.5910 HCO=1.0516									
TAF= 106.44									
T1, T2, T3, -----T(M+1)									
88.334	87.813	87.105	86.157	84.920	83.366				
81.530	79.560	77.746	76.421	75.729	75.650				
96 PERIOD QAT= 88379. QST= 2116390. QOT= 4377. HCI=1.5958 HCO=1.0663									
TAF= 107.33									
T1, T2, T3, -----T(M+1)									
89.268	88.746	88.035	87.079	85.824	84.233				
82.328	80.236	78.240	76.699	75.837	75.721				
108 PERIOD QAT= 90624. QST= 2387579. QOT= 7083. HCI=1.6004 HCO=1.0802									
TAF= 108.16									
T1, T2, T3, -----T(M+1)									
90.144	89.621	88.907	87.944	86.674	85.054				
83.089	80.894	78.736	76.995	75.967	75.804				
4HR 120 PERIOD QAT= 92740. QST= 2657934. QOT= 10755. HCI=1.6047 HCO=1.0933									
TAF= 108.95									
T1, T2, T3, -----T(M+1)									
90.971	90.448	89.731	88.763	87.480	85.834				
83.819	81.534	79.232	77.304	76.116	75.900				
132 PERIOD QAT= 94745. QST= 2927299. QOT= 15527. HCI=1.6087 HCO=1.1056									
TAF= 109.70									
T1, T2, T3, -----T(M+1)									
91.757	91.233	90.514	89.541	88.248	86.580				
84.521	82.156	79.725	77.626	76.282	76.006				
144 PERIOD QAT= 96656. QST= 3195530. QOT= 21527. HCI=1.6126 HCO=1.1172									
TAF= 110.41									
T1, T2, T3, -----T(M+1)									
92.507	91.982	91.262	90.285	88.982	87.294				
85.198	82.761	80.213	77.956	76.465	76.121				
156 PERIOD QAT= 98483. QST= 3462504. QOT= 28869. HCI=1.6163 HCO=1.1282									
TAF= 111.09									
T1, T2, T3, -----T(M+1)									
93.226	92.701	91.979	90.998	89.687	87.982				
85.851	83.351	80.697	78.294	76.661	76.245				
168 PERIOD QAT= 100237. QST= 3728103. QOT= 37656. HCI=1.6199 HCO=1.1386									
TAF= 111.75									
T1, T2, T3, -----T(M+1)									
93.917	93.391	92.668	91.683	90.366	88.645				
86.483	83.926	81.176	78.638	76.869	76.376				

REV.





CALCULATION SHEET

PROJECT ANPPJOB NO. 18601 - 200CALC. NO. 13-MC-HJ-2ESUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOMSHEET NO. 47

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	KSS	6-13-88	Johannes	6/13/88					

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

REV.

6 HR

180 PERIOD QAT= 101926. QST= 3992231. QOT= 47982. HCI=1.6234 HCO=1.1484
 TAF= 112.38
 T1, T2, T3, -----T(M+1)
 94.583 94.057 93.332 92.345 91.020 89.286
 87.097 84.488 81.650 78.986 77.088 76.513

192 PERIOD QAT= 103555. QST= 4254796. QOT= 59929. HCI=1.6268 HCO=1.1578
 TAF= 112.99
 T1, T2, T3, -----T(M+1)
 95.227 94.700 93.974 92.984 91.654 89.907
 87.693 85.037 82.119 79.339 77.317 76.656

204 PERIOD QAT= 105131. QST= 4515719. QOT= 73569. HCI=1.6300 HCO=1.1667
 TAF= 113.58
 T1, T2, T3, -----T(M+1)
 95.850 95.323 94.596 93.604 92.268 90.510
 88.273 85.574 82.582 79.695 77.553 76.802

216 PERIOD QAT= 106659. QST= 4774933. QOT= 88968. HCI=1.6332 HCO=1.1752
 TAF= 114.15
 T1, T2, T3, -----T(M+1)
 96.455 95.928 95.200 94.206 92.865 91.097
 88.839 86.101 83.041 80.053 77.796 76.953

228 PERIOD QAT= 108143. QST= 5032375. QOT= 106180. HCI=1.6363 HCO=1.1833
 TAF= 114.71
 T1, T2, T3, -----T(M+1)
 97.044 96.516 95.788 94.791 93.446 91.668
 89.392 86.617 83.495 80.412 78.045 77.106

8 HR


240 PERIOD QAT= 109587. QST= 5287995. QOT= 125256. HCI=1.6393 HCO=1.1911
 TAF= 115.26
 T1, T2, T3, -----T(M+1)
 97.617 97.089 96.360 95.361 94.012 92.226
 89.932 87.125 83.944 80.773 78.299 77.262

264 PERIOD QAT= 112368. QST= 5793589. QOT= 169160. HCI=1.6451 HCO=1.2057
 TAF= 116.30
 T1, T2, T3, -----T(M+1)
 98.723 98.194 97.464 96.462 95.105 93.304
 90.979 88.113 84.828 81.496 78.818 77.579

288 PERIOD QAT= 115023. QST= 6291427. QOT= 220945. HCI=1.6507 HCO=1.2191
 TAF= 117.30
 T1, T2, T3, -----T(M+1)
 99.781 99.252 98.520 97.515 96.153 94.338
 91.987 89.070 85.694 82.219 79.348 77.901

312 PERIOD QAT= 117570. QST= 6781304. QOT= 280800. HCI=1.6561 HCO=1.2314
 TAF= 118.27
 T1, T2, T3, -----T(M+1)
 100.80 100.27 99.535 98.528 97.161 95.335
 92.961 89.999 86.543 82.938 79.883 78.225

336 PERIOD QAT= 120025. QST= 7263080. QOT= 340000. HCI=1.6613 HCO=1.2430





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-25
 SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 48

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	5-13-88	<i>J. Jones</i>	6/13/88	△				
△					△				

REV. 4-INDI-

 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

TAF= 119.20

T1, T2, T3, -----T(M+1)

101.78	101.25	100.52	99.507	98.134	96.298
93.904	90.904	87.376	83.652	80.421	78.548

12 HR

360 PERIOD QAT= 122397. QST= 7736676. QOT= 425159. HCI=1.6664 HCO=1.2537

TAF= 120.10

T1, T2, T3, -----T(M+1)

102.73	102.20	101.46	100.45	99.077	97.233
94.821	91.785	88.193	84.359	80.958	78.870

432 PERIOD QAT= 129104. QST= 9108150. QOT= 703796. HCI=1.6808 HCO=1.2819

TAF= 122.65

T1, T2, T3, -----T(M+1)

105.42	104.89	104.16	103.14	101.75	99.888
97.432	94.310	90.553	86.428	82.546	79.814

504 PERIOD QAT= 135311. QST=10406394. QOT= 1056153. HCI=1.6944 HCO=1.3056

TAF= 125.02

T1, T2, T3, -----T(M+1)

107.93	107.40	106.66	105.64	104.24	102.36
99.870	96.676	92.783	88.405	84.078	80.714

576 PERIOD QAT= 141107. QST=11633488. QOT= 1480075. HCI=1.7072 HCO=1.3257

TAF= 127.24

T1, T2, T3, -----T(M+1)

110.27	109.74	109.00	107.98	106.58	104.68
102.16	98.905	94.891	90.283	85.537	81.564

648 PERIOD QAT= 146544. QST=12792212. QOT= 1972721. HCI=1.7194 HCO=1.3433

TAF= 129.33

T1, T2, T3, -----T(M+1)

112.48	111.95	111.21	110.19	108.78	106.87
104.32	101.01	96.882	92.060	86.918	82.363


24 HR

720 PERIOD QAT= 151656. QST=13885662. QOT= 2530963. HCI=1.7310 HCO=1.3586

TAF= 131.31

T1, T2, T3, -----T(M+1)

114.57	114.03	113.29	112.26	110.85	108.93
106.35	102.99	98.763	93.741	88.222	83.111





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-253

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 49

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	<i>Doine</i>	6/13/88	1				

REV. INDI.


APPENDIX D

ENGINEERING EVALUATIONS
PALO VERDE NUCLEAR GENERATING STATION
ENGINEERING ANALYSIS WORK SHEET

EA _____
Sheet 2 of 3

Title: <u>INITIAL TEMPERATURES CONCRETE</u>				
<u>TRAIN A</u>		Performed by: <u>E.A. ZARBO</u>	Date: <u>6-9-88</u>	
References:	<u>START 1243</u>	Review Method by:	Alternate Calc <input type="checkbox"/>	
	<u>STOP 1845</u>	Detailed Review <input type="checkbox"/>	Qualification Test <input type="checkbox"/>	
Reviewed by: _____		Date: _____		
ROOM	TEMP	HUM	TEMP	HUM
			AVG TEMP	AVG HUMID.
HPSI	81.5	/		
LPST	81.4	/		
CS	80.8	/		
AF	100.4	/		
ELEC PEN	90.1	/		
EW	79.9	/		
ESF SWITCH GEAR	78.4	/		
CONTROL ROOM	75.5	/		
AMBIENT	100.5	97.8		
	START	FINISH		
	/	/		
	/	/		
	/	/		
	/	/		
	/	/		
	/	/		
	/	/		

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36





CALCULATION SHEET

PROJECT ANPP JOB NO. 18601 - 200 CALC. NO. 13-MC-HJ-253
 SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM SHEET NO. 50

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	5-13-88	J. Brown	5/13/88					

REV. INDI-C

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

ENGINEERING EVALUATIONS
 PALO VERDE NUCLEAR GENERATING STATION
 ENGINEERING ANALYSIS WORK SHEET

EA _____
 Sheet 3 of 3

Title: <u>INITIAL TEMPERATURES - CONCRETE.</u>				
<u>TRAIN B</u>		Performed by: <u>R. A. ZARCO</u>		Date: <u>6-9-88</u>
References:		Review Method by:		
<u>START 1743</u>		Alternate Calc <input type="checkbox"/>		
<u>STOP 1845</u>		Detailed Review <input type="checkbox"/>		
		Qualification Test <input type="checkbox"/>		
Reviewed by: _____		Date: _____		
ROOM	TEMP/HUM	TEMP/HUM	AVG TEMP	AVG HUMID.
HPSI	83.0	/		
LPSI	LOCKED HIGH RAD			
CS	81.2	/		
AF	94.8	/		
ELEC PEN-1	92.1	/		
EW	79.9	/		
ESF SWITCH GEAR	75.1	/		
CONTROL ROOM	75.5	/		
AMBIENT	100.5	97.8		
	START	FINISH		
	/	/		
	/	/		
	/	/		
	/	/		





CALCULATION SHEET

PROJECT ANPP

JOB NO. 18601 - 200

CALC. NO. 13-MC-HJ-2

SUBJECT TRANSIENT TEMPERATURE STUDY FOR MAIN CONTROL ROOM

SHEET NO. 51

REV	ORIGINATOR	DATE	CHECKER	DATE	REV	ORIGINATOR	DATE	CHECKER	DATE
0	PSS	6-13-88	<i>[Signature]</i>	5/13/88	1				
1					2				

ENGINEERING EVALUATIONS

EA Sheet 2 of 2

PALO VERDE NUCLEAR GENERATING STATION ENGINEERING ANALYSIS WORK SHEET

Title: METEOROLOGICAL DATA TAKEN FROM MET TOWER CHARTS
FOR 5/20/88 THRU 5/29/88 AND 6/9/88
 Performed by: RA. ZARBO Date: 6/10/88

References: _____ Review Method by: Alternate Calc
 Detailed Review
 Qualification Test
 Reviewed by: _____ Date: _____

DATE HIGH TEMP (°F)

5/20/88	93.9
5/21/88	96.6
5/22/88	100.1
5/23/88	99.9
5/24/88	98.4
5/25/88	99.1
5/26/88	101.3
5/27/88	97.0
5/28/88	94.2
5/29/88	78.9
6/9/88	99.8

