

## **NRR-PMDAPEm Resource**

---

**From:** Goetz, Sujata  
**Sent:** Tuesday, October 31, 2017 1:41 PM  
**To:** Jason R Haas  
**Subject:** Fermi 2 – Acceptance of Requested Licensing Action to Adopt TSTF-484 (EPID L-2017-LLA-0351)

Dear Mr. Haas,

By letter dated October 9, 2017 (Agencywide Document and Access Management System (ADAMS) Accession No. ML17283A248) DTE Electric Company submitted a license amendment request for Fermi 2. The proposed amendment would revise limiting condition for operation 3.10.1, and the associated Bases, to expand its scope to include provisions for temperature excursions greater than 200 degree Fahrenheit as a consequence of inservice leak and hydrostatic testing, and as a consequence of scram time testing initiated in conjunction with an inservice leak or hydrostatic test, while considering operational conditions to be in Mode 4. This change is consistent with NRC approved Revision 0 to Technical Specification Task Force (TSTF) Improved Standard Technical Specification Change Traveler, TSTF-484, “Use of TS 3.10.1 for scram time testing activities.”

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff’s acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff’s ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

Based on the information provided in your submittal, the NRC staff has estimated that this licensing request will take approximately 250 hours to complete. The NRC staff expects to complete this review in approximately 12 months, which is October 2018. If there are emergent complexities or challenges in our review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for the changes, along with the new estimates, will be communicated during the routine interactions with the assigned project manager.

These estimates are based on the NRC staff’s initial review of the application and they could change, due to several factors including requests for additional information, unanticipated addition of scope to the review, and review by NRC advisory committees or hearing-related activities. Additional delay may occur if the submittal is provided to the NRC in advance or in parallel with industry program initiatives or pilot applications.

If you have any questions, please contact me.

**Sujata Goetz**  
**Project Manager, Fermi, Unit 2**

**Nuclear Regulatory Commission  
11555 Rockville Pike  
Office of the Nuclear Reactor Regulation  
NRC/NRR/DORL/LPL3  
Office O8F2  
Mailroom O8-B1A  
Rockville, MD 20852-2738  
Washington, DC 20555-0001**

**(o) 301.415.8004**

**(f) 301.415.3313**

**Hearing Identifier:** NRR\_PMDA  
**Email Number:** 3809

**Mail Envelope Properties** (Sujata.Goetz@nrc.gov20171031134100)

**Subject:** Fermi 2 – Acceptance of Requested Licensing Action to Adopt TSTF-484 (EPID L-2017-LLA-0351)  
**Sent Date:** 10/31/2017 1:41:26 PM  
**Received Date:** 10/31/2017 1:41:00 PM  
**From:** Goetz, Sujata

**Created By:** Sujata.Goetz@nrc.gov

**Recipients:**  
"Jason R Haas" <haasj@dteenergy.com>  
Tracking Status: None

**Post Office:**

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	3559	10/31/2017 1:41:00 PM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**