REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8908300232 DOC. DATE: 89/08/22 NOTARIZED: NO DOCKET #
FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
AUTH. NAME AUTHOR AFFILIATION
HAYNES, J. G. Arizona Public Service Co. (formerly Arizona Nuclear Power
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Submits Special Rept 1-SR-89-528 re steam generator tubes plugged on 890813 as result of inservice insp.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES: 05000528

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD5 LA	1	0	PD5 PD	5	5
	CHAN, T	1	1	DAVIS, M.	1	1
INTERNAL:	ACRS	6	6	AEOD/DSP/TPAB	1	1
	NRR/DEST/MEB 9H	1	1	NRR/DEST/MTB 9H	1	1
	NUDOCS-ABSTRACT	1	1	OC/LFMB	1	0
	OGC/HDS1	1	0	REG FILE 01	1	1
	RES/DSIR/EIB	1	1			
EXTERNAL:	EG&G BROWN, B	1	1	EG&G ROCKHOLD, H	1	1
	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			
NOTES:		1	1			

per J. McKn
on 9/6/89

TOTAL NUMBER OF COPIES REQUIRED: LTTR 28 ENCL 25

Arizona Public Service Company

PALO VERDE NUCLEAR GENERATING STATION
P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

192-00509-JGH/TDS/JJN
August 22, 1989

NRC Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sirs:

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Unit 1
Docket No. STN 50-528 (License No. NPF-41)
Special Report 1-SR-89-008
File: 89-020-404

Attached please find a Special Report prepared and submitted pursuant to Technical Specifications 4.4.4.5.a and 6.9.2. This report discusses Steam Generator tubes plugged as a result of an Inservice Inspection.

If you have any questions, please contact T. D. Shriver, Compliance Manager, at (602) 393-2521.

Very truly yours,

J G Haynes

J. G. Haynes
Vice President
Nuclear Production

JGH/TDS/JJN/kj

Attachment

cc: W. F. Conway (all w/a)
D. B. Karner
J. B. Martin
T. J. Polich
M. J. Davis
A. C. Gehr
INPO Records Center

A047 per J. Mckn. on 9/6/89

8908300232 890822
PDR ADOCK 05000528
Q PDR

PALO VERDE NUCLEAR GENERATING STATION

STEAM GENERATOR TUBE PLUGGING

License No. NPF-41

Docket No. STN 5-528

Special Report 1-SR-89-008

This Special Report is required by Palo Verde Unit 1 Technical Specification 4.4.4.5 REPORTS a, within 15 days following the completion of each inservice inspection of steam generator tubes.

On August 13, 1989, Palo Verde Unit 1 was in Mode N (Reactor Core off-loaded to the Spent Fuel Pool), when an inservice inspection of both steam generators was completed. The inspection resulted in the plugging of 12 tubes in steam generator number 1 and 8 tubes in steam generator number 2.

The complete results of the steam generator tube inservice inspection will be submitted to the Commission in a Special Report within 12 months following completion of the inspection as required by Technical Specification section 4.4.4.5 REPORTS b.