

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9010300054 DOC.DATE: 90/10/11 NOTARIZED: NO DOCKET #
 FACIL:STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530
 AUTH.NAME AUTHOR AFFILIATION
 TROSKOSKI,W. Ofc of Enforcement (Post 870413)
 LIEBERMAN,J. Ofc of Enforcement (Post 870413)
 RECIPIENT NAME RECIPIENT AFFILIATION

R
I
D
S
/
A
D
D
S

SUBJECT: EN-90-091:on 901016,notice of proposed imposition of civil penalty in amount of \$125,000 will be issued to licensee. based on

DISTRIBUTION CODE: IE33F COPIES RECEIVED:LTR 0 ENCL 1 SIZE: 1
 TITLE: Enforcement Notice (EN)

NOTES:STANDARDIZED PLANT 05000528
 Standardized plant. 05000529
 Standardized plant. 05000530

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	L	T	ID	CODE/NAME	L	T
INTERNAL:	AEOD/DOA		1	1	AEOD/DSP/TPAB		1	1
	NRR/DOEA/OEAB11		1	1	NRR/DREP/PEPB9D		1	1
	NRR/PMAS/ILRB12		1	1	NUDOCS FULL TXT		1	1
	OE DIR		1	1	OE FILE 01		1	1
	<u>REG FILE</u> 02		1	1				
EXTERNAL:	NRC PDR		1	1	NSIC		1	1
NOTES:			1	1				

R
I
D
S
/
A
D
D
S

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 12

IA4

11

OFFICE OF ENFORCEMENT
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Arizona Public Service (EA 90-121)
(Palo Verde)
Docket Nos. 50-528, 50-~~529~~, and 50-530

Subject: PROPOSED IMPOSITION OF CIVIL PENALTY - 125,000

This is to inform the Commission that a Notice of Violation and Proposed Imposition of Civil Penalty in the amount of \$125,000 will be issued on or about October 16, 1990 to Arizona Public Service. This action is based on the failure to ensure the adequacy of the emergency lighting system. QA Program requirements for Test Control and Corrective Action were not applied to portions of the fire protection system. In addition, various emergency lighting units in the Control Room, Control Building, and Auxiliary Building were not capable of operating for the specified eight hours. The civil penalty was escalated 50% for NRC identification and 100% for poor past performance with emergency lighting.

It should be noted that the licensee has not been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Notice	October 16, 1990
Telephone Notification of Licensee	October 16, 1990

The State of Arizona will be notified.

The licensee has thirty days from the date of the Notice in which to respond. Following NRC evaluation of the response, the civil penalty may be remitted, mitigated, or imposed by Order.

Contact: W. Troskoski, OE, 23281 J. Lieberman, OE, 20741

Distribution

OWFN 6:15
Chairman Carr
Comm. Rogers
Comm. Curtiss
Comm. Remick

SECY
OCA
GPA
SP

OWFN 6:15
EDO
DEDR
DEDS
OE
NMSS
NRR
OI
OGC

MNBB 6:15
OC
AEOD
Op Ctr

PHIL 6:15
IRM

Regional Offices MAIL
 RI 6:15 RIV 6:15 ADM: Doc. Mgt. Br.
 RII 6:15 RV 6:15 PDR ACRS
 RIII 6:15 RES OIG

PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL PUBLICLY ANNOUNCED

9010300054 901011
 PDR I&E PDC
 EN-90-091

0/1
 EN90-91 IE:33

