

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210140405 DOC. DATE: 92/10/07 NOTARIZED: NO DOCKET #  
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public Service Co. 05000528  
 AUTH. NAME: [REDACTED] AUTHOR AFFILIATION: Arizona Public Service Co. (formerly Arizona Nuclear Power)  
 [REDACTED] NWAY, W.F. RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)  
 [REDACTED] RECIP. NAME

SUBJECT: Forwards addl info re violation noted in insp rept  
 50-528/91-25. Summary of & clarification to info re  
 timeliness for evaluating motor-operated valve dynamic test  
 data provide.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: STANDARDIZED PLANT 05000528 /

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	
	PD5 PD	1 1	TRAMMELL, C	1 1	A
INTERNAL:	ACRS	2 2	AEOD	1 1	D
	AEOD/DEIB	2 2	AEOD/DSP/TPAB	1 1	D
	AEOD/TTC	1 1	DEDRO	1 1	S
	NRR MORISSEAU, D	1 1	NRR/DLPQ/LHFBPT	1 1	
	NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB	1 1	
	NRR/DREP/PEPB9H	1 1	NRR/PMAS/ILRB12	1 1	
	NUDOCS-ABSTRACT	1 1	<del>OE-DTR</del>	1 1	
	OGC/HDS1	1 1	<u>REG FILE</u> 02	1 1	
	RGN5 FILE 01	1 1			
EXTERNAL:	EG&G/BRYCE, J.H.	1 1	NRC PDR	1 1	R
	NSIC	1 1			I

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 24



Arizona Public Service Company

P O. BOX 53999 • PHOENIX, ARIZONA 85072-3999

102-02306-WFC/TRB/JNI  
October 7, 1992

WILLIAM F. CONWAY  
EXECUTIVE VICE PRESIDENT  
NUCLEAR

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-37  
Washington, DC 20555

Reference: Letter dated August 27, 1992, from L. T. Miller Jr., NRC, to W. F. Conway, APS

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)**  
**Units 1, 2, and 3**  
**Docket Nos. STN 50-528/529/530**  
**Additional Information Related to Notice of Violation**  
**50-528/91-25-02**  
**File: 92-070-026**

The enclosure to this letter provides a summary of and clarification to the information provided to the NRC during a telephone conversation between D. Corporandy, NRC, and T. R. Bradish, Arizona Public Service Company (APS), on September 17, 1992. This information, regarding the timeliness for evaluating motor-operated valve dynamic test data, was provided in response to the referenced letter.

Should you have any questions regarding this information, please contact Thomas R. Bradish at (602) 393-5421.

Sincerely,

*James M. Levine for WFC*

WFC/TRB/JNI/jni

Enclosure

cc: J. B. Martin  
J. A. Sloan

9210140405 921007  
PDR ADDOCK 05000528  
Q PDR

*JEB*



**ENCLOSURE**

**SUMMARY OF TELEPHONE CONVERSATION**

**ON SEPTEMBER 17, 1992**

**ENCLOSURE**  
**SUMMARY OF TELEPHONE CONVERSATION**  
**ON SEPTEMBER 17, 1992**

The following is a summary of and clarification to the information provided to the NRC during a telephone conversation between D. Corporandy, NRC, and T. R. Bradish, Arizona Public Service Company (APS), on September 17, 1992. This information, regarding the timeliness for evaluating motor-operated valve dynamic test data, was provided in response to the letter dated August 27, 1992, from L. T. Miller Jr., NRC, to W. F. Conway, APS.

APS will calculate the acceptance criteria and review the test data against the acceptance criteria within 7 days of completion of the test work order for valves tested in MODEs 1 through 4. The comparison of the test data against the calculated acceptance criteria will be completed no more than 7 days following MODE 4 entry for valves tested in MODEs 5 and 6. Where the test data results are outside the acceptance criteria, then the condition will be addressed using the PVNGS condition reporting program.

The dynamic test performed may not be the design bases test. Because of this, the acceptance criteria will only be developed to the extent that they apply to the test performed. For example, the acceptance criteria for a hydro-pump test for a gate valve may be different than a design bases test which includes flow.

The new procedure, containing the evaluation process and the time frames for evaluating the test data, will be issued by October 21, 1992. The results of dynamic tests performed prior to issuance of the new procedure will be reviewed using the new procedure. These reviews will be completed within six months of the issuance of the procedure.

