

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8708240030 DOC. DATE: 87/08/17 NOTARIZED: NO DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335  
 AUTH. NAME AUTHOR AFFILIATION  
 WOODY, C. O. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-67, changing Tech Specs  
 3 4.10. "PCS - Structural Integrity ASME Code Class 1, 2 & 3  
 Components," & Section 4.0, "Surveillance Requirements."  
 Fee paid. Encls include evaluation & hazards determination.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3 + 43  
 TITLE: OR Submittal: Inservice Inspection/Testing

## NOTES:

|           | RECIPIENT    |  | COPIES |      |  | RECIPIENT          |  | COPIES |      |
|-----------|--------------|--|--------|------|--|--------------------|--|--------|------|
|           | ID CODE/NAME |  | LTTR   | ENCL |  | ID CODE/NAME       |  | LTTR   | ENCL |
|           | PD2-2 LA     |  | 1      | 0    |  | PD2-2 PD           |  | 5      | 5    |
|           | TOURIGNY, E  |  | 1      | 1    |  |                    |  |        |      |
| INTERNAL: | AEOD/DOA     |  | 1      | 1    |  | AEOD/DSP/TPAB      |  | 1      | 1    |
|           | ARM/DAF/LFMB |  | 1      | 0    |  | NRR/DEST/MEB       |  | 1      | 1    |
|           | NRR/DEST/MTB |  | 1      | 1    |  | NRR/PMAS/ILRB      |  | 1      | 1    |
|           | OGC/HDS2     |  | 1      | 0    |  | <u>REG FILE</u> 01 |  | 1      | 1    |
|           | RES/DE/EIB   |  | 1      | 1    |  |                    |  |        |      |
| EXTERNAL: | LPDR         |  | 1      | 1    |  | NRC PDR            |  | 1      | 1    |
|           | NSIC         |  | 1      | 1    |  |                    |  |        |      |

*Rec'd w/Check \$ 150.00*



AUGUST 17 1987

L-87-337

Office of Nuclear Reactor Regulation  
Attention: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit I  
Docket No. 50-335  
Proposed License Amendment  
Reactor Coolant System - Structural Integrity  
ASME Code Class 1, 2 and 3 Components

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith a request to amend Facility Operating License DPR-67.

As required by 10 CFR 50.55a(g), FPL updated the Inservice Inspection Program (ISI) for St. Lucie Unit I to the requirements of the 1974 Edition through Summer 1975 Addenda of Section XI of the ASME Boiler and Pressure Vessel Code. This is still applicable for the first 10 year Inspection Interval which ends February 11, 1988. As a result of this update, proposed Technical Specifications were submitted to NRC by FPL letters L-77-203, dated July 1, 1977, and L-77-291, dated September 16, 1977. Also, on September 8, 1978, FPL letter L-78-295 was submitted to incorporate revisions to the program based on meetings between FPL and NRC staff in May 1978. Interim NRC approval of the FPL program was granted on December 20, 1977, however, final NRC approval is still pending.

Due to the length of time which has expired since the original ISI and Inservice Testing (IST) Technical Specification proposals, and based on conversations between FPL and the NRC, revised Technical Specification submittals are being developed by FPL for both the ISI and IST programs. The revised submittals will replace those submittals which were proposed in 1977 and 1978.

The subject proposed amendment involves changes to Technical Specification 3.4.10, RCS - Structural Integrity ASME Code Class 1, 2 and 3 Components. Also, included is a change to the St. Lucie Unit I Technical Specifications, Section 4.0, Surveillance Requirements.

A marked up copy of the affected Technical Specification pages is included as Attachment 1. An Evaluation in support of the proposed amendment is included in Attachment 2. A "Determination of No Significant Hazards Consideration" is provided as Attachment 3.

AD47  
11

8708240030 870817  
PDR ADCK 05000335  
P PDR

Rec'd w/ check \$150.00

1944

1944

1944

1944

1944

1944

1944

1944

1944

1944

U. S. Nuclear Regulatory Commission  
L-87-337  
Page two

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.


In accordance with 10 CFR 50.91(b)(1), a copy of the proposed amendment is being forwarded to the state designee for the State of Florida.

In accordance with 10 CFR 170.21, FPL Check No. 5404 is attached as remittance for the license amendment application fee for St. Lucie Unit 1.

With the first 10 year Inspection Interval ending February 11, 1988, it is requested that NRC approve the subject proposed Technical Specification amendment by January 15, 1988.

Please contact us if you have any questions about this submittal.

Very truly yours,

  
C. O. Woody  
Group Vice President  
Nuclear Energy

COW/MSD/gp  
Attachments

cc: Dr. J. Nelson Grace, Regional Administrator, USNRC, Region II  
Mr. Lyle Jerrett, Florida Dept. of Health and Rehabilitative Services  
Senior Resident Inspector, USNRC, St. Lucie Plant




STATE OF FLORIDA            )  
                                      ) ss.  
COUNTY OF PALM BEACH )

J. W. Dickey being first duly sworn, deposes and says:


That he is Vice President of Nuclear Operations of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

  
\_\_\_\_\_  
J. W. Dickey

Subscribed and sworn to before me this

17 day of August, 1987.

  
\_\_\_\_\_  
Service M. Dalinis

NOTARY PUBLIC, in and for the County  
of Palm Beach, State of Florida

My Commission expires: \_\_\_\_\_

NOTARY PUBLIC STATE OF FLORIDA  
MY COMMISSION EXP SEPT 18, 1989  
BONDED THRU GENERAL INS. UND.

