CAR 1288)

1	CONTROL BLOCK:
	CONTROL BLOCK: [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N Y R E G 1 0 0 - 0 0 0 0 - 0 0 3 .4 1 1 1 1 1 5 57 CAT 58 (5)
0 1 7 8	REPORT L 6 0 5 0 0 0 2 4 4 7 0 3 0 2 8 1 8 0 4 0 1 8 1 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
	EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During test C SI pump did not start with bus 16 breaker (T.S.3.3.1.1c). This is simi-
0 2	
0 3	lar to LER 81-002. Electricians observed breaker operation during this test. The C SI
0 4	pump had been proven operable using bus 14 breaker during this test as well as the
0 5	other 2 pumps. Breaker was examined and tested successfully 3 times in test position,
0 6	racked in and test completed successfully. Test was repeated successfully next day,
0 7	and test frequency was increased to weekly with monitoring instrumentation. Three
0 8	weeks later breaker malfunctioned on 2nd attempt.
7 8	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
7 8	9 10 11 12 13 18 19 20 SEQUENTIAL OCCURRENCE REPORT REVISION LEGICO EVENT YEAR REPORT NO. CODE TYPE NO.
	17 REPORT 8 1
	ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT NPRD-4 PRIME COMP. COMPONENT MANUFACTURER C B D 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 W 1 2 0 26
	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0	Closing circuit malfunction. Qualified replacement installed and tested. Faulty
11	breaker to be examined and tested by RG&E and Westinghouse to identify exact cause.
1 2	Breaker is Westinghouse DB-50 air circuit breaker, 500 amp.
1 3	
1 4	
7 8	FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32
1 5	E 28 1 0 0 29 NA B 31 Surveillance test
	ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
1 6	$\begin{bmatrix} Z & (33) & Z & (34) & NA & \\ 10 & 11 & 44 & 45 & NA & \\ 80 & & & & & & & & & & & & & & & & & & $
TT T	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) 1 0 0 0 (37) Z (38) NA
7 8	9 11 12 13 80
18	NUMBER DESCRIPTION (41) 9 11 12 NA
1 9	LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION NA
7 8	9 10 80
20	ISSUED DESCRIPTION (45) NA NA
	19040 90567 NAME OF PREPARER E. Clair Edgar PHONE: 315-524-4446, ext. 248 &

