U. S. NUCLEAR REGULATORY COMMISSION

REGION II

Docket Nos.: 50-335, 50-389

License Nos.: DPR-67. NPF-16

Report No.: 50-335/98-301

Licensee: Florida Power and Light Company

Facility: St. Lucie Plant Units 1 & 2

Location: Jensen Beach, FL

Dates:

June 22-26, 1998

Examiners:

George T. Hopper, Chief License Examiner

Ronald F. Aiello, License Examiner Richard S. Baldwin, License Examiner

Approved by:

Thomás A. Peebles, Chief, Operator Licensing and Human Performance Branch Division of Reactor Safety



• 1

•

• . •

· · · · .

4

x *

u

.

L. •

•

.

۸

•

,

i -

•

EXECUTIVE SUMMARY

St. Lucie Plant Units 1 & 2 NRC Examination Report No. 50-335/98-301 and 50-389/98-301

During the period of June 22-26, 1998. NRC examiners conducted an announced operator licensing initial examination in accordance with the guidance of Examiner Standards, NUREG-1021, Interim Revision 8. This examination implemented the operator licensing requirements of 10 CFR §55.41. §55.43. and §55.45.

Operations

- Three Senior Reactor Operator (SRO) candidates and three Reactor Operator (RO) Candidates received written examinations and operating tests. All examinations were administered by NRC operator licensing examiners. The written examination was administered on June 19, 1998, and the operating tests were administered June 22-25, 1998. (Section 05.1)
- <u>Candidate Pass/Fail</u>

	SRO	RO	Total	Percent
Pass	2	3	5	83.3
Fail	1	0	1	16.7

- The NRC noted the quality of the licensee's proposed examination was satisfactory and had significantly improved as compared to the previous examination submittal (Report NO. 97-301). (Section 05.2)
- The NRC concluded that inadequate administration of security precautions led to the packaging of exam materials in a single envelope which was delivered to the NRC in an opened condition. Future examination development should include strict adherence to security guidelines contained in NUREG 1021. This should minimize the possibility of examination compromise and the delay or cancellation of an examination. (Section 05.3)
- The examiners concluded that SRO candidate performance on the written examination was weak. Overall performance on the operating test was satisfactory with some significant weaknesses noted in the areas of



recognizing adverse plant parameters. understanding system response and taking manual control of equipment when automatic actions fail to occur. (Section 05.4)

The NRC noted that confusion existed among the candidates with regards to the expectations of performing the immediate operator actions in the standard post-trip actions (SPTAs) of the EOPs. Training on the implementation of the SPTAs together with insufficient procedural guidance led to poor candidate performance. The procedural guidance and training of the operators combined to result in less than optimal mitigation of the events. (Section 08).

Report Details

Summary of Plant Status

During the period of the examinations Unit 1 and Unit 2 were at 100 percent power.

I. Operations

05 Operator Training and Qualifications

05.1 <u>General Comments</u>

NRC examiners conducted regular, announced operator licensing initial examinations during the period June 22-26, 1998. NRC examiners administered examinations developed by the licensee's training department, under the requirements of an NRC security agreement, in accordance with the guidelines of the Examiner Standards (ES), NUREG-1021, Interim Revision 8. Three Senior Reactor Operator (SRO) instant and three Reactor Operator (RO) applicants received written examinations and operating tests.

05.2 Pre-Examination Activities

a. <u>Scope</u>

The NRC reviewed the licensee's examination submittal using the criteria specified for examination development contained in NUREG 1021. Interim Revision 8.

b. <u>Observations and Findings</u>

The licensee developed the SRO and RO written examinations, one Job Performance Measure (JPM) set, and three dynamic simulator scenarios for use during this examination. All materials were submitted to the NRC on time. NRC examiners reviewed, modified as necessary, and approved the examination prior to administration. The NRC conducted an on-site preparation visit during the week of June 8, 1998, to validate examination materials and familiarize themselves with the details required for examination administration.







(1) Written Examination Development

The written examination was submitted on time. The organization of the submitted examination with some of the reference material attached expedited the examination review process.

This was the licensee's second attempt at developing the examinations under the new examination development pilot program. The NRC noted that the quality of the licensee's submittal had significantly improved as compared to the previous submittal. Aside from minor editorial changes to clarify or improve the language of the questions, the number of technical errors noted were minimal. The licensee worked diligently to resolve the NRC comments. The final version of the original written examination met the criteria specified in NUREG 1021. Interim Revision 8.

The final written examination, along with some other test materials, arrived at the Region II office in a torn open envelope. As a result, the final version of the written examination was significantly modified as a precautionary measure. The outcome of this effort resulted in a final product that contained some psychometric errors. Specifically, three questions on the final version of the examinations contained errors that resulted in changing the answer key to accept an additional correct answer and one other question had the correct answer changed. The licensee submitted comments on these four questions (Enclosure 3). The NRC resolution of the licensee's comments is attached as Enclosure 4.

(2) Operating Test Development

The NRC reviewed one JPM set and administrative section of the examination for the walk-through portion of the examination. The examiners found the JPMs were at the appropriate level of difficulty. Overall quality of the JPMs was satisfactory. Some minor technical errors were noted such as the incorrect designation of critical steps. The NRC also noted that the quality of the JPM questions was weak. Several JPM questions lacked significant operational validity and some were nondiscriminatory in value. The ES examples of suitable JPM questions are open reference, analysis, synthesis, and application level questions that require higher order cognitive thought processes and should avoid direct look-ups. Increased attention



.

•

Ň

.

3

in this area is needed to supply and examination consistent with the guidelines of NUREG 1021, Interim Revision 8.

The NRC reviewed three simulator scenarios for the examination. Some changes and additions were made to the scenarios to enhance the examiners opportunity to observe candidates perform the required competencies. Overall, the scenarios were found to be challenging and at the right level of difficulty.

c. <u>Conclusion</u>

The NRC noted that the quality of the licensee's proposed examination was satisfactory and had significantly improved compared to the previous examination submittal (Report No. 97-301). The NRC noted that improvement in JPM question development is needed to comply with the guidelines of NUREG 1021. Interim Revision 8.

05.3 Examination Security

NUREG 1021, Interim Revision 8, "Operator Licensing Examination Standards For Power Reactors", ES-201 Attachment 1, delineates examination security and integrity considerations. Item 3 states, "The examination outlines, written examinations, and operating tests that are mailed to the NRC regional office shall be placed in a double envelope."

The licensee inadvertantly submitted the final version of the written examinations and scenarios in a single wrapped, brown mailing envelope. The envelope was delivered by Federal Express in a torn open condition on the morning of June 2, 1998. The NRC mail clerk delivered the package to the chief examiner who immediately started an inquiry to determine the cause of the damage to the envelope and the potential for examination compromise. The NRC noted the damage to be extensive as indicated by the pictures contained in Enclosure 5, and appeared to have been caused by mishandling or sorting machinery. If the materials had been properly packaged in accordance with the guidance in NUREG 1021, the inner envelope would probably have remained intact. Upon notification by the NRC, the licensee conducted an internal investigation to determine if the envelope had been opened on site or in route to the NRC. The licensee's investigation found that the package had been dispatched in good condition and had not been opened or damaged on site. A summary of the licensee's investigation is attached as Enclosure 6.



The NRC concluded the envelope had been torn open by the shipping agent in handling and the potential for compromise of examination material was remote. Nevertheless, to ensure examination integrity, the NRC and the licensee agreed to make significant alterations to the examination materials. Changes were made to the scenarios, and 40 questions were replaced on each written examination. The licensee expended a considerable effort to accomplish the changes. Therefore, the changes did not result in a delay of the examination administration.

4

The NRC concluded that inadequate implementation of security precautions led to the packaging of examination materials in a single envelope that was delivered to the NRC in an opened condition. Future examination development should include strict adherence to security guidelines in NUREG 1021 to minimize the possibility of examination compromise and the delay or cancellation of an examination.

05.4 Examination Results and Related Findings. Observations. and Conclusions

a. <u>Scope</u>

The examiners reviewed the results of the written examination and evaluated the candidates' compliance with and use of plant procedures during the simulator scenarios and JPMs. The guidelines of NUREG-1021, Forms ES-303-3 and ES-303-4, "Competency Grading Worksheets for Integrated Plant Operations," were used as a basis for the operating test evaluations.

Observations and Findings.

The examiners reviewed the results of the written examination and found that five of six candidates passed. Overall SRO candidate performance on the written examination was weak with one candidate failing this portion of the examination and the other two achieving a grade of 80 percent. Examiners also identified several weaknesses in candidate performance during the operations portion of the examination. Details of the weaknesses are described in each individual's examination report. Form ES-303-1. "Operator Licensing Examination Report." Copies of the evaluations have been forwarded under separate cover to the Training Manager in order to enable the licensee to evaluate the weaknesses and provide appropriate remedial training for those operators as necessary.

ų

• . · · · · · · . ,

ړ.

•

During one scenario. candidates failed to recognize that they were feeding a faulted/ruptured steam generator (SG) despite the fact that they had positive indication of full feedwater flow with a Main Steam Isolation Signal (MSIS) actuation. A similar performance discrepancy was noted on the last examination report (97-301). On another occasion. the candidate's did not make an attempt to energize the one available vital bus for 15 minutes after a Loss of offsite power had occurred (to ensure the maintenance of vital auxiliaries). Candidates also appeared hesitant to take manual control of systems when automatic controllers were not functioning properly prior to obtaining SRO verbal approval. This contributed to three of three crews having to trip the reactor when manual control of feedwater was attempted unsuccessfully following a feedwater flow transmitter failure.

c. <u>Conclusion</u>

The examiners concluded that SRO candidate performance on the written examination was weak. Overall performance on the operating test was satisfactory with some significant weaknesses noted in the areas of recognizing adverse plant parameters, understanding system response and taking manual control of equipment when automatic actions fail to occur.

08 Miscellaneous Operations Issues

a. <u>Scope</u>

The NRC reviewed the performance of the candidates during the dynamic simulator examinations and noted some performance discrepancies associated with the implementation of the Emergency Operating Procedures (EOP).

b. <u>Observations and Findings</u>

The examiners noted that different crew responses to the same series of events ended up with widely varying results. During the SG tube rupture with a faulted feed line scenario, one SRO candidate carefully noted the plants automatic response to the events and had the crew take immediate manual action to ensure that safety system actuations that should have occurred and equipment that should be operating was doing so prior to entering and reading 2-EOP-1. "Standard Post Trip Actions" (SPTA). In general, the other crews took actions to verify Engineered Safeguards Equipment was operating only when called out by steps within the EOPs. This had a major impact on this scenario since one train of feed



• • • • •

•

, .

•

,

regulating isolation valves failed open on a MSIS actuation resulting in continuous feeding of the faulted SG. Actuation of MSIS should have closed the feed header isolation valves. Two crews never reached the step to shut these valves because they had taken excessive time to reach this point (two hours) and the scenario was stopped. They were not close to the EOP-15 Success Path 3: Steam Generator with SIAS step 17. which directs isolating the affected SG per Appendix-R, directing closure of these valves. The fault on the SG was a feedline break inside containment. Consequently, there was no decrease in generator pressure as would be expected if the fault was in the steam line, but a drastic increase in containment pressure (30+ psia). A steam line break may result in an excessive cooldown or SG depressurization, which if RCS temperature decreases to less than 525 degrees F or SG pressure decreases to 600 psia, will prompt the operators to go to the contingency actions of RCS Heat Removal which eventually has the operators "Ensure MSIS has actuated." The examiners noted that there was no step within the SPTAs that directed the operators to ensure MSIS actuation if it started on high containment pressure. Since there was no specific compensatory action contained within the SPTAs, verification of proper system (MSIS) response could have identified the problem to the operators. If operators did not take manual action to ensure proper system response in this scenario, implementation of compensatory action within the EOPs would be delayed for over 30 minutes until the appropriate step was reached. The consequence of feeding a faulted SG for a prolonged period of time could result in unnecessary deposition of energy into containment and aggravation of the primary system overcooling event resulting in positive reactivity addition.

The NRC noted, from this and other examples, that some candidates were not verifying or ensuring safety system actuations in a timely manner. Licensee training representatives stated that operators should only take actions outside of the SPTAs if a safety function was being challenged. According to CEN-152 (Combustion Engineering Emergency Procedure Guidelines) SPTA Bases, the actions within the SPTAs were chosen to reflect the verification of expected automatic system responses and the actions which operators always take in response to a trip. In addition. steps within the SPTAs are considered immediate operator actions. After these are performed, the purposes for the SPTAs are to reverify the post trip actions which are performed by operators following any reactor trip, and to standardize a safety function approach to any event. Since MSIS is an expected automatic system response to high containment. pressure for Unit 2, verification of the systems proper response is congruent with the CEN-152 Bases ideology. However, 2-EOP-1 did not

,

•

.

.

• •



direct operators to verify MSIS when actuated by high containment pressure. Waiting until a safety function is challenged is not mentioned in the CEN-152 Bases document and is inconsistent with the intent of the SPTA procedure.

c. <u>Conclusion</u>

The NRC noted that confusion existed among the candidates with regards to the expectations of performing the immediate operator actions in the SPTAs of the EOPs. Current training on the implementation of the SPTAs. together with insufficient procedural guidance led to poor candidate performance. The procedural guidance and training of the operators combined to result in less than optimal mitigation of the events.

Management Meetings

X1. Exit Meeting Summary

At the conclusion of the site visit, the examiners met with representatives of the plant staff listed on the following page to discuss the results of the examinations and other issues.

None of the material provided to the examiners was identified by the licensee as proprietary.

PARTIAL LIST OF PERSONS CONTACTED

Licensee

- M. Allen, Training Manager
- T. Bolander, Training
- D. Brown, Initial Operations Training
- R. Dietz. Licensing
- D. Fadden, Services Manager
- J. Martin. Simulator Services Manager
- T. Quillen, Licensing
- L. Rich, Operations Training Supervisor
- A. Scales, Operations
- J. Stall, Site Vice President



<u>NRC</u>

G. Warnick, Resident Inspector

ITEMS OPENED, CLOSED, AND DISCUSSED

<u>Closed</u>

None.



.

. . • • ۰.

• .

• • • Ð • •

• • • · · ·

.

ENCLOSURE 2

SIMULATION FACILITY REPORT

Facility Licensee: Florida Power and Light - St. Lucie Plant

Facility Docket Nos.: 50-335 and 50-389

Operating Tests Administered on: June 22-25, 1998

This form is to be used only to report observations. These observations do not constitute audit or inspection findings and are not. without further verification and review. indicative of noncompliance with 10 CFR 55.45(b). These observations do not affect NRC certification or approval of the simulation facility other than to provide information that may be used in future evaluations. No licensee action is required in response to these observations.

While conducting the simulator portion of the operating tests, the following items were observed (if none. so state):

DESCRIPTION

None.

ITEM

Florida Power & Light Company, 6351 S. Ocean Drive, Jensen Beach, FL 34957



June 25, 1998

L-98-181 10 CFR 55.5

Regional Administrator, Region II U. S. Nuclear Regulatory Commission Attn: Mr. Thomas A. Peebles, Chief Operator Licensing and Human Performance Branch Atlanta Federal Center 61 Forsyth St., SW Suite 23T85 Atlanta, GA 30303

Re: St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 Operator License Training Program June 19, 1998 RO/SRO Exam Comments

On June 19, 1998, the NRC administered Reactor Operator (RO) and Senior Reactor Operator (SRO) Examinations at St. Lucie Plant. An exam analysis was performed after administration of the exams and the attached comments on the RO/SRO written examinations are submitted by the facility for consideration by the NRC. These comments affect questions 66, 70, 73, and 95 on the SRO examination. Questions 73 and 95 also affect the RO Examination.

Should you have any questions, please contact us.

Very truly yours,

J. A. Stall Vice President St. Lucie Plant

JAS/GRM

Attachment





•

ú

, .

•

· · ·

. •

· · · ·

Question 66

Unit 2 is at 70% power, returning from a SNO. As the RO withdraws control rods for ASI control, a 25 second continuous rod withdrawal event occurs. The excursion is stopped when the RO places the CEDMCS control switch in off. The following post event parameters are observed:

Reactor Power75%ASI-.42RCS Tcold545°FRCS Pressure2260 psig

Which of the following describes the effect this event has on Unit 2 DNB Tech Spec requirements, as compared to the same event occurring on Unit 1? (assume same post event parameters for Unit 1)

- a. Unit 2 DNB Tech Spec requirements are NOT met, Unit 1 DNB Tech spec requirements are met.
- b. Unit 1 DNB Tech Spec requirements are NOT met, Unit 2 DNB Tech spec requirements are met.
- c. Unit 1 and Unit 2 DNB Tech Spec requirements are NOT met.
- d. Unit 2 and Unit 1 DNB Tech Spec requirements are met.

· · ·

1 . а — т х

• .

. . .

•

.

.

1

.

5

.

• .

, وز .

. 4

Question 66: Change answer key for distractor A to distractor D. Unit 2 ASI falls exactly on the "Acceptable Operation" line, which would make distractor D the correct answer.

• • 、

•

•

ŕ .

• •

•

, ,

• .

v · ·



FIGURE 2.2-2

LOCAL POWER DENSITY-HIGH TRIP SETPOINT PART 2. (QR2 versus Y1)

2 - 4 - 4 --

. . . · · • 4

h

•

.

, A

.

•

• •

. . . .

· · · ·

.



FIGURE 2.2-2

LOCAL POWER DENSITY- HIGH TRIP SETPOINT PART 2 (QR2 Versus Y1)

, . . · · · •

. . • •

٩

. .

.

.

.

•

USNRC SENIOR REACTOR OPERATOR EXAMINATION

Question 70

According to AP-0010120, "Conduct of Operations" which of the following would be permissible concerning the manual initiation of the Auxiliary Feedwater Actuation System (AFAS)?

Manual initiation of:

a. AFAS 1 ten minutes after a trip from 100% power.

b. AFAS 1 and 2 during SPTAs due to a LOOP from 20% power

c. AFAS 1 and 2 ten minutes after a trip with S/G levels at 29% NR

d. AFAS 2 after a LOCKOUT during a cooldown for a SGTR in the 2B S/G.



Question 70: Accept distractor A and distractor B as the correct answer. Validated distractor B conditions on the simulator, and AFAS eventually actuated at approximately 17 minutes post trip. Considering new SPTA implementation method, SPTAs could still be in progress 17 minutes post trip.

. · · 4

•

•

•

, **v** · · ·

. . , v

• · ·



larry index

DESCRIPTION

LABEL

,			
RRFLUXA	AVERAGE NORMALIZED FLUX		1
SILSIN	LT_9013A SENSOR INPUT	0 376 A10 %	2
S1LSIN6	LT_9023A SENSOR INPUT	6 377 06 %	3
FKWRA	AFW FW HEADER A FLOW	lbs/sec	4
FKWRB	AFW FW HEADER B FLOW	lbs/sec	5
90			Ē

PAGE



AVERAGE NORMALIZED FLUX



larry : DATA RECORDED ON 25/JUN/98 AT 04:03:31



•



.

•

× .

.

•

, h











larry : DATA RECORDED ON 25/JUN/98 AT 04:03:31





larry : DATA RECORDED ON 25/JUN/98 AT 04:03:31


• • •

•.

.

•

; , (







larry : DATA RECORDED ON 25/JUN/98 AT 04:03:31



lbs/sec AFW FW HEADER A FLOW



lbs/sec

larry : DATA RECORDED ON 25/JUN/98 AT 04:03:31



Page 5

ST. LUCIE PLANT ADMINISTRATIVE PROCEDURE NO. 0010120, REVISION 103 CONDUCT OF OPERATIONS

APPENDIX E EOP OPERATING PHILOSOPHY (Page 7 of 12)

Emergency Operating Procedure Implementation: (continued)

1. (continued)

ì

- H. (continued)
 - 3. If a valid ESFAS actuation occurs, then the operating crew should NOT . exit EOP-1 to EOP-2. EOP-1 should be exited to one of the optimal recovery EOPs or EOP-15 for the following reasons:
 - a. The optimal recovery EOPs contain procedural steps to determine the extent of the damage.
 - b. EOP-2 entry conditions assumes an uncomplicated trip has occurred. A valid ESFAS actuation is NOT an uncomplicated trip.
 - 4. If a spurious invalid ESFAS actuation occurs in any plant mode, Then, perform the applicable EOP 99 table prior to restoration of components.
 - 5. Manual initiation of AFAS is allowable under the following circumstances:
 - a. Automatic actuation of the system did NOT occur after the appropriate time delay has elapsed.
 - b. When cooling down the RCS using only one Steam Generator, if the operable Steam Generator is affected by the AFAS rupture identification circuit.
 - c. During the loss of off-site power conditions, after AFAS actuation, if one feedwater header pressurizes before the other. This assumes neither feed header is ruptured.
 - 6. Manual initiation of AFAS should NOT be done during other scenarios because it defeats the rupture identification circuit. This does NOT prevent a crew decision to manually operate AFW components, start pumps and open valves, if deemed necessary.

USNRC SENIOR REACTOR OPERATOR EXAMINATION

Question 73

A LOOP/LOCA has occured on Unit 1 and the 1A EDG has failed to start. The ANPS has directed alignment of the 1B charging pump to the Auxiliary HPSI header per EOP-99, Appendix T. Which of the following describes the procedurally directed reason for this alignment?

To provide an alternate means of:

- a. Hot Leg Injection flow
- b. RCS makeup
- c. emergency boration
- d. collapsing the vessel head void

· ·

•



Question 73: Accept distractor B or distractor C as the correct answer. EOP-15 is the only place Appendix T is referenced in the event of a ruptured charging header and the need to emergency borate. EOP-15 is not mentioned in the stem. If the LOCA referenced in the stem was in the charging header, distractor B (RCS makeup) could be viable.

•	BEVISION NO .:	PROCEDURE TITLE:	,			PAGE:
•	14	FUNCTION	IAL REC	OVE	ERY `	11 of 201
	PROCEDURE NO .:	EMERGENCY OPI			ROCEDURE	
D	1-EOP-15	51. LU			5 2 BEACTIVITY	CONTROL
ų		• •				(continued)
		Success Path 2: E	mergend	у Во	oration CVCS	
в	INST	RUCTIONS		С	ONTINGENCY	
					ACTIONS	·
	· 2.		2.	(cor	ntinued)	
ļ				в.	(continued)	
	. :	•			2. Place control s V2501, "VCT I Valve" to CLOS hold closed.	witch for Discharge SE, and
		-			3. Locally OPEN following break	the ærs:
		× •			a. 1-42018 (V2 1B5 MCC)	2501 at
					, AND	
					b. 1-42017 (V2 1B5 MCC)	2504 at
	•				4. Release V250 V2501 control	4 and switches.
) .	3. Ensure pump is CVCS	at least one charging s operating using a llow path.	3.	<u>If</u> th una bor hea "Alt to F Hea	ne CVCS flow path available; <u>Then</u> eme ate using auxiliary ader per Appendix ⁻ emate Charging Fl RCS Through Aux. ader."	is ergency HPSI F, ow Path HPSI
•						•
						•

.

	REVISION NO .:	PROCEDURE TITLE:	PAGE:
ж а́	20	APPENDIXES/FIGURES/TABLES	71 of 117
	PROCEDURE NO.: 1-EOP-99	EMERGENCY OPERATING PROCEDURE ST. LUCIE UNIT 1	
		APPENDIX T ALTERNATE CHARGING FLOW PATH TO RCS <u>THROUGH AUX. HPSI HEADER</u> (Page 1 of 3)	
)	Letdown v due to los	<u>NOTE</u> will NOT be available while charging through Aux. HPSI I is of cooling flow through the regenerative heat exchange	Header er.
	1. <u>If</u> charging to V2429, "Ch	flow is lost due to a rupture or component failure <u>downsti</u> arging Pump Discharge Isolation," <u>Then</u> perform the follo	ream of wing:
	C	<u>CAUTION</u> losure of V3656 will render Aux. HPSI Header inoperable	
·)	A. CLOSE B. Place a	V3656, "HPSI Pump 1A Discharge Valve." (RTGB 106, I	Key 54) /hile
	C. Locally the faile Penetra	ng system. CLOSE V2429, "Charging Pump Discharge Isolation," to d portion of the line (located in pipe penetration room at tion Number 27).	isolate
	D. OPEN <u>c</u>	one Auxiliary HPSI Header Loop Isolation Valve:	
)	HCV-36 HCV-36 HCV-36 HCV-36	 17 1A2 Cold Leg 27 1A1 Cold Leg 37 1B1 Cold Leg 47 1B2 Cold Leg 	
	E. Locally Header	OPEN V2340, "Charging Pumps Discharge to Auxiliary H Isolation," located in 1A Charging Pump Room.	ipsi [*]
	F. Establis opening	h boration to charging pump by starting 1A or 1B BAM P V2514, "Emergency Borate Valve."	ump and
1	G. Start the shutdow	e desired charging pump and borate as necessary to main on margin greater than or equal to 3600 pcm.	intain .
U			
		(Continued on Next Page)	

· ·

·

, • • • • • • • • •

• •

. تر •

, .

.

-• . . *

* •

• •

. , 5

• • •



•

•		,	
	REVISION NO.: 20	PROCEDURE TITLE: APPENDIXES/FIGURES/TABLES	PAGE:
D	PROCEDURE NO.: 1-EOP-99	EMERGENCY OPERATING PROCEDURE ST. LUCIE UNIT 1	72 of 117
		APPENDIX T ALTERNATE CHARGING FLOW PATH TO RCS <u>THROUGH AUX. HPSI HEADER</u> (Page 2 of 3)	
	1. (continued)		
)	H. Verify c applical	harging flow to RCS by observing pressurizer level incr ble HPSI Loop Flow Indicator.	ease and
	FI-3311 FI-3321	FI-3331 FI-3341	
	I. Record and Tra	all charging pump cycles using AP 0010134, "Compon nsients," and forward to Technical Staff for review.	ent Cycles
	2. <u>If</u> a loss of o	charging flow path has occurred due to a line rupture of failure <u>upstream</u> of V2429, "Charging Pump Discharge m the following:	r Isolation,"
D	1	<u>NOTE</u> A Charging Pump will be required to perform this lineu	. .
	· A. CLOSE	V3656 "HPSI Pump 1A Discharge Valve." (RTGB 106,	Key 54)
	B. Place al realignin	I charging pump control switches to the STOP position	while
``````````````````````````````````````	C. Locally ( Header	CLOSE V2338, "1A Charging Pump Discharge to Charge Isolation."	ging Pump
)	D. OPEN <u>o</u>	ne Auxiliary HPSI Header Loop Isolation Valve:	
	HCV-36 HCV-36 HCV-36 HCV-36	<ul> <li>17 1A2 Cold Leg</li> <li>27 1A1 Cold Leg</li> <li>37 1B1 Cold Leg</li> <li>47 1B2 Cold Leg</li> </ul>	
	E. Locally ( Header I	DPEN V2340, "Charging Pump Discharge to Auxiliary H solation," located in 1A Charging Pump Room.	IPSI
		(Continued on Next Page)	

• >

.

L

÷

.

· · ·

* *

۰ ۰

•

.

r

-

•

, , ,

- <b>-</b>	REVISION NO.: 20	PROCEDURE TITLE: APPENDIXES/FIGURES/TABLES	PAGE:
D.	PROCEDURE NO.: 1-EOP-99	EMERGENCY OPERATING PROCEDURE ST. LUCIE UNIT 1	73 OF 117
		APPENDIX T ALTERNATE CHARGING FLOW PATH TO RCS <u>THROUGH AUX. HPSI HEADER</u> (Page 3 of 3)	
1.	. 2. (continue	d)	
	F. Estat openi	lish boration to charging pump by starting 1A or 1B BAM P ng V2514, "Emergency Borate Valve."	ump and
	G. Start shutd	the 1A Charging Pump and borate as necessary to maintai own margin greater than or equal to 3600 pcm.	n
	H. Verify applic	charging flow to RCS by observing pressurizer level increa able HPSI Loop Flow Indicator:	ase and
	FI-33 FI-33	1 FI-3331 21 FI-3341	
	I. Recor and T	d all charging pump cycles using AP 0010134, "Componen ransients," and forward to Technical Staff for review.	t Cycles
		· .	
		<del>.</del>	
٨			
		,	
•		```	
	1		

4

D

USNRC SENIOR REACTOR OPERATOR EXAMINATION

Question 95

According to ADM-11.03, "Temporary Change to Procedures", which one of the following is an example of a valid Temporary Change (TC) to a Procedure?

A Temporary Change that is:

- a. authorized for 92 days by the NPS and Operations Manager.
- b. authorized on an EPIP by the NPS with concurrence from the QA Manager.
- c. implemented for 14 days and to be reviewed by the FRG tomorrow.
- d: implemented to delete an Independent Verification on an inaccessible valve.





Question 95: Accept distractor C and distractor D as the correct answer. Distractor C does not state that the Temporary Change has actually been in use for 14 days. "The Temporary Change that <u>is</u> implemented" rather than "The Temporary Change that <u>has been</u> implemented" could mean originated with a 14 day time limit, therefore, FRG would be reviewing it on the second day after implementation.

•, •	REVISION NO .:	PROCEDURE TITLE:	PAGE:
• _	5	TEMPORARY CHANGE TO PROCEDURES	
	PROCEDURE NO .:	· ·	15 of 22
	ADM-11.03	ST. LUCIE PLANT	
	6.0 INSTRUC	TIONS (continued)	
	6.2 Proc	essing of TCs After Review/Approval	
	1.	TCs to Unit Specific PSL Procedures	
	· · · ·	A. The Author shall make a copy of the approved TC and to the controlled procedure in the associated Unit's Co Room.	d attach it ontrol
		<ol> <li>Place the original in the FRG Technician Bin located i Control Room.</li> </ol>	n the
	2.	Cs to Unit Common PSL Procedures	
		A. The Author shall make copies of the approved TC and distribute them as follows:	i
		<ol> <li>Attach one copy to the affected controlled procedu Unit 1 Control Room.</li> </ol>	ure in the
U		<ol> <li>Attach one copy to the affected controlled procedu Unit 2 Control Room.</li> </ol>	ure in the
•	. E	<ol> <li>Place the original in the FRG Technician Bin located in Control Room.</li> </ol>	n the
	3. 1	Cs to Contractor or Vendor Procedures	
	· /	A. The Author shall make a copy of the approved TC and to or file it with the onsite Master copy of the Contracto Vendor's procedure.	i attach it or's or
	E	<ol> <li>Place the original in the FRG Technician Bin located in Control Room.</li> </ol>	n the
•	4. T F	The FRG Technician shall ensure all TCs obtain FRG review of approval within 14 days of implementation.	ew and
<b>O</b>	_ 5. lı w s	n the event a TC is NOT approved by the Plant General N vithin 14 days of the TC implementation date, a Condition hall be generated.	/lanager Report
		•	

.

3

END OF SECTION 6.2



L-98-197

Regional Administrator, Region II U. S. Nuclear Regulatory Commission Attn: Mr. Thomas A. Peebles, Chief Operator Licensing and Human Performance Branch Atlanta Federal Center 61 Forsyth St., SW Suite 23T85 Atlanta, GA 30303

Re: St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 Operator License Training Program June 19, 1998 RO/SRO Exam Comments Question 73

On June 19, 1998, the NRC administered Reactor Operator (RO) and Senior Reactor Operator (SRO) Examinations at St. Lucie Plant. Attachment 1 to this letter provides amended comments regarding question 73 as requested during a July 16, 1998, discussion between Mr. G. Hopper (NRC) and Mr. Tim Bolander (FPL). Attachments 2, 3, and 4 are references that support the foundation of the comments.

Please contact us should you have any questions regarding this letter.

Very truly yours,

J. A. Stall Vice President St. Lucie Plant

JAS/spt



Attachments



St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 L-98-197 Attachment 1 Page 1 of 3

# June 1998 USNRC SRO Examination

Question 73 Amended Comment

#### Content:

Question stem refers to a LOOP/LOCA with one EDG failure. Question then asks for the reason to use Appendix T of EOP-99, which cross connects 1B Charging Pump with the Auxiliary HPSI header.

# Purposes:

Charging to Auxiliary HPSI is used for several purposes. They include:

1. Emergency Boration for reactivity control if the charging header is ruptured.

2. Inventory addition to the RCS if the charging header is ruptured.

3. Leak testing of the check valves in the ECCS system.

### **References** (attached):

- 1. CVCS design basis of St. Lucie Unit 1 UFSAR, section 9.3.4.1M & N
- 2. HPSI design basis of St. Lucie Unit 1 ECCS system text, 0711207
- 3. ONOP 1-0210030, "Charging and Letdown", Appendix B



St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 L-98-197 Attachment 1 Page 2 of 3

#### **Comments:**

The question gives no configuration that would require using either lineup. This requires the candidate to make at least two assumptions. The common assumption is that the charging header is ruptured. The second assumption leads to utilization of either purpose 1 or 2 of the cross connect.

LOCA is an event that can place Inventory Control in jeopardy. If the candidate reasonably assumed that the only available HPSI pump had failed, Inventory Control would be in jeopardy. This scenario would lead to implementation of EOP-15. After steps 1-9 are completed, the next process would be success path 2 of RCS Inventory control. The final contingencies of this path state the following: "If RCS Inventory Control is not satisfied, then:

- "A. Continue actions to establish Inventory Control while pursuing other safety functions that are in jeopardy."
   (A reasonable path would be the use of Appendix T to establish 44 GPM of makeup entering the RCS)
- "B. Request additional instructions from the Technical Support Center." (A reasonable path would be instructions for the use of Appendix T to establish 44 GPM of makeup entering the RCS)

If the candidate assumed multiple stuck CEAs, this would also lead to the implementation of EOP-15. After steps 1-9 are completed, the next process would be Success Path 2 of Reactivity Control. One of the contingency steps in Success Path 2 utilizes Appendix T to establish Emergency boration.

Comparing the Off-Normal (Appendix B) and Emergency (Appendix T) procedures:

- 1. ONOP step 7.25 uses Appendix B to establish an alternate charging path (makeup).
- 2. Neither appendix states the reason for establishing the lineup and both have the same title.
- 3. Both appendixes use the same steps for making the alignment, except the EOP appendix aligns the charging pump suction to the Boric Acid Makeup Tanks. This different alignment is expected as the charging pumps automatically align to the BAM tanks post SIAS.

, , , ,

1 . . . • • •

· ·

. 

• .

.

•

•

.



St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 L-98-197 Attachment 1 Page 3 of 3

# Conclusion:

From the information given in the stem of the question, an SRO could correctly answer the reason for this alignment is either RCS makeup or Emergency Boration.

Due to the reasons listed above, it is requested that both distractor B and distractor C be accepted as correct answers on this question.



#### 9.3.4 CHEMICAL AND VOLUME CONTROL SYSTEM

#### 9.3.4.1 Design Bases

-----

The chemical and volume control system is designed to:

- a) maintain the chemistry and purity of the reactor coolant within the limits specified in Table 9.3-8
- b) maintain the required volume of water in the reactor coolant system by compensating for coolant contraction or expansion due to plant step load changes of ±10 percent of full power and ramp changes of ±5 percent of full power per minute between 15 and 100 percent power and for reactor coolant losses or additions
- c) accept out-flow from the reactor coolant system when the reactor coolant is heated at the administrative rate of 75F/hr and to provide the required makeup when the reactor coolant is cooled at the administrative rate of 75F/hr using two charging pumps
- d) accommodate the reactor coolant system water inventory change for a full-to-zero power decrease with no makeup system operation and with the volume control tank initially at the normal operating level band
- e) inject concentrated boric acid into the reactor coolant system upon a safety injection actuation signal (SIAS)
- f) control the boron concentration in the reactor coolant system to obtain optimum control element assembly (CEA) positioning to compensate for reactivity changes associated with large changes in reactor coolant temperature, core burnup, and xenon concentration variations, and to provide shutdown margin for maintenance and refueling operations
- g) inject boron in sufficient quantity to counteract the maximum reactivity increase due to cooldown at 75F/hr and xenon decay using one charging pump
- h) automatically divert the letdown flow to the waste management system (WMS) when the volume control tank is at the highest permissible
   level
- i) provide continuous on-line measurement of reactor coolant boron concentration and radioactivity due to fission and corrosion products
- j) assure that the radioactivity due to corrosion and fission products in the reactor coolant system does not exceed Technical Specification limits for an assumed 1 percent failed fuel condition
- k) provide auxiliary pressurizer spray for operator control of the reactor coolant system pressure during the final stages of shutdown and to allow for the cooling of the pressurizer

9.3-17

1) collect the controlled bleedoff from the reactor coolant pump seals

should the normal charging path become inoperable.

- n) leak test the reactor coolant system
- 0) withstand the environmental conditions as presented in Section 3.11

F

- p) withstand the expected transients given in Table 9.3-9 without any adverse effects.
- q) supply a source of coolant water to be injected into the reactor coolant pump seals
- r) provide a means for filling and maintaining the boron concentration of the Safety Injection Tanks

Portions of the CVCS system required for safe shutdown are designed and built to meet the requirements of seismic Class I in accordance with Regulatory Guide 1.29 to satisfy the design bases (e) and (f) above during and after a design bases earthquake, such as the boric acid injection portions of the systems from the boric acid makeup tanks through the boric acid makeup pumps and the charging pumps. The letdown line through the letdown heat exchangers (and the component cooling water supply), the ion exchangers and volume control tank are not required for boron injection and accordIngly are designed to be Quality Group D and non-seismic Class I. FSAR Appendix 3D presents a discussion of a CVCS letdown line break and mitigation with the resultant effects on safety related equipment due to the accident environment.

The pressurizer steam space (vented through the pressurizer power relief valves) and contraction due to reactor coolant system cooldown provides sufficient volume for the injection of the required amount of concentrated (2.5 weight percent minimum) boric acid to provide a minimum of 5 percent  $\Delta \rho$  subcritically at cold shutdown.

9.3-18



Amendment:15, (1/97)

•

• . . • , . . .

* * **y** . •

• • .

• 4

• • •

•

.

. .

•

`

•



The HPSI System HP [B] header and auxiliary HP [A] header are protected from over pressurization by a relief valve located on each header. The HP [B] header relief valve, V3412, is a back pressure compensated valve with a set pressure of 1750 psig and a capacity of 5 gpm. The auxiliary HP [A] header relief valve, V3417, has a set pressure of 2485 psig and a capacity of 132 gpm. The increased capacity and set pressure of the auxiliary HP [A] header relief valve allows the charging pumps to use this piping for charging into the RCS (not a normal path).

#### c. Low Pressure Safety Injection

The purpose of the Low Pressure Safety Injection (LPSI) pumps is to inject borated water into the RCS to minimize the severity of a LOCA by injecting with sufficient capacity to keep the core cooled during the injection phase. The LPSI pumps are also used to provide shutdown cooling flow, fill the SITs and provide purification flow for the RCS while shutdown.

The LPSI System consists of two pumps with separate suction headers from the RWT. The two pumps automatically start on SIAS and discharge through normally open motor operated valves. LPSI pump A discharges through V3206. LPSI pump B discharges through V3207. These valves are motor operated on Unit 1 and manually operated on Unit 2. The discharge flow, in Unit 1, then combines into a single pipe through an air operated flow control valve, FCV-3306, into a four pipe low pressure header. Refer to Figure 1. [Unit 2 LPSI discharge piping consists of two separate lines, as shown in Figure 2, each supplying a two pipe low pressure header, A and B.] Valve FCV-3306 [FCV 3306 and FCV 3301] is controlled from RTGB 106 [206] by a two-position, AUTO-LOCKED OPEN switch. Each low pressure header is provided with a normally closed motor operated isolation valve which opens automatically on a SIAS thus opening the flow path for safety injection into the RCS. The LPSI header isolation valves are powered from the following 480 V power supplies: HCV 3615, LPSI to loop A2. MCC A5; HCV 3625, LPSI to loop A1, MCC A6; HCV 3635, LPSI to loop B1, MCC B5: HCV 3645, LPSI to loop B2, MCC B6. All four valves can be controlled from RTGB 106 by individual three-position CLOSE-AUTO-OPEN (spring return to





۲.

. . e • .

ler.

.

•

. .

REVISION NO.:	FUNCTION	AL RE	COVERY	PAGE:
PROCEDURE NO.: 1-EOP-15	EMERGENCY OPE ST. LU	ERATIN CIE UN	IG PROCEDURE. NIT 1	35 of 201
	Success Path 2: SI	AS and	5.4 RCS INVENTORY	CONTROL (continued)
INST	RUCTIONS		CONTINGENCY ACTIONS	,
14. (continu	ed)	1		
B. At R and Cont Valve swite OPE C. Ensu annu Y-19 Leak	TGB 105, OPEN V6301 V6302, "RDT ainment Isolation es" by placing the thes to RESET, <u>Then</u> N. The CRAC panel inciator, Annunciator , "ECCS Pump Room age Valves Misaligned"	• •		
is lit. I 15. Verify "F is being following A. Read indica (Sens page	ACS Inventory Control" satisfied by the g criteria: for vessel level ates core is covered. sors 7 and 8 covered, 212, QSPDS.) AND	15.	<ul> <li><u>If</u> "RCS Inventory Con NOT satisfied, <u>Then</u>:</li> <li>A. Continue actions establish invento while pursuing of functions in jeopa</li> <li>B. Request addition instructions from Technical Support</li> </ul>	trol" is to ny control her safety ardy. al the rt Center.
				!

7

(Continued on Next Page)



• •

*

r • ·

*,* 

• • •

.



PROCE	ол NO 31		CHARGING AND LETDOWN	
PROCE				<b>•</b> • • • •
	EDURE	NO.:	OFF-NORMAL OPERATING PROCEDURE	2 of 18
1-	0210	030	ST. LUCIE UNIT 1	
1.0	TITL	<u>.E</u> :		
	CHA	RGIN	G AND LETDOWN	
2.0	<u>PUF</u>	POSE	<u></u>	
	This flow.	proce	dure provides instructions for reestablishing Charging and	l Letdown
'n	lf a i valve	malfun e, this	nction occurs with the in-service letdown level or pressure procedure provides steps for placing the alternate valve i	control n service.
3.0	REF	EREN	ICES:	
	3.1	St. L	ucie Unit 1 FUSAR, Chapter 9.3.4.	• •
	3.2	P & I	D Flow Diagrams 8770-G-078 Sheets 120, 121, 130 and	131.
	3.3	Cont	rol Wiring Diagram, 8770-B-327, Sheet 139	
	3.4	ONO	P 1-0250031, "Boron Concentration Control."	
	3.5	Unit	1 Technical Specifications.	
	3.6	One	or more of the following symbols may be used in this pro-	cedure.
		1. § s	Indicates a Regulatory commitment made by technical specifications, condition of license, audit, LER, bulletin, etc should NOT be revised without Facility Review Group app	c. and roval.
		2. ¶ r	Indicates a management directive, vendor recommendator practice or other non-regulatory commitment that should N revised without consultation with the plant staff.	ion, plant IOT be
		3. 9	Y Indicates a step that requires a sign off on a data shee	t.
4.0	REC	ORDS	S REQUIRED:	
	4.1	Norm	nal log entries.	

D

ſ

• . · · · . • , , ,

•

· · · · • • . . ``

٩

*



REVIS	NO.:	PROCEDURE TITLE:	PAGE:			
31		CHARGING AND LETDOWN	2 of 19			
PROC	EDURE NO.: .	OFF-NORMAL OPERATING PROCEDURE ST. LUCIE UNIT 1	3 01 10			
5.0	ENTRY CO	ONDITIONS:	-			
	Any one o	r more of the following conditions exist:				
	5.1 Loss	of charging flow.	1			
	5.2 Letdo	2 Letdown isolation valves close, isolating letdown.				
	5.3 Letdo	Letdown high-low pressure.				
	5.4 Trans line-u	sfer of letdown level/pressure control valves to alternat up is required.	e valve			
6.0	EXIT CONDITIONS:					
	6.1 Norm stable	nal Charging/Letdown flows are established with press	urizer level			
		<b>x</b>				
	•		ı.			
		•				
		•				

Ĵ



31 PROCEDURE NO.: 1-0210030		CHARGING AN	1D LETDOWN	
		OFF-NORMAL OPERATING PROCEDURE		4 of 18
7.0 O	PERATC	R ACTIONS:		<u> </u>
7.	1 imme	diate Operator Actions:		
	INS	STRUCTIONS	CONTINGENCY ACTIONS	
1.	<u>lf</u> letdo STOP	own flow is lost, <u>Then</u> the charging pumps.		
	A. Ri çc	ETURN charging pump ntrol switches to AUTO.		
2.	<u>lf</u> char ISOLA	ging flow is lost, <u>Then</u> TE letdown.		
7.	2 Subse	quent Operator Actions:		
1.	<u>If</u> char has be power consta pressu	ging and letdown flow en lost, <u>Then</u> maintain and temperature nt to minimize rizer level deviations.	•	
2.	VERIF automa occurra contair automa	Y all applicable atic actions have ed. Appendix A as a listing of expected atic actions.		
3.	<u>If</u> char has be DETER	ging and letdown flow en lost, <u>Then</u> RMINE the cause.	· · ·	
4.	<u>If</u> a cha occurre leak ar Techni guidan	arging system leak has ed, <u>Then</u> ISOLATE the ad refer to applicable cal Specifications for ce.	·	
5.	<u>If</u> the n path be <u>Then</u> F Altema through Heade	ormal charging flow ecomes unavailable, REFER to Appendix B, te Charging Flow Path n Auxiliary HPSI		

,

a

*

F

-. · · · · · ·

. . • 

.

REVISION NO.:	PROCEDURE TITLE:		PAGE:
31	CHARGING A	ND LETDOWN	E of 19
PROCEDURE NO.: 1-0210030	OFF-NORMAL OPEF ST. LUC	RATING PROCEDURE	50110
7.0 OPERATO	R ACTIONS: (continued)		
7.2 (contir	ued)		
INS	STRUCTIONS	CONTINGEI ACTIONS	NCY S
6. <u>If</u> letdo pressu tempo cycling	own is unavailable, <u>then</u> Irizer level may be rarily maintained by 9 charging pumps.	,	
<u>If</u> one or i binding m (hydroger (nitrogen after resto	<u>N(</u> more charging pumps have ay have occurred. This ca binding) or rupture of a ch binding). If this is the case oring a source of water to th	<u>DTE</u> lost pumping ability, <u>The</u> n result from pumping the arging pump suction acc , the charging pumps mu ne suction.	n·gas- e VCT dry umulator st be vented
7. <u>If</u> char been l <u>Then</u> l and let	ging and letdown has ost and can be restored, REESTABLISH charging tdown flow as follows:	7.	
A. El lev	NSURE adequate VCT vel is indicated.	A. RESTORE the normal operatin Refer to ONOF "Boron Concer Control."	VCT to the ng band. P 1-0250031 atration
B. EN co sw pro se se pro pro	NSURE the letdown level ntrol valve selector vitch and the letdown essure control valve lector switch are lected to the level and essure control valves esently in service.	, ,	
C. M/ AL	ATCH the JTO-MANUAL output of		

,

P

•
• •	REVISION NO .: .	PROCEDURE TITLE:	· · · · · · · · · · · · · · · · · · ·	PAGE:
	31	CHARGING	AND LETDOWN	
·	PROCEDURE NO .:			6 of 18
		OFF-NORMAL OF	PERATING PROCEDURE	
	1-0210030	SI.L		
	7.0 OPERATO	PRACTIONS: (continued	1)	
	7.2 (contir	nued)		· · ·
		STRUCTIONS	CONTINGENCY	,
		4		
	7. (contir	nued)		
	D. SI cc <u>Tr</u>	HIFT the letdown level ontroller to MANUAL, .		
,	E. El pr Al 15	NSURE the letdown essure controller in JTO and set to maintain 50 psig.		
P	F. Pl pc sv pc	ACE the letdown valve osition limiter bypass key vitch in the BYPASS osition.		
,	G. ST	FART one charging imp and verify flow.	·	
•	H. VE he ter or pr V2 (le	ERIFY that regenerative pat exchanger high . mperature alarm, SIAS CIS alarms are NOT esent, <u>Then</u> OPEN 2515 and V2516 etdown isolation valves).	•	
	If V2515 necessary until flow	reclosed due to a high le / to cycle V2515 while op is adequate to clear the l	<u>NOTE</u> tdown line temperature, <u>Then</u> it bening the letdown level control high temperature alarm.	may be valve
	I. SL let an 5	OWLY OPEN the down level control valve d ESTABLISH proximately GPM letdown flow.		• •

. 

٠ .

. .

.

•

ĸ

6

•

•

•

.

*

•

•

-

3

, .

• .

y. . ۳ ۹ ۴

5 •

31				7 of 18
PROCEDURE NO	).: )	OFF-NORMAL OPEF		
1-021003	<u>ν.</u> ΔΤΟ	B ACTIONS (continued)		
7.0 <u>01 - 1 - 1</u>	<u>Arc</u>			
7.2 (c	ontin	ued)	-	
	INS	TRUCTIONS	CONTINGENCY ACTIONS	
7. (c	ontin	ued)		
Prolo going	ongeo g soli	<u>CAL</u> d use of charging without le id. Pressurizer level must b	<u>JTION</u> etdown could result in the pres be closely monitored.	surizer
	*			و 
Char	ging	temperature should NOT b	e allowed to increase more un	
J.	ging ninut <u>W</u> tei ind rat GI mi	temperature should NOT b e. <u>hen</u> letdown mperature stabilizes, crease letdown flow at a te NOT to exceed 5-10 PM over at least a four nute period, until	J. <u>If</u> letdown cannot be restored, <u>Then</u> initia charging as required restoring pressurized seal injection or bor	en ou P ete d for r level, ration.
J.	ging ninut <u>W</u> ter inc rat GI mi let flo	temperature should NOT b e. <u>hen</u> letdown mperature stabilizes, crease letdown flow at a te NOT to exceed 5-10 PM over at least a four nute period, until down and charging ws are matched.	J. <u>If</u> letdown cannot be restored, <u>Then</u> initia charging as required restoring pressurize seal injection or bor	en ou P ite d for r level, ration.
J.	ging ninut W ter ind rai GI GI EN flo EN pro ma	hen letdown mperature stabilizes, crease letdown flow at a te NOT to exceed 5-10 PM over at least a four nute period, until down and charging ws are matched. NSURE the letdown essure controller is aintaining letdown essure at 150 psig.	J. <u>If</u> letdown cannot be restored, <u>Then</u> initia charging as required restoring pressurize seal injection or bor	e ite d for r level, ration.
J.	ging ninut W ten rai Gl ni let flo EN ma pro BA lev AL	hen letdown mperature stabilizes, crease letdown flow at a te NOT to exceed 5-10 PM over at least a four inute period, until down and charging ws are matched. NSURE the letdown essure controller is aintaining letdown essure at 150 psig. ALANCE the letdown /el control Auto-Manual tputs, <u>Then</u> shift to the JTO position.	J. <u>If</u> letdown cannot be restored, <u>Then</u> initia charging as required restoring pressurize seal injection or bor	an our ate d for r level, ration.



.

D



,

,

* ۲ *

• * 4 , ^ · · · • • , • •

•

.

۰.

• •

Ċ	REVISION NO .:	PROCEDURE TITLE:	· · · · · · · · · · · · · · · · · · ·	PAGE:
	31	CHARGING	AND LETDOWN	8 of 18
	1-0210030	OFF-NORMAL OPE		00110
	7.0 <u>OPERATC</u>	DR ACTIONS: (continued)		
,	7.2 (contin	nued)		×
-	INS	STRUCTIONS	CONTINGENCY ACTIONS	
	7. (contin	nued)	' .	
•	V	<u>CA</u> /2345, Lètdown Safety Rel	UTION lief Valve will open at 600 psig.	
	N. SL let co se EN be	OWLY RAISE the down pressure introller (PIC-2201) tpoint to 430 psig and NSURE pressure is ing maintained.		
	8. <u>If</u> Letd malfun PERFC	own <b>Level</b> control is octioning, <u>Then</u> DRM the following:		
•	A. VE Hi	ERIFY output of C-1110, PZR LEVEL DN CNTL VLV	A. PLACE HIC-1110 in MANUAL.	
	res cu	sponding as expected to rrent plant conditions.	1. ADJUST Letdow to a value consis current plant con	n Flow ` tent with ditions.
	-		2. PERFORM a sys walkdown obsen evidence of leak lifting relief valve	stem /ing for age or s.
	B. VE · con as out	RIFY selected level ntrol valve responding expected to HIC-1110 tput.	B. PLACE Alternate Let Level Control Valve service using OP 1-0 Charging and Letdow Normal Operation.	:down in )210020, vn -
				/R31

•

e

۰,

ŀ

. • •

.

. ,

.

**、** .

•

• •

. •

ų

•				PAGE
• •	REVISION NO .:	PROCEDURE TITLE:		
	31		AND LEIDOWN	0 -5 10
	PROCEDURE NO .:	OFF-NORMAL OPE	RATING PROCEDURE	90118
	1-0210030	ST. LUCIE UNIT 1		
	7.0 <u>OPERATO</u>	R ACTIONS: (continued)		
	7.2 (contin	nued)	*	
	INS	STRUCTIONS	CONTINGENCY ACTIONS	,
	9. <u>If</u> Let is ma PERF	down <b>Pressure</b> control Ifunctioning, <u>Then</u> FORM the following:	r	
	A. V.	/ERIFY output of PIC-2201, LTDN	A. PLACE PIC-2201 ii MANUAL.	n
	F a	PRESSURE, responding as expected for current plaint conditions.	<ol> <li>ADJUST Letdor Pressure to a v consistent with plant conditions</li> </ol>	wn alue current s.
			2. PERFORM a sy walkdown obse evidence of lea lifting relief valv	ystem rving for` kage or ⁄es.
	B. V p ra ta	/ERIFY selected pressure control valve esponding as expected o PIC-2201 output.	B. PLACE Alternate L Pressure Control V service using OP 1 Charging and Letde Normal Operation.	etdown alve in -0210020, own -
			•	/R31
	· · ·			
T				

£	BEVISI	ON NO :	PBOCEDURE TITLE:	PAGE:						
		31	CHARGING AND LETDOWN							
:	PROCE	DURE NO.:	OFE-NORMAL OPERATING PROCEDURE	10 of 18						
e	1-	0210030	ST. LUCIE UNIT 1							
				•						
		CHARGING AND LETDOWN AUTOMATIC RESPONSES (Page 1 of 1)								
	1.	Regenerati V2515, Let	ive heat exchanger high outlet temperature of 470°F closed address and sol. Valve.	. es						
	2.	High ∆P ac Letdown Is	cross the regenerative heat exchanger of 275 psid closes ol. Valve.	s V2516,						
	з.	Charging p	numps trip on low suction pressure of 10 psia.							
	4.	Letdown he boronomet the purifica	eat exchanger high outlet temperature of 145°F isolates er and process radiation monitor and diverts letdown flow tion ion exchangers.	flow to the v around						
			· · ·							
			•	•						
		-								
		••	х х							
3										
ŧ		•	• ·							
		r	•							
		μ								
			•							
		•								
				*						

.

Ð

## END OF APPENDIX A

	BEVISION NO .:	PROCEDURE TITLE:	PAGE:
a á	31	CHARGING AND LETDOWN	11 of 18
	PROCEDURE NO.:	OFF-NORMAL OPERATING PROCEDURE	
	1-0210030		
		ALTERNATE CHARGING FLOW PATH TO RCS	
		THROUGH AUXILIARY HPSI HEADER	
		· (Page 1 of 8)	
			INITIAL
		CAUTION	
	Use of Disch	this flow path has the potential for lifting V3417, 1A/1C HP Hdr Relief, once a charging pump is started.	SI Pump
۰			·
·	Letdow header exchar	<u>NOTE</u> In will NOT be available while charging through Auxiliary HI due to loss of cooling flow through the regenerative heat nger.	PSI
	1. Ensure	all charging pumps are off.	
	2: <u>If</u> chargi <u>downstr</u> <u>Then</u> pe	ing flow is lost due to a rupture or component failure eam of V2429, Charging Pump Disch at Penetr #27 Isol, erform the following:	
	Cic	<u>NOTE</u> osure of V3656 will render the Auxiliary HPSI Header inope	rable.
	A. Clo	se V3656, HPSI Pump 1A Discharge.	
	When Specif	<u>CAUTION</u> all charging pumps are in the STOP position, Technical ication 3.0.3 is applicable.	
	B. Pla	ce all charging pump control switches to the STOP position	l
	C. Loc	ally close V2429, Charging Pump Disch at Penetr #27 Isol ated in penetration room at Penetration Number 27.	
		•	

REVISION NO.	PROCEDURE TITLE:	PAGE:	
31	CHARGING AND LETDOWN	12 of 19	
PROCEDURE NC	OFF-NORMAL OPERATING PROCEDURE ST. LUCIE UNIT 1	12 01 18	
1021000	APPENDIX B ALTERNATE CHARGING FLOW PATH TO RCS THROUGH AUXILIARY HPSI HEADER (Page 2 of 8)		
2. (contin	ued)	INITIAL	
D. O	pen one of the following valves:		
- H0 - H0 H0 H0 H0	CV-3617, AUX HPSI Hdr to Loop 1A2 valve. CV-3627, AUX HPSI Hdr to Loop 1A1 valve. CV-3637, AUX HPSI Hdr to Loop 1B1 valve. CV-3647, AUX HPSI Hdr to Loop 1B2 valve.		
E. Lo Ho	cally open V2340, Charging Pump Disch Hdr to Aux HPSI Ir Isol, located in 1A Charging Pump Room.		
F.· In: au	stall the following temporary jumpers to prevent charging pur to start on low pressurizer level:	ıp	
R	TGB 103, Terminal Board HH, T58 to T59.		
R	TGB 103, Terminal Board HH, T59 to T60.	<u> </u>	
G. Er to	nsure RCS pressure is being maintained less than or equal 2250 psia.		
• U 72 H m • R pu be	<u>CAUTION</u> se of this flowpath will result in a boron addition to the RCS. 25 gallons of highly borated water may be contained in the Au PSI header line being used. RCS temperature must be close onitored during this evolution. CS pressure must NOT exceed 225 psia at any time a charg ump is discharging into the HPSI header. The charging pump e stopped if pressure exceeds 2250 psia.	Up to uxiliary ely ing p must	
H. St	art the selected charging pump.	<b>.</b>	
I. Re	eturn selected charging pump control switch to the AUTO	٠	
pc	ISILION.	·	

Ô

C

a

•

	NO.:	PROCEDURE IIILE:	FAGE.
REVISION			
3	51		13 of 18
	RE NO.:	OFF-NORMAL OPERATING PROCEDURE	
1-02	10030		<u> </u>
		ALTERNATE CHARGING FLOW PATH TO RCS	
		THROUGH AUXILIARY HPSI HEADER	
		(Page 3 of 8)	
		, ,	
2. (co	ontinue	d)	INTTAL
		CAUTION CAUTION	
ļ	t chargi	ing flow to the RCS can NOT be verified, <u>Then</u> V3417,	
Ľ		1751 Pump Disch Hur Hellel, may have lined.	
T	Vorifi	v charging flow to BCS by observing pressurizer level	
υ.	incre	ase and applicable HPSI I oop flow indicator FI-3311.	
	FI-33	21. Fl-3331 or Fl-3341.	
		· · · · · · · · · · · · · · · · · · ·	
к.	<u>lf</u> V34	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, Then	
К.	<u>If</u> V34 perfo	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> m the following:	
К.	<u>If</u> V34 perfo	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> rm the following:	
K.	<u>If</u> V34 perfo /3417 w 212 psi	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> rm the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig.	imately
K. V 2	<u>If</u> V34 perfo /3417 w 212 psi	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> rm the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig.	imately _
K. V 2	<u>If</u> V34 perfo /3417 w 212 psi 1. S	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> rm the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig. Stop the charging pump.	imately
K. V 2	<u>If</u> V34 perfo 23417 w 212 psi 1. S 2. <u>V</u> li	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> rm the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig. Stop the charging pump. <u>When</u> V3417 has reseated, <u>Then</u> determine the cause for i ift.	imately ,
K. V 2	<u>If</u> V34 perfo /3417 w 212 psi 1. S 2. <u>V</u> ii 3. Ii	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> m the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig. Stop the charging pump. <u>When</u> V3417 has reseated, <u>Then</u> determine the cause for i ift. f it has been determined that V3417 is NOT malfunctioning	imately
K. V 2	<u>If</u> V34 perfo /3417 w 212 psi 1. S 2. <u>V</u> ii 3. <u>II</u>	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> m the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig. Stop the charging pump. <u>When</u> V3417 has reseated, <u>Then</u> determine the cause for i ift. <u>f it has been determined that V3417 is NOT malfunctioning</u> <u>Then</u> restart the charging pump.	imately ,  its
K. V 2	<u>If</u> V34 perfo /3417 w 212 psi 1. S 2. <u>V</u> ii 3. <u>II</u>	A17, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> rm the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig. Stop the charging pump. <u>When</u> V3417 has reseated, <u>Then</u> determine the cause for i ift. <u>I</u> it has been determined that V3417 is NOT malfunctioning <u>Then</u> restart the charging pump.	imately _  its g,
K. V 2	<u>If</u> V34 perfo 23417 w 212 psi 1. S 2. <u>V</u> 1i 3. <u>If</u> 4. <u>If</u>	A17, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, <u>Then</u> rm the following: <u>NOTE</u> vill not reseat until HPSI header pressure lowers to approx ig. Stop the charging pump. <u>When</u> V3417 has reseated, <u>Then</u> determine the cause for i fit. <u>I</u> it has been determined that V3417 is NOT malfunctioning. <u>Then</u> restart the charging pump. <u>I</u> it has been determined that V3417 is malfunctioning, <u>The</u> estore systems' alignment to normal per Step N.	imately , its g, <u></u>
К.   V 2 	<u>If</u> V34 perfo /3417 w 212 ps 1. S 2. <u>V</u> ii 3. <u>II</u> 4. <u>II</u> ro Cycle Press	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, Then m the following:         NOTE         vill not reseat until HPSI header pressure lowers to approxig.         Stop the charging pump. <u>When</u> V3417 has reseated, <u>Then</u> determine the cause for inft.         f it has been determined that V3417 is NOT malfunctioning.         f it has been determined that V3417 is malfunctioning, <u>The</u> estore systems' alignment to normal per Step N.         e the selected charging pump as necessary to maintain surizer level between 55% and 67%.	imately its g, <u>en</u>
K.   V 2	<u>If</u> V34 perfo /3417 w 212 psi 1. S 2. <u>V</u> ii 3. <u>II</u> 4. <u>II</u> rd Cycle Press	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, Then im the following:         NOTE         vill not reseat until HPSI header pressure lowers to approxig.         Stop the charging pump.         When V3417 has reseated, Then determine the cause for inft.         f it has been determined that V3417 is NOT malfunctioning.         f it has been determined that V3417 is malfunctioning, The estore systems' alignment to normal per Step N.         e the selected charging pump as necessary to maintain surizer level between 55% and 67%.	imately its g, en
K. V 2 L. M.	<u>If</u> V34 perfo /3417 w 212 psi 1. S 2. <u>V</u> ii 3. <u>II</u> 4. <u>II</u> rd Cycle Press Reco Cycle	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, Then         rm the following:         NOTE         vill not reseat until HPSI header pressure lowers to approxig.         Stop the charging pump. <u>When</u> V3417 has reseated, <u>Then</u> determine the cause for inft.         f it has been determined that V3417 is NOT malfunctioning.         f it has been determined that V3417 is malfunctioning, <u>The</u> estore systems' alignment to normal per Step N.         e the selected charging pump as necessary to maintain surizer level between 55% and 67%.         rd all charging pump cycles per AP 0010134, "Componentes and Transients," and forward to Technical Staff for revise	imately its g, <u>en</u>
K. V 2 L. M.	<u>If</u> V34 perfo /3417 w 212 psi 1. S 2. <u>V</u> ii 3. <u>If</u> 4. <u>If</u> rd Cycle Press Reco Cycle	417, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, Then         rm the following:         NOTE         vill not reseat until HPSI header pressure lowers to approxig.         Stop the charging pump.         When V3417 has reseated, Then determine the cause for inft.         f it has been determined that V3417 is NOT malfunctioning.         f it has been determined that V3417 is malfunctioning.         f it has been determined that V3417 is malfunctioning.         f it has been determined that V3417 is malfunctioning.         f it has been determined that V3417 is malfunctioning.         f it has been determined that V3417 is malfunctioning.         f all charging pump as necessary to maintain surizer level between 55% and 67%.         rd all charging pump cycles per AP 0010134, "Componentes and Transients," and forward to Technical Staff for reviewers of the selected staff for reviewers.	imately its g, en t

·

.

• . ٩ • • •

•

.

.

۰ с Х . . .

. · · · · · · • . - · · ****** . * *

. . • • • .

• , . . ٠

•

÷

·

.

и



,

	J.:	PROCEDURE TITLE:	PAGE:
31 PROCEDURE NO.: 1-0210030		CHARGING AND LETDOWN '	14 of 19
		OFF-NORMAL OPERATING PROCEDURE ST. LUCIE UNIT 1	14 01 16
		APPENDIX B <u>ALTERNATE CHARGING FLOW PATH TO RCS</u> <u>THROUGH AUXILIARY HPSI HEADER</u> (Page 4 of 8)	
2. (con	ntinued	)	INITIAL
N.	<u>When</u> heade	alternate charging to the RCS through the Auxiliary HPS r is no longer desired, <u>Then</u> perform the following:	1
	1. E	nsure the charging pumps are off.	
	2. Lo A	ocally close V2340, Charging Pump Disch Hdr to ux HPSI Hdr Isol, located in 1A Charging Pump Room.	/ I.V.
	3. C	lose or ensure closed the following valves:	
	H H H H	CV-3617, AUX HPSI Hdr to Loop 1A2 valve. CV-3627, AUX HPSI Hdr to Loop 1A1 valve. CV-3637, AUX HPSI Hdr to Loop 1B1 valve. CV-3647, AUX HPSI Hdr to Loop 1B2 valve.	/ I.V.
	4. Lo . Po	ocally lock open V2429, Charging Pump Disch at enetr #27 Isol.	/ I.V.
	5. Lo	ock open V3656, HPSI Pump 1A Discharge.	/ I.V.
ŗ	6. R	emove the following jumpers:	
	Α.	RTGB 103, Terminal Board HH, T58 to T59	/ I.V.
	B.	RTGB 103, Terminal Board HH, T59 to T60	/ I.V.
O.	Notify leak te	Technical Staff to perform required check valve esting when this evolution is complete.	

•

D

٠

C



· · ·

.

•



•

.

NEVISION I	10.:	PROCEDURE TITLE:	PAGE:
3	1	CHARGING AND LETDOWN	15 of 10
PROCEDUR	E NO.: 0030	OFF-NORMAL OPERATING PROCEDURE ST. LUCIE UNIT 1	15 01 18
	<u> </u>	APPENDIX B ALTERNATE CHARGING FLOW PATH TO RCS THROUGH AUXILIARY HPSI HEADER (Page 5 of 8)	INITIAL
3. <u>If</u> a rup Dis	loss of oture or o sch at Pe	charging flow path has occurred due to a line component failure <u>upstream</u> of V2429, Charging Pump enetr #27 Isol, <u>Then</u> perform the following:	x
"		<u>NOTE</u> 1A charging pump will be required to perform this lineup.	
A.	Close	V3656, HPSI Pump 1A Discharge.	
В.	Place : while r	all charging pump control switches to the STOP position ealigning system.	
C.	Close	V2429, Charging Pump Disch at Penetr #27 Isol.	
D.	Locally Pump	v close V2338, 1A Charging Pump Disch to Charging Disch Hdr Isol.	<u> </u>
E.	Open <u>o</u>	one of the following valves:	
-	HCV-3 HCV-3 HCV-3 HCV-3	617, AUX HPSI Hdr to Loop 1A2 valve. 627, AUX HPSI Hdr to Loop 1A1 valve. 637, AUX HPSI Hdr to Loop 1B1 valve. 647, AUX HPSI Hdr to Loop 1B2 valve.	
F.	Localiy Hdr Isc	open.V2340, Charging Pump Disch Hdr to Aux HPSI ol, located in 1A Charging Pump Room.	
G.	Instali pump a	the following temporary jumpers to prevent charging auto start on low pressurizer level:	
)ei	RTGB	103, Terminal Board HH, T58 to T59	. <u></u>
	RTGB	103, Terminal Board HH, T59 to T60	<u> </u>
٠			

a

٠

۲

•

P

,

×.

٠ .

,

*

•

њ •

•

. .

. . Ŧ

2

• ٣ ¢ + ,

.*

•

REVISION	NO		PAGE:
3	31	CHARGING AND LETDOWN	
PROCEDUI	RE NO.: 10030	OFF-NORMAL OPERATING PROCEDURE ST. LUCIE UNIT 1	16 of 18
	. <u></u>	APPENDIX B ALTERNATE CHARGING FLOW PATH TO RCS THROUGH AUXILIARY HPSI HEADER (Page 6 of 8)	· ·
3. (co	ontinued	) .	INITIAL
H.	Ensure to 225	e RCS pressure is being maintained less than or equal 0 psia.	
•	725 ga heade during RCS p pump be sto	allons of highly borated water may be contained in the A r line being used. RCS temperature must be closely mo this evolution. pressure must NOT exceed 2250 psia at any time a char is discharging into the HPSI header. The charging pump pped is pressure exceeds 2250 psia.	HPSI initored ging must
I.	Start ti	ne 1A charging pump.	
J.	Return position	1A charging pump control switch to the AUTO	· ·
<u>lf</u> P	chargin ump Dis	<u>CAUTION</u> g flow to the RCS an NOT be verified, <u>Then</u> V3417, 1A/ ch Hdr Relief, may have lifted.	IC HPSI
K.	Verify f increas FI-333	low to the RCS by observing pressurizer level se and applicable HPSI flow indicator FI-3311, FI-3321, 1 or FI-3341.	, 
v	`	•	

R

REVISION N	10.:	PROCEDURE TITLE:	PAGE:
3	1	CHARGING AND LETDOWN	, , ,, ,
PROCEDUR	E NO.:	OFF-NORMAL OPERATING PROCEDURE	17 of 1
1-021	0030	APPENDIX B <u>ALTERNATE CHARGING FLOW PATH TO RCS</u> <u>THROUGH AUXILIARY HPSI HEADER</u> (Page 7 of 8)	
3. (co	ntinued	)	<u>INITIAL</u>
L.	<u>If</u> V34 <u>Then</u>	17, 1A/1C HPSI Pump Disch Hdr Relief, has lifted, perform the following:	
V: 22	3417 wi 212 psiç	<u>NOTE</u> Ill not reseat until HPSI header pressure lowers to approxi J.	mately
	1. S	top the charging pump.	
	2. <u>W</u> lif	<u>/hen</u> V3417 has reseated, <u>Then</u> determine the cause for it t.	S
	3. <u>If</u> <u>T</u> I	it has been determined that V3417 is NOT malfunctioning nen restart the charging pump.	<b>,</b> ,
	4. <u>İf</u> <u>TI</u>	it has been determined that V3417 is malfunctioning, <u>nen</u> restore systems' alignment to normal per Step O.	
М.	Cycle Pressi	the selected charging pump as necessary to maintain urizer level between 55% and 67%.	. <u></u>
N.	Recor Cycles review	d all charging pump cycles per AP 0010134, "Component s and Transients," and forward to Technical Staff for	
		, ,	
		т	
			ŧ

۴.,

••

P

•

REVISION NO .:		PROCEDURE TITLE:	PAGE:
•31		CHARGING AND LETDOWN	19 of 19
PROCEDURE NO.: 1-0210030		OFF-NORMAL OPERATING PROCEDURE ST. LUCIE UNIT 1	
		APPENDIX B ALTERNATE CHARGING FLOW PATH TO RCS THROUGH AUXILIARY HPSI HEADER (Page 8 of 8)	
З. (сс	ontinue	٠ (۲	INITIAL
Ο.	<u>Wher</u> head	<u>ı</u> alternate charging to the RCS through the Auxiliary HPS er is no longer desired, <u>Then</u> perform the following:	<b>;</b> ]
	1. E	insure the charging pumps are off.	
	2. L F	ocally close V2340, Charging Pump Disch Hdr to Aux IPSI Hdr Isol, located in 1A Charging Pump Room.	/ I.V.
	3. C	lose or ensure closed the following valves:	
·	ן ד ר	ICV-3617, AUX HPSI Hdr to Loop 1A2 valve. ICV-3627, AUX HPSI Hdr to Loop 1A1 valve. ICV-3637, AUX HPSI Hdr to Loop 1B1 valve. ICV-3647, AUX HPSI Hdr to Loop 1B2 valve.	/ I.V.
	4. L P	ocally lock open V2429, Charging Pump Disch at 'enetr #27 Isol.	/ I.V.
	5. L	ock open V3656, HPSI Pump 1A Discharge.	/ I.V.
	6. F	lemove the following jumpers:	
	· A	. RTGB 103, Terminal Board HH, T58 to T59	/ I.V.
	B	RTGB 103, Terminal Board HH, T59 to T60	/
Ρ.	Notify testin	Technical Staff to perform required check valve leak g when this evolution is complete.	·. v .
•		<b>x</b>	

,**"** 

•

.

°.-

3

## ENCLOSURE 4

## NRC RESOLUTION OF FACILITY RECOMMENDATIONS

<u>Question 66</u>: *Recommendation accepted*. The Unit 2 ASI falls directly on the "Acceptable Operation" boundary of the Axial Shape Index curve (Figure 2.2-2). Therefore, since both units ASIs are in the acceptable operation boundary. both Unit 2 and Unit 1 DNB Tech Spec requirements are met which was choice (d) on the question. The answer key was changed to reflect choice (d) as the only correct answer.

<u>Question 70</u>: *Comment accepted*. The NRC reviewed the simulator performance data submitted with the comments and concluded that AFAS actuated in slightly under 17 minutes from the LOOP/reactor trip. Since it is quite likely that a crew would still be in the SPTAs (Standard Post Trip Actions) and if AFAS did not auto actuate as required then anual initiation of AFAS 1 and 2 during SPTAs due to a LOOP form 20% power is a plausible answer. The answer key was changed to accept choice (b) as an additional correct answer.

<u>Question 73</u>: *Comment partially accepted*. The NRC disagreed with the licensee's reason for accepting the additional correct answer. Analysis revealed that the question was flawed and additional information was discovered during the research of the question.

The question attempted to measure a candidate's ability to understand under what conditions would one align the 1B charging pump to the Auxiliary HPSI header per EOP-99. Appendix T. The intended answer was that this is done to perform an emergency boration in EOP-15 success path 2 when the CVCS flowpath is unavailable (normal charging path not available). In the question the candidate was not told there was a problem with the charging header but merely that there was a LOOP/LOCA and the ANPS had directed the alignment of the 1B charging pump to the Auxiliary HPSI header per EOP-99. Appendix T. The candidate had to determine from the information given that there was some problem with the charging header because of the lineup that was directed. The only time EOP-99 appendix T would be used is when the charging header is not available.

The candidate was given a condition of a LOOP/LOCA on Unit 1 with only vital bus B available. The conditions given would not normally require entry into EOP-15, since a LOOP/LOCA is not considered a dual event, and EOP-3 would normally be the path taken. Also there was no information given that would indicate there was a problem with Reactivity Control. The question appears to be hinged on knowing where and why in the EOPs does one use EOP-99 appendix T

. 

. • • •

· · ·

• • •

Ŧ

•

. .



()

and not on the stated initial conditions. If a candidate recalled that this procedure is used as an alternate emergency boration flowpath in EOP-15 reactivity control choice (c) would be the correct answer. Additionally, emergency boration is a conservative action that usually correct for most emergency situations. With a LOCA in progress the charging pumps automatically align for emergency boration upon receipt of a SIAS signal during a LOCA.

If a candidate used the information in the stem of the question and determined that he did not have a dual event and was in the LOCA procedure with normal charging not available, the "RCS makeup" choice would be correct. EOP-3 LOCA procedure step 6.b requires maximum safety injection flow be established to include "All available charging pumps." If the charging header was unavailable another charging flowpath would be required to ensure all charging pumps were operating. EOP-99 Appendix T is entitled "Alternate Charging Flow Path To RCS through Aux HPSI Header". This procedure is used according to step 1 if. "Charging flow is lost due to a rupture or component failure downstream of V2429. charging pump discharge isolation valve." and normal charging is unavailable. Since implementation of Appendix T would meet the intent of EOP-3 step 6.B with the charging header unavailable, choice (b) is an additional correct answer.

<u>Question 95</u>: Comment accepted. The comment refers to the following statement contained in choice (c): "A Temporary Change that is implemented for 14 days and to be reviewed by the FRG tomorrow." Though not the intended interpretation, the NRC agrees that choice (c) could be interpreted to mean that the temporary change was just issued to last only 14 days and to be reviewed by the FRG on the second day vice had been issued for 14 days already and would be reviewed by the FRG on the 15th day. Since the former interpretation meets the requirements of ADM-11.03. "Temporary Change to Procedures" step 6.2.4, it is an additional correct answer. The answer key was changed to accept choice (c) as an additional correct answer.







ENCLOSURE 5

> • •

•

· ·







JUL-22-1998 14:19

USNRC ST LUCIE



Florida Power & Light Company, 6501 South Dcean Drive, Jensen Beach, FL 34957

L-98-199 10 CFR 55.5

Regional Administrator, Region II U. S. Nuclear Regulatory Commission Attn: Mr. Thomas A. Peebles Chief, Operator Licensing and Human Performance Branch Atlanta, GA 30303

Re: St. Lucie Units 1 and 2 Docket Nos. 50-335 and 50-389 Damaged Exam Package Received by NRC.

On June 2, 1998, Florida Power & Light Company (FPL) was notified by the NRC that an exam envelope was damaged when delivered. The envelope was shipped via Federal Express from St. Lucie Plant to the NRC Region II Office in Atlanta, Georgia on June 1, 1998. The envelope contained portions of reactor operator and senior reactor operator examinations written by FPL and sent to NRC Region II for review and approval. The envelope was not sent in a standard Federal Express box or envelope. It was sent in a regular brown paper envelope. FPL counsel requested that corporate security assist in an investigation consisting of interviews of persons who may have handled the envelope to determine whether the envelope left the FPL site intact.

On June 3, 1998, FPL area security manager met with FPL counsel at St. Lucie Nuclear Training Facility. They conducted interviews of FPL employees who handled or saw the envelope in question on the date it was shipped from St. Lucie Plant. Also on June 3, 1998, the FPL area security manager interviewed the Federal Express employee who received the envelope from the FPL St. Lucie Plant shipping and receiving department and transported the package to the Federal Express facilities.

Based on the evidence obtained and the interviews conducted, FPL concluded that the envelope left the St. Lucie Plant intact and undamaged. Should you have any questions, please contact us.

Very truly yours,

J. A. Stall

Vice President St. Lucie Plant

JAS/GRM

ENCLOSURE 6

