

C&D TECHNOLOGIES, INC.
Power Solutions

1400 Union Meeting Road
Blue Bell, PA 19422
Phone: (215) 619-2700
Fax: (215) 619-7887

October 23, 2017


VIA ELECTRONIC TRANSMISSION
Nuclear Regulatory Commission
Operations Center
hoo.hoc@nrc.gov

Subject: Retraction of Interim Report – Inability to Complete 10CFR Part 21 Evaluation Regarding Cracking in KCR-13 Standby Battery Jars

On May 29, 2015 C&D Technologies submitted an interim Part 21 report (ML15155A575, Part 21 log 2015-34-00) regarding jar cracks discovered in a KCR-13 battery at Indian Point Nuclear Energy Center. This report was issued as the analysis of this battery jar had not yet been completed. The analysis was subsequently completed, and it was determined that the jar cracking was not related to the design or production of this battery, and thus is not a defect reportable under Part 21. Indian Point Nuclear Energy Center was notified of the findings of the report; however, no final Part 21 report was issued by C&D to the NRC, leaving the interim Part 21 report open.

Based on the results of the analysis the Interim Report (NRC Log No. 2015-34-06) dated May 29, 2015 is retracted. If you have any questions or wish to discuss this matter, please contact me.

Sincerely,



Robert Malley
VP Quality and Process Engineering
rmalley@cdtechno.com
(215) 619-7830

Cc: A. Lauzon
D. Anderson
R. Malley
S. DiMauro
J. Anderson
D. Heimer