

CORE OPERATING LIMITS REPORT

PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

UNIT 2 CYCLE 7


Revision 1

9607080274 960628
PDR ADOCK 05000528
P PDR

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

Table of Contents

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Cover Page	1.0 2n	1
Table of Contents	1	2
Affected Technical Specifications	1	4
CORE Operating Limits		
3.1.1.1 Shutdown Margin - Reactor Trip Breakers Open		
3.1.1.2 Shutdown Margin - Reactor Trip Breakers Closed		
3.1.1.3 Moderator Temperature Coefficient	1	5
3.1.2.7 Boron Dilution Alarms		
3.1.3.1 Movable Control Assemblies - CEA Position		
3.1.3.6 Regulating CEA Insertion Limits		
3.1.3.7 Part Length CEA Insertion Limits		
3.2.1 Linear Heat Rate		
3.2.3 Azimuthal Power Tilt - Tq	1	6
3.2.4 DNBR Margin		
3.2.7 Axial Shape Index		
3.9.1 Boron Concentration (Mode 6)		
List of Figures	1	7
Figure 3.1.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	1	7a
Figure 3.1.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	0	8
Figure 3.1.1.3-1 MTC Acceptable Operation, Modes 1 and 2	0	9
Figure 3.1.3.1-1 Core Power Limit After CEA Deviation	0	10
Figure 3.1.3.6-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	0	11
Figure 3.1.3.6-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	0	12
Figure 3.1.3.7-1 Part Length CEA Insertion Limits Versus Thermal Power	0	13



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT
Table of Contents (Continued)

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	0	14
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEAC's Inoperable	0	15
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEAC's Operable)	0	16
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEAC's Inoperable)	0	17
List of Tables	0	18
Table 3.1.2.7-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	0	19
Table 3.1.2.7-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	0	20
Table 3.1.2.7-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	0	21
Table 3.1.2.7-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	0	22
Table 3.1.2.7-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	0	23



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

This Report has been prepared in accordance with the requirements of Technical Specification 6.9.1. The Core Operating Limits have been developed using the NRC approved methodologies specified in Section 6.9.1.10 of the Palo Verde Unit 2 Technical Specifications.

AFFECTED PVNGS TECHNICAL SPECIFICATIONS

- 3.1.1.1 Shutdown Margin - Reactor Trip Breakers Open
- 3.1.1.2 Shutdown Margin - Reactor Trip Breakers Closed
- 3.1.1.3 Moderator Temperature Coefficient
- 3.1.2.7 Boron Dilution Alarms
- 3.1.3.1 Movable Control Assemblies - CEA Position
- 3.1.3.6 Regulating CEA Insertion Limits
- 3.1.3.7 Part Length CEA Insertion Limits
- 3.2.1 Linear Heat Rate
- 3.2.3 Azimuthal Power Tilt - T_q
- 3.2.4 DNBR Margin
- 3.2.7 Axial Shape Index
- 3.9.1 Boron Concentration (Mode 6)

CORE OPERATING LIMITS

The cycle-specific operating limits for the specifications listed are presented below.

3.1.1.1 - Shutdown Margin - Reactor Trip Breakers Open

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.1.1-1.

3.1.1.2 - Shutdown Margin - Reactor Trip Breakers Closed

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.1.2-1.



x

2



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS - CONTINUED3.1.1.3 - Moderator Temperature Coefficient

The moderator temperature coefficient (MTC) shall be within the area of Acceptable Operation shown in Figure 3.1.1.3-1.

3.1.2.7 - Boron Dilution Alarms

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.1.2.7-1 through 3.1.2.7-5.

3.1.3.1 - Movable Control Assemblies - CEA Position

With one or more full-length or part-length CEAs misaligned from any other CEAs in its group by more than 6.6 inches, the minimum required MODES 1 and 2 core power reduction is specified in Figure 3.1.3.1-1.

3.1.3.6 - Regulating CEA Insertion Limits

One or more CEAC's OPERABLE: With COLSS IN SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits shown in Figure 3.1.3.6-1; with COLSS OUT OF SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits shown in Figure 3.1.3.6-2.

3.1.3.7 - Part Length CEA Insertion Limits

One or more CEAC's OPERABLE: The part length CEA groups shall be limited to the insertion limits shown in Figure 3.1.3.7-1.

3.2.1 - Linear Heat Rate

The linear heat rate limit of 13.5 kW/ft shall be maintained.



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS - CONTINUED3.2.3 - Azimuthal Power Tilt - T_q

The AZIMUTHAL POWER TILT (T_q) shall be less than or equal to the limit in Figure 3.2.3-1 with COLSS IN SERVICE.

3.2.4 - DNBR Margin

COLSS IN SERVICE and Both CEAC's INOPERABLE - Maintaining COLSS calculated core power less than or equal to COLSS calculated core power operation limit based on DNBR decreased by the allowance shown in Figure 3.2.4-1.

COLSS OUT OF SERVICE and Either One or Both CEAC's are OPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-2 using any operable CPC channel.

COLSS OUT OF SERVICE and CEAC's INOPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-3 using any operable CPC channel.

3.2.7 - Axial Shape Index


The core average AXIAL SHAPE INDEX (ASI) shall be maintained within the following limits:

COLSS OPERABLE
- $-0.188 \leq ASI \leq 0.169$

COLSS OUT OF SERVICE (CPC)
- $-0.10 \leq ASI \leq 0.10$

3.9.1 - Boron Concentration (Mode 6)

The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained at a uniform concentration ≥ 2500 ppm.




PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

LIST OF FIGURES

- 3.1.1.1-1. Shutdown Margin Versus Cold Leg Temperature, Reactor Trip Breakers Open
- 3.1.1.2-1. Shutdown Margin Versus Cold Leg Temperature, Reactor Trip Breakers Closed
- 3.1.1.3-1. MTC Acceptable Operation, Modes 1 and 2.
- 3.1.3.1-1. Core Power Limit After CEA Deviation.
- 3.1.3.6-1. CEA Insertion Limits Versus Thermal Power (COLSS In Service).
- 3.1.3.6-2. CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)
- 3.1.3.7-1. Part Length CEA Insertion Limit Versus Thermal Power.
- 3.2.3-1. Azimuthal Power Tilt Limit Versus Thermal Power (COLSS In Service).
- 3.2.4-1. COLSS DNBR Power Operating Limit Allowance for Both CEACs Inoperable.
- 3.2.4-2. DNBR Margin Operating Limit Based on Core Protection Calculators (COLSS Out of Service, CEACs Operable)
- 3.2.4-3. DNBR Margin Operating Limit Based on Core Protection Calculators (COLSS Out of Service, CEACs Inoperable)

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT


FIGURE 3.1.1.1-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS OPEN






PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

FIGURE 3.1.1.2-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS CLOSED



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT
FIGURE 3.1.1.3-1
MTC ACCEPTABLE OPERATION, MODES 1 AND 2


Revision 0



MODERATOR TEMPERATURE COEFFICIENT ($\times 10^{-4} \Delta \rho / F$)



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

FIGURE 3.1.3.1-1
CORE POWER LIMIT AFTER CEA DEVIATION *

* WHEN CORE POWER IS REDUCED TO 55% OF RATED THERMAL POWER PER THIS LIMIT CURVE, FURTHER REDUCTION IS NOT REQUIRED




PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

FIGURE 3.1.3.6-1

CEA INSERTION LIMITS VERSUS THERMAL POWER
(COLSS IN SERVICE)

Revision 0



FRACTION OF RATED THERMAL POWER




PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

FIGURE 3.1.3.6-2

CEA INSERTION LIMITS VERSUS THERMAL POWER
(COLSS OUT OF SERVICE)

Revision 0



FRACTION OF RATED THERMAL POWER


Page 12 of 23

CEA POSITION (INCHES WITHDRAWN)

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT


FIGURE 3.1.3.7-1

PART LENGTH CEA INSERTION LIMITS VERSUS THERMAL POWER




PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

FIGURE 3.2.3-1
AZIMUTHAL POWER TILT VERSUS THERMAL POWER
(COLSS IN SERVICE)



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT
FIGURE 3.2.4-1
COLSS DNBR OPERATING LIMIT
ALLOWANCE FOR BOTH CEAC'S INOPERABLE




COLSS DNBR POWER OPERATING LIMIT REDUCTION
(% OF RATED THERMAL POWER)




PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

FIGURE 3.2.4-2
 DNBR MARGIN OPERATING LIMIT BASED ON
 THE CORE PROTECTION CALCULATORS
 (COLSS OUT OF SERVICE, CEAC'S OPERABLE)



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

FIGURE 3.2.4-3
DNBR MARGIN OPERATING LIMIT BASED ON
THE CORE PROTECTION CALCULATORS
(COLSS OUT OF SERVICE, CEAC's INOPERABLE)



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

LIST OF TABLES

- 3.1.2.7-1. Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{\text{eff}} > 0.98$.
- 3.1.2.7-2. Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{\text{eff}} > 0.97$.
- 3.1.2.7-3. Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{\text{eff}} > 0.96$.
- 3.1.2.7-4. Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{\text{eff}} > 0.95$.
- 3.1.2.7-5. Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{\text{eff}} \leq 0.95$.

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

TABLE 3.1.2.7-1

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{eff} > 0.98$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	1 hour	ONA	ONA
4 not on SCS	12 hours	1 hour	ONA	ONA
5 not on SCS	8 hours	1 hour	ONA	ONA
4 & 5 on SCS	ONA	ONA	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

TABLE 3.1.2.7-2

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.98 \geq K_{\text{eff}} > 0.97$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	2 hours	0.5 hours	ONA
4 not on SCS	12 hours	2.5 hours	1 hour	0.5 hours
5 not on SCS	8 hours	2.5 hours	1 hour	0.5 hours
4 & 5 on SCS	8 hours	0.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

TABLE 3.1.2.7-3

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.97 \geq K_{\text{eff}} > 0.96$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	3.5 hours	1.5 hours	0.5 hours
4 not on SCS	12 hours	3.5 hours	1.5 hours	1 hour
5 not on SCS	8 hours	3.5 hours	1.5 hours	1 hour
4 & 5 on SCS	8 hours	1 hour	0.5 hours	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

TABLE 3.1.2.7-4

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.96 \geq K_{eff} > 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	5 hours	2 hours	1 hour
4 not on SCS	12 hours	5 hours	2 hours	1 hour
5 not on SCS	8 hours	5 hours	2 hours	1 hour
4 & 5 on SCS	8 hours	2 hours	0.5 hours	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT

TABLE 3.1.2.7-5

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{eff} \leq 0.95$

OPERATIONAL MODE.	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	6 hours	2.5 hours	1.5 hours
4 not on SCS	12 hours	6 hours	3 hours	1.5 hours
5 not on SCS	8 hours	6 hours	3 hours	1.5 hours
4 & 5 on SCS	8 hours	2 hours	1 hour	0.5 hours
6 (≥ 4000 ppm)	24 hours	8 hours	4 hours	2 hours
6 (< 4000 ppm)	24 hours	2 hours	0.5 hours	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation not allowed

