

Revision 2 Pages

Unit 2 COLR

9708050254 970730
PDR ADOCK 05000528
P PDR

CORE OPERATING LIMITS REPORT

PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

UNIT 2 CYCLE 7

Revision 2




Small, faint, illegible marks or characters in the top right corner.

PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT


Table of Contents

<u>Description</u>	<u>Revision #</u>	<u>Page</u>	
Cover Page	2	1	2
Table of Contents	2	2	
Affected Technical Specifications	1	4	
CORE Operating Limits			
3.1.1.1 Shutdown Margin - Reactor Trip Breakers Open			
3.1.1.2 Shutdown Margin - Reactor Trip Breakers Closed			
3.1.1.3 Moderator Temperature Coefficient	2	5	2
3.1.2.7 Boron Dilution Alarms			
3.1.3.1 Movable Control Assemblies - CEA Position			
3.1.3.6 Regulating CEA Insertion Limits			
3.1.3.7 Part Length CEA Insertion Limits			
3.2.1 Linear Heat Rate			
3.2.3 Azimuthal Power Tilt - Tq	1	6	
3.2.4 DNBR Margin			
3.2.7 Axial Shape Index	1	6	
3.9.1 Boron Concentration (Mode 6)			
List of Figures	1	7	
Figure 3.1.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	1	7a	
Figure 3.1.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	0	8	
Figure 3.1.1.3-1 MTC Acceptable Operation, Modes 1 and 2	0	9	
Figure 3.1.3.1-1 Core Power Limit After CEA Deviation	0	10	
Figure 3.1.3.6-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	0	11	
Figure 3.1.3.6-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	0	12	
Figure 3.1.3.7-1 Part Length CEA Insertion Limits Versus Thermal Power	0	13	



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT
Table of Contents (Continued)

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	0	14
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEAC's Inoperable	0	15
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEAC's Operable)	0	16
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEAC's Inoperable)	0	17
List of Tables	0	18
Table 3.1.2.7-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	0	19
Table 3.1.2.7-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	0	20
Table 3.1.2.7-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	0	21
Table 3.1.2.7-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	0	22
Table 3.1.2.7-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	0	23



PVNGS UNIT 2 CYCLE 7 CORE OPERATING LIMITS REPORT
CORE OPERATING LIMITS - CONTINUED

3.1.1.3 - Moderator Temperature Coefficient

The moderator temperature coefficient (MTC) shall be within the area of Acceptable Operation shown in Figure 3.1.1.3-1.

3.1.2.7 - Boron Dilution Alarms

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.1.2.7-1 through 3.1.2.7-5.

3.1.3.1 - Movable Control Assemblies - CEA Position

With one or more full-length or part-length CEAs misaligned from any other CEAs in its group by more than 6.6 inches, the minimum required MODES 1 and 2 core power reduction is specified in Figure 3.1.3.1-1.

3.1.3.6 - Regulating CEA Insertion Limits

One or more CEAC's OPERABLE: With COLSS IN SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits shown in Figure 3.1.3.6-1; with COLSS OUT OF SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits shown in Figure 3.1.3.6-2.

3.1.3.7 - Part Length CEA Insertion Limits

One or more CEAC's OPERABLE: The part length CEA groups shall be limited to the insertion limits shown in Figure 3.1.3.7-1.

3.2.1 - Linear Heat Rate

The linear heat rate limit of 13.3 kW/ft shall be maintained.