

Revision 3 Pages

Unit 3 COLR

9708050257 970730
PDR ADUCK 05000528
P PDR



•
•
•

•

CORE OPERATING LIMITS REPORT

PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

Unit 3

Revision 3

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

Table of Contents

<u>Description</u>	<u>Revision #</u>	<u>Page</u>	
Cover Page	3	1	
Table of Contents	3	2	3
Affected Technical Specifications	1	4	
CORE Operating Limits			
3.1.1.1 Shutdown Margin - Reactor Trip Breakers Open			
3.1.1.2 Shutdown Margin - Reactor Trip Breakers Closed			
3.1.1.3 Moderator Temperature Coefficient	3	5	
3.1.2.7 Boron Dilution Alarms			
3.1.3.1 Movable Control Assemblies - CEA Position			3
3.1.3.6 Regulating CEA Insertion Limits			
3.1.3.7 Part Length CEA Insertion Limits			
3.2.1 Linear Heat Rate			
3.2.3 Azimuthal Power Tilt - Tq	1	6	
3.2.4 DNBR Margin			
3.2.7 Axial Shape Index			
3.9.1 Boron Concentration (Mode 6)			
List of Figures	1	7	
Figure 3.1.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	1	8	
Figure 3.1.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	1	9	
Figure 3.1.1.3-1 MTC Acceptable Operation, Modes 1 and 2	1	10	
Figure 3.1.3.1-1 Core Power Limit After CEA Deviation	1	11	
Figure 3.1.3.6-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	1	12	
Figure 3.1.3.6-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	1	13	
Figure 3.1.3.7-1 Part Length CEA Insertion Limits Versus Thermal Power	1	14	

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT
Table of Contents (Continued)

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	1	15
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEACs Inoperable	1	16
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Operable)	1	17
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Inoperable)	1	18
List of Tables	1	19
Table 3.1.2.7-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	1	20
Table 3.1.2.7-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	1	21
Table 3.1.2.7-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	1	22
Table 3.1.2.7-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	1	23
Table 3.1.2.7-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	1	24



PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS - CONTINUED3.1.1.3 - Moderator Temperature Coefficient

The moderator temperature coefficient (MTC) shall be within the area of Acceptable Operation shown in Figure 3.1.1.3-1.

3.1.2.7 - Boron Dilution Alarms

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.1.2.7-1 through 3.1.2.7-5.

3.1.3.1 - Movable Control Assemblies - CEA Position

With one or more full-length or part-length CEAs misaligned from any other CEAs in its group by more than 6.6 inches, the minimum required MODES 1 and 2 core power reduction is specified in Figure 3.1.3.1-1.

3.1.3.6 - Regulating CEA Insertion Limits

One or more CEACs OPERABLE: With COLSS IN SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits shown in Figure 3.1.3.6-1; with COLSS OUT OF SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits shown in Figure 3.1.3.6-2.

3.1.3.7 - Part Length CEA Insertion Limits

One or more CEACs OPERABLE: The part length CEA groups shall be limited to the insertion limits shown in Figure 3.1.3.7-1.

3.2.1 - Linear Heat Rate

The linear heat rate limit of 12.9 kW/ft shall be maintained.

