

REGULATORY INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 050-316

DOC DATE: 781003

RECIPIENT: Keppler, J.G. NOIR3

ACCESSION NBR: 7810110188

ORIGINATOR: Shaller, D.V.

COPIES RECEIVED:

LTR 3 ENCL 3

SUBJECT:

SIZE: 1 + 2

Forwards LER#78-067/03L-0 & LER#78-068/03L-0: Condensate storage level fell below Tech Spec limit of 175,000 gallons. Fall in level due to storage tanks being crosstied to check leakage in tank. Level returned to normal after no leakage identified.

Rounding off of T(Z) setpoint results in FZ calculations being nonconservative in top of core.

DISTRIBUTION CODE: A002

DISTRIBUTION TITLE:

INCIDENT REPORTS

NAME	ENCL?
BR CHIEF	W/4 ENCL
REG FILE	W/ENCL
MRC FOR	W/ENCL
I & E	W/2 ENCL
MIPC	W/3 ENCL
I & C SYSTEMS BR	W/ENCL
EMERGENCY PLAN BR	W/ENCL
NOVAK/CHECK	W/ENCL
EEB	W/ENCL
AD FOR ENG	W/ENCL
PLANT SYSTEMS BR	W/ENCL
HANAUER	W/ENCL
AD FOR PLANT SYSTEMS	W/ENCL
AD FOR SYS & PROJ	W/ENCL
REACTOR SAFETY BR	W/ENCL
ENGINEERING BR	W/ENCL
VOLLMER/BUNCH	W/ENCL
KREGER/J. COLLINS	W/ENCL
POWER SYS BR	W/ENCL
K SEYFRIT/IE	W/ENCL
LPDR.	W/ENCL
NSIC	W/ENCL
ACRS	W/16 ENCL

FOR ACTION

D. Eisenhut

ORB#1 BC

M. Mlynczak

ORB#1 LA

TOTAL NUMBER OF COPIES REQUIRED:

LTR


44

ENCL

44

NOTES: 1. Send 3 copies of all material to I & E.

A0 4
60



INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

October 3, 1978

REGULATORY DOCKET FILE COPY.

Mr. J.G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-74
Docket No. 50-316

Dear Mr. Keppler:

Pursuant to the requirements of the Appendix A Technical Specifications
the following reports are submitted:

RO 78-067/03L-0
RO 78-068/03L-0.

Sincerely,


for D.V. Shaller
Plant Manager

REGULATORY DOCKET FILE COPY

/bab

cc: J.E. Dolan
R.W. Jurgensen
R.F. Kroeger
R. Kilburn
R.J. Vollen BPI
K.R. Baker RO:III
R.C. Callen MPSC
P.W. Steketee, Esq.
R. Walsh, Esq.
G. Charnoff, Esq.
J.M. Hennigan
G. Olson
PNSRC
J.F. Stietzel
R.S. Keith
T.P. Beilman/J.L. Rischling
Dir., IE (30 copies)
Dir., MIPC (3 copies)

7810110188

