

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	M	I	D	C	C	2	0	0	0	0	0	0	0	0	0	0	0	0	0	4	1	1	1	1	5
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
LICENSEE CODE						LICENSE NUMBER						LICENSE TYPE						57 CAT 58							

01	L	0	5	0	0	0	3	1	6	7	0	8	12	0	7	18	8	1	0	1	18	7	18	9	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
CON'T		REPORT SOURCE		DOCKET NUMBER						EVENT DATE				REPORT DATE											

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | WHILE TEST CLOSING TURBINE VALVES AT 99% POWER, STEAM FLOW WAS REDUCED CAUSING

03 | REACTOR COOLANT TEMP. TO INCREASE TO 577°F AND PRESSURE TO DECREASE TO 2185 PSIA

04 | IN VIOLATION OF TECH. SPEC. 3.2.5. MAXIMUM TIME LIMIT EXCEEDED WAS 8 MINUTES.

05 | ACTION REQUIRES RETURNING TO WITHIN LIMITS WITHIN TWO HOURS. NO PROBABLE

06 | CONSEQUENCES.

07 |

08 |

09	C	A	A	X	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE		LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER											
G		G		Z		Z		0000		N		N		Z		Z999											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | THE CAUSE OF THIS EVENT WAS TESTING VALVE AT TOO HIGH A POWER LEVEL. FUTURE

11 | TURBINE VALVE TESTS WILL BE AT A REDUCED POWER LEVEL TO ALLOW FOR TRANSIENTS.

12 | TECH. SPEC. 3.2.5 ALLOWS FOR A POWER INCREASE TRANSIENT. WE INTEND TO REQUEST

13 | A TECH. SPEC. REVISION TO ALSO ALLOW FOR A POWER DECREASE TRANSIENT.

14 |

15	E	0	9	9	NA	A	OPERATOR OBSERVATION
7	8	9	10	11	12	13	14
FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY
ACTIVITY CONTENT		RELEASED OF RELEASE			AMOUNT OF ACTIVITY		LOCATION OF RELEASE
Z		Z			NA		NA

17	0	0	0	Z	NA
7	8	9	10	11	12
PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION	

18	0	0	0	NA
7	8	9	10	11
PERSONNEL INJURIES NUMBER		DESCRIPTION		

19	Z	NA
7	8	9
LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION

20	N	NA
7	8	9
ISSUED DESCRIPTION		PUBLCITY

7810230183

NAME OF PREPARER

R.S. Lease

PHONE: (616) 465-5901

NRC USE ONLY

