

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (2) (3) (4) (5) (6)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MIDCC1 | 00000000000000000 | 411111 | |

CONT REPORT SOURCE L | 050003115 | 102878 | 111578

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | DURING NORMAL OPERATION THE HIGH CONTAINMENT RADIO GAS AND HUMIDITY ALARMS WERE
03 | RECEIVED INDICATING A POSSIBLE RCS LEAK. A LEAK RATE TEST SHOWED RCS LEAKAGE TO
04 | BE 1.4 GPM. SOURCE OF LEAKAGE COULD NOT BE IDENTIFIED WITHIN THE SIX HOUR LIMIT
05 | SPECIFIED IN T.S. 3.4.6.2 AND THE UNIT WAS PLACED IN HOT STANDBY.
06 |
07 |
08 |

SYSTEM CODE CA | CAUSE CODE E | CAUSE SUBCODE X | COMPONENT CODE VALVEX | COMP. SUBCODE F | VALVE SUBCODE P

LER/RO REPORT NUMBER (17) | EVENT YEAR 78 | SEQUENTIAL REPORT NO. 060 | OCCURRENCE CODE 03 | REPORT TYPE L | REVISION NO. 0

ACTION TAKEN X | FUTURE ACTION B | EFFECT ON PLANT A | SHUTDOWN METHOD A | HOURS 0015 | ATTACHMENT SUBMITTED N | NPRD-4 FORM SUB. N | PRIME COMP. SUPPLIER N | COMPONENT MANUFACTURER C631

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | THE RCS LEAK WAS DISCOVERED TO BE EXCESSIVE PACKING LEAKAGE ON A 3/4 VALVE IN PZR
11 | SAFETY VALVE LOOP SEAL DRAIN LINE. VALVE WAS FOUND TO BE 1/8 TURN OPEN. VALVE
12 | WAS CLOSED AND LEAKAGE WAS STOPPED. VALVE WILL BE REPACED DURING FUTURE COLD
13 | SHUTDOWN.
14 |

FACILITY STATUS E | % POWER 100 | OTHER STATUS NA | METHOD OF DISCOVERY A | DISCOVERY DESCRIPTION OPERATOR OBSERVATION

ACTIVITY CONTENT RELEASED OF RELEASE Z | AMOUNT OF ACTIVITY NA | LOCATION OF RELEASE NA

PERSONNEL EXPOSURES NUMBER 000 | TYPE Z | DESCRIPTION NA

PERSONNEL INJURIES NUMBER 000 | DESCRIPTION NA

LOSS OF OR DAMAGE TO FACILITY TYPE 7 | DESCRIPTION NA

PUBLICITY ISSUED N | DESCRIPTION NA

NAME OF PREPARER: H. M. Chadwell | PHONE: (616) 465-5901

NRC USE ONLY

PO 917-926

