

LICENSEE EVENT REPORT

CONTRACT BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C L 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 1 4 5
7 8 9 14 15 25 26 30 37 48 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 1 2 1 4 7 8 8 0 1 0 9 7 9 9
7 8 60 61 68 69 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 WHILE PERFORMING A ROUTINE SURVEILLANCE TEST IT WAS DISCOVERED THAT THE INDICATED
0 3 POSITION OF ROD H-8 WAS GREATER THAN THE ALLOWABLE TWELVE STEP LIMIT IMPOSED BY
0 4 T.S. 3.1.3.2. PREVIOUS OCCURRENCES INCLUDE 050-0315/76-13,44,54; 0315/77-27,28,33,
0 5 34; 0315/78-04,07,38,46; 050-0316/78-07, 08,22, 31, 41, 64 and 75.
0 6
0 7
0 8

0 9 SYSTEM CODE I D (11) CAUSE CODE E (12) CAUSE SUBCODE G (13) COMPONENT CODE I N S T R U (14) COMP. SUBCODE I (15) VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER EVENT YEAR 7 8 21 22 SHUTDOWN METHOD 23 SEQUENTIAL REPORT NO. 0 6 4 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
ACTION TAKEN E (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED N (23) NPRD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER W 1 2 0 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 THE VARIABLE SHUNT RESISTOR CONTAINED IN THE CONTROL BOARD INDICATOR FOR ROD H-8
1 1 WAS FOUND TO BE OUT OF ADJUSTMENT AND WAS CORRECTED TO ALLOW PROPER DISPLAY. NO
1 2 FURTHER ACTION IS PLANNED.
1 3
1 4

1 5 FACILITY STATUS E (28) % POWER 0 6 4 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION SURVEILLANCE TEST (32)
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT Z (33) Z (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION NA (39)
7 8 9 10 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION NA (41)
7 8 9 10 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43)
7 8 9 10 11 12 80

2 0 PUBLICITY ISSUED N (44) DESCRIPTION NA (45)
7 8 9 10 11 80

NAME OF PREPARER T. P. Beilman

PHONE: 616-465-5901

Dupe of 790115-0137

