

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	2	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5
7	8	9					14	15											25	26						30	57	CAT	58
		LICENSEE CODE						LICENSE NUMBER													LICENSE TYPE								

CON'T

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80																			
		L	6	0	5	0	0	0	3	1	6	7	0	1	1	1	7	9	8	0	1	3	1	7	9	9															

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | OPERATING AT 100% POWER THE QUADRANT POWER TILT RATIO ALARM PER TECH SPEC 4.2.4 WAS

0 3 | IN ERROR. THIS REQUIRES CALCULATION OF THE TILT RATIO EACH 12 HRS. THE FIRST 12 HOUR

0 4 | SURVEILLANCE WAS MISSED. REACTOR POWER WAS CONSTANT WITH EQUILIBRIUM XENON. NO

0 5 | PROBABLE CONSEQUENCES.

0 6 |

0 7 |

0 8 |

7 8 9 80

09		SYSTEM CODE ZZ		11	CAUSE CODE D		12	CAUSE SUBCODE .Z		13	COMPONENT CODE ZZZZZZZ						14	COMP. SUBCODE Z		15	VALVE SUBCODE Z		16												
7 8		9 10			11			12			13							19			20														
17		LER/RO REPORT NUMBER		EVENT YEAR 79		23		SEQUENTIAL REPORT NO. 001		26		OCCURRENCE CODE 03		29		REPORT TYPE 11		31		REVISION NO. 0		32													
ACTION TAKEN LG		18		FUTURE ACTION LG		19		EFFECT ON PLANT 7		20		SHUTDOWN METHOD 7		21		HOURS 00000		22		ATTACHMENT SUBMITTED N		23		NPRD-4 FORM SUB. N		24		PRIME COMP. SUPPLIER 7		25		COMPONENT MANUFACTURER 7999		26	
33		34		35		36		37		40		41		42		43		44		45		46		47		48		49		50					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE QUADRANT POWER TILT ALARM WAS OPERABLE BUT IN ERROR BECAUSE THE INSTRUMENTS FROM
1 1 WHICH THE ALARM CALCULATES WERE BEING CALIBRATED. MAXIMUM ERROR WOULD HAVE BEEN 0.003.
1 2 PROCEDURE HAS BEEN REVISED TO REQUIRE HAND CALCULATION WHILE THESE INSTRUMENTS ARE
1 3 BEING CALIBRATED.
1 4

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	(28)	1	0	0	(29)	A	(31)
ACTIVITY CONTENT RELEASED OF RELEASE		AMOUNT OF ACTIVITY		OPERATOR OBSERVATION					
1	6	7	(33)	7	(34)	NA		LOCATION OF RELEASE	
PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	(37)	7	(38)	NA	
PERSONNEL INJURIES NUMBER		DESCRIPTION							
1	8	0	0	0	(40)	NA			
LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION							
1	9	Z	(42)	NA		<i>Shipped 7902050122</i>			
PUBLICITY ISSUED		DESCRIPTION							
2	0	N	(44)	NA		NRC USE ONLY			

NAME OF PREPARER R. S. Lease

PHONE: (616) 465-5901

