REPLATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:7904270315 DOC.DATE: 79/04/23 NOTARIZED: NO FACIL:50-315 DONALD C. COOK NUCLEAR POWER PLANT, UNIT 1, INDIANA & 50-316 DONALD C. COOK NUCLEAR POWER PLANT, UNIT 2, INDIANA & AUTHOR AFFILIATION MALONEY, G.P. INDIANA & MICHIGAN POWER CO. RECIPIENT AFFILIATION DENTON, H.R. OFFICE OF NUCLEAR REACTOR REGULATION DOCKET # 05000315 05000316

SUBJECT: SUPPLEMENTS 790404 LTR TRANSMITTING AMEND 83 TO PSAR.CHECK ENCLOSED AS FEE ALTHOUGH UNDER PROTEST.ADDL INFO FORWARDED RE WESTINGHOUSE PARTS MADE OF TYPE 304 STAINLESS STEEL & USED FOR ANTI-ROTATION DEVICES.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR / ENCL O SIZE: 2 11 TITLE: GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LIC


\$4,400.00 NOTES: I WE - 3 CUS MATL. WICHECK RECIPIENT ID CODE/NAME COPIES LITE ENCL RECIPIENT ID CODE/NAME COPIES LTTR ENCL 05 BC ORB #1 ACTION: INTERNAL: REG FILE 02 NRC PDR 14 TA/EDO 16 AD SYS/PROJ 18 REAC SFTY BR 20 EEB L& Em CORE PERF BR 17 ENGR BR 19 PLANT SYS BR 21 EFLT TRT SYS 1 SS BRINKMAN EXTERNAL: 03 LPDR 23 ACRS 04 NSIC

¥6

TOTAL NUMBER OF COPIES REQUIRED: LTTR ENCL

APR 3 0 1979

4871 1



Indiana & Michigan Power Company

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

April 23, 1979 AEP:NRC:00190

Donald C. Cook Nuclear Plant Units 1 and 2 Dockets No. 50-315 and 50-316 Licenses No. DPR-58 and DPR-74 Part Length Control Rods

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Denton:

This letter supplements our letter dated April 4, 1979 (AEP:NRC:00117) which transmitted to you Amendment No. 83 to the Donald C. Cook Nuclear Plant Final Safety Analysis Report (FSAR). One of the changes described therein is the removal of part-length control rods from Unit 1 and the installation of permanent anti-rotation devices on the part length control rod drive mechanisms and the replacement of the temporary anti-rotation devices in Unit 2 with permanent ones identical to those in Unit 1. The latter change is planned to take place during the first Unit 2 refueling outage which is expected next fall. As stated elsewhere in the FSAR, thimble plugs are installed in those fuel assemblies not holding control rods, neutron source assemblies or burnable poison assemblies.

Although we continue to find ourselves in disagreement with the NRC staff that this change requires NRC review due to reasons discussed before, we are enclosing a check for \$4,400 as the fee specified in 10 CFR 170.22 for Class I and III amendments in order to comply with the staff request in this matter.

In confirmation of telephone discussions with the NRC staff we supply the following additional information provided to us by Westinghouse. The new parts supplied by Westinghouse for the permanent anti-rotation devices are made of Type 304 stainless steel. Each thimble plug is permanently attached to the baseplate by a nut which is locked to the threaded end of the plug by a small lock bar welded to the nut.

Hosi Weer

7904270315

Mr. Harold R. Denton, Director -2-AEP:NRC:00190 The corresponding Technical Specifications changes were also discussed with members of your staff. Very truly yours, GPM:em Vice President Sworn and subscribed to before me this 23d day of April, 1979 in New York County, New York

GREGORY M. GURICAN
Notary Public, State of Haw York
No. 31-4640401
Qualified in New York County
Commission Expires March 30, 19 AJ.

cc: R. C. Callen

G. Charnoff

P. W. Steketee

R. J. Vollen

R. Walsh

D. V. Shaller-Bridgman R. W. Jurgensen

