

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 2 200000000000000000 3411111 4
 7 8 9 14 15 25 26 30 57 58 80

CONT

01 L 05000316 7062979 8072779 9
 7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING UNIT STARTUP FROM COLD SHUTDOWN AND WHILE IN MODE 4, THE EAST ESF VENTILA-
03 TION SYSTEM FIRE PROTECTION SPRAY FOR THE CHARCOAL FILTER OPERATED AT 2230. AFTER
04 INVESTIGATING THE ALARM AND FINDING NO FIRE, THE FIRE PROTECTION SPRAY WAS MANUALLY
05 ISOLATED AND A FIRE WATCH WAS POSTED. THE EAST ESF VENTILATION SYSTEM WAS RETURNED
06 TO OPERABLE IN LESS THAN 1 HOUR. THE WEST ESF VENTILATION SYSTEM REMAINED OPERABLE
07 DURING THIS TIME. AFFECTED T.S. 3.7.6.1.

08 _____
 7 8 9

09 7 8	SYSTEM CODE Z Z 11	CAUSE CODE X 12	CAUSE SUBCODE Z 13	COMPONENT CODE C K T B R K 14	COMP. SUBCODE E 15	VALVE SUBCODE Z 16
17 7 8	LER/RO REPORT NUMBER 7 9 21	EVENT YEAR 7 9 22	SEQUENTIAL REPORT NO. 0 2 3 24	OCCURRENCE CODE <input checked="" type="checkbox"/> 03 28	REPORT TYPE L 30	REVISION NO. 0 32
18 7 8	ACTION TAKEN B 33	FUTURE ACTION Z 34	EFFECT ON PLANT Z 35	SHUTDOWN METHOD Z 36	HOURS 0 0 0 0 37	ATTACHMENT SUBMITTED N 41
19 7 8	NPRD-4 FORM SUB. N 42	PRIME COMP. SUPPLIER X 43	COMPONENT MANUFACTURER X 9 9 9 44	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)		

10 THE SPRAY ACTUATION WAS CAUSED BY A GROUNDED MANUAL ACTUATION STATION. THE
11 CORRECTIVE ACTION WAS TO CLEAN AND RESTORE THE MANUAL ACTUATION STATION TO
12 OPERABLE STATUS. THE CHARCOAL FILTER FIRE SPRAY WAS RETURNED TO OPERABLE IN
13 12 HOURS AND THE FIRE WATCH TERMINATED.

14 _____
 7 8 9

15 7 8	FACILITY STATUS C 28	% POWER 0 0 0 29	OTHER STATUS NA 30	METHOD OF DISCOVERY A 31	DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32
------------------------	---	---	------------------------------------	---	---

16 7 8	ACTIVITY RELEASED 7 33	CONTENT OF RELEASE Z 34	AMOUNT OF ACTIVITY NA 35	LOCATION OF RELEASE NA 36
------------------------	---	--	--	---

17 7 8	PERSONNEL EXPOSURES NUMBER 0 0 0 37	TYPE Z 38	DESCRIPTION NA 39
------------------------	--	--	-----------------------------------

18 7 8	PERSONNEL INJURIES NUMBER 0 0 0 40	DESCRIPTION NA 41
------------------------	---	-----------------------------------

19 7 8	LOSS OF OR DAMAGE TO FACILITY TYPE Z 42	DESCRIPTION NA 43
------------------------	--	-----------------------------------

20 7 8	PUBLICITY ISSUED N 44	DESCRIPTION NA 45
------------------------	--	-----------------------------------

7908030234 S

NAME OF PREPARER C. E. MURPHY

PHONE: 616-465-5901 X-316

