

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet


<p>This temporary sheet applies to OFF-SITE RADIOLOGICAL MONITORING</p> <p>Instruction or Procedure No. PMP 2081 EPP.012</p> <p>Revision No. 0</p>	<p>TEMPORARY SHEET NO.</p> <p style="text-align: center;">TP-1</p>
---	--

The following change (☒) new requirement () shall be instituted effective (Date) 25 Februray, 1982.

Change step 3.7.2 to read:

Place a particulate filter and a silver zeolite cartridge in the air sampler and collect a sample of 5 to 10 cubic foot volume at the location where the mRem/hr reading was the highest (found during the traverse).

Step 3.7.4 - Change "charcoal" to "silver zeolite".



REASON: Change sample specification from time to total volume. Change references to charcoal cartridges to silver zeolite.

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

<p>Expiration Date: <u>PROCEDURE REVISION</u></p> <p>Originator: <u>[Signature]</u></p> <p>Management Staff: <u>[Signature]</u></p> <p>Senior Reactor Operator: <u>[Signature]</u></p> <p>PNSRC <u>E L Townley</u> Date <u>2-25-82</u></p> <p>Plant Manager <u>W. J. [Signature]</u> Date <u>2-25-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>
--	--

1944

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to ENVIRONMENTAL MONITORING & ANALYSIS Instruction or Procedure No. PMP 2081 EPP.013 Revision No. 0</p>	<p>TEMPORARY SHEET NO. TP-1</p>
<p>The following change (X) new requirement () shall be instituted effective (Date) <u>25 February, 1982</u>.</p> <p>Change step 3.2.7 to read:</p> <p style="padding-left: 40px;">Collect air samples of 5 to 10 cubic feet total volume at the location of maximum dose rate (cloud centerline) at various distances (e.g., consider 1, 2, 3, 4, 5, 10, 20 miles from the site).</p> <div style="text-align: center; margin-top: 100px;"><div style="border: 1px dashed black; padding: 10px; display: inline-block;">FEB 27 1982</div></div> <p><u>REASON:</u> Change sample specification from sample time to total sample volume to account for different sample flow rates.</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>PROCEDURE REVISION</u> Originator: <u><i>W. Palmer</i></u> Management Staff: <u><i>W. Palmer</i></u> Senior Reactor Operator: <u><i>W. Palmer</i></u> PNSRC <u><i>E. L. Townley</i></u> Date <u>2-25-82</u> Plant Manager <u><i>W. Palmer</i></u> Date <u>2-25-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p> <div style="text-align: center; margin-top: 50px;"><div style="border: 1px solid black; width: 50px; height: 50px; transform: rotate(45deg); margin: 0 auto;"></div></div>

X

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to OFF-SITE DOSE ASSESSMENTS.</p> <p>Instruction or Procedure No. PMP 2081 EPP.014</p> <p>Revision No. 0</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1</p>
<p>The following change (<input checked="" type="checkbox"/>) new requirement () shall be instituted effective (Date) <u>25 February, 1982</u>.</p> <p>The procedure is defective and is not to be used until the review currently in progress results in the necessary revisions.</p> <div style="text-align: right; margin-top: 100px;"><div style="border: 1px solid black; padding: 5px; display: inline-block;">302 FEB 27 1982</div></div>	
<p><u>REASON:</u> Current procedure is incomplete and does not agree with other methods of off-site dose assessment.</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input type="checkbox"/> YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>PROCEDURE REVISION</u></p> <p>Originator: <u><i>R. Palmer</i></u></p> <p>Management Staff: <u><i>E. J. Amantele</i></u></p> <p>Senior Reactor Operator: <u><i>[Signature]</i></u></p> <p>PNSRC <u><i>E. L. Townley</i></u> Date <u>2-25-82</u></p> <p>Plant Manager <u><i>W. J. [Signature]</i></u> Date <u>2-25-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2031 EPP.001	Emergency Telephone Communications	Revision 0 4-1-81	
EPP.002	Barring of the PABX	Revision 0 4-1-81	
EPP.003	Follow-Up Off-Site Communications	Revision 0 4-1-81	
EPP.004	Protective Action Guides (PAGs) and Protective Actions	Revision 0 4-1-81	
EPP.005	Personnel Evacuation	Revision 0 4-1-81	
EPP.006	Activation of the Reentry and Rescue Team	Revision 0 4-1-81	
EPP.007	Security Actions During Emergency Conditions	Revision 0 4-1-81	
EPP.008	Emergency Medical Plan Guidelines	Revision 0 4-1-81	
EPP.009	Health Physics Procedures	Revision 0 4-1-81	
EPP.010	Activation of Radiation Monitoring Teams	Revision 0 4-1-81	
EPP.011	On-Site Radiological Monitoring	Revision 0 4-1-81	
EPP.012	Off-Site Radiological Monitoring	Revision 0 4-1-81	TP-1,2-25-82 Exp N/A
EPP.013	Environmental Monitoring and Analysis	Revision 0 4-1-81	TP-1,2-25-82 Exp N/A

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2081 EPP.014	Off-Site Dose Assessments	Revision 0 4-1-81	TP-1,2-25-82 Exp N/A
EPP.015	Sampling and Analysis of Waterborne Releases	Revision 0 4-1-81	
EPP.016	Collection and Analysis of Liquid and Gaseous Samples	Revision 0 4-1-81	
EPP.017	Interpretation of Liquid and Gaseous Samples	Revision 0 4-1-81	
EPP.018	Transportation Accidents Involving Radioactive Material	Revision 0 4-1-81	
EPP.019	AEP Emergency Response Organization Activation and Management	Revision 0 4-1-82	
EPP.020	Activation and Operation of the Technical Support Center (TSC)	Revision 0 4-1-81	TP-1,11-16-81 Exp N/A
EPP.021	Activation and Operation of the Operations Staging Area (OSA) and Personnel Accountability	Revision 0 4-1-81	TP-1,11-16-81 Exp N/A
EPP.022	Activation and Operation of the Recovery Center (RC) (An Emergency Operations Facility)	Revision 0 4-1-81	
EPP.023	Activation and Operation of the Emergency Control Center (ECC) (An Emergency Operations Facility)	Revision 0 4-1-81	
EPP.024	Activation and Operation of the Joint Public Information Center (JPIC) (An Emergency Operations Facility)	Revision 0 4-1-81	

