



Dresden Nuclear Power Station
6500 North Dresden Road
Morris, IL 60450

SVPLTR # 17-0046

November 13, 2017

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Dresden Nuclear Power Station, Unit 2
Renewed Facility Operating License Nos. DPR-19
NRC Docket No. 50-237

Subject: Core Operating Limits Report for Unit 2 Cycle 26

The purpose of this letter is to transmit the Core Operating Limits Report (COLR) for Dresden Nuclear Power Station (DNPS) Unit 2 operating cycle 26 (D2C26) in accordance with Technical Specifications Section 5.6.5, "CORE OPERATING LIMITS REPORT (COLR)."

There are no regulatory commitments contained in this submittal.

Should you have any questions concerning this letter, please contact Mr. Bruce Franzen at (815) 416-2800.

Respectfully,

A handwritten signature in black ink, appearing to read "P. Karaba".

Peter J Karaba
Site Vice President
Dresden Nuclear Power Station

Attachments: Core Operating Limits Report for Dresden Unit 2 Cycle 26, Revision 0

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Dresden Nuclear Power Station

A001
NRR

Core Operating Limits Report

For

Dresden Unit 2 Cycle 26

Revision 0

Table of Contents

	Page
Record of Dresden 2 Cycle 26 COLR Revisions.....	3
1. Terms and Definitions	6
2. General Information.....	7
3. Average Planar Linear Heat Generation Rate	8
4. Operating Limit Minimum Critical Power Ratio	47
4.1. Manual Flow Control MCPR Limits.....	47
4.1.1. Power-Dependent MCPR	47
4.1.2. Flow-Dependent MCPR	47
4.2. Scram Time	48
4.3. Exposure Dependent MCPR Limits.....	49
4.4. Recirculation Pump ASD Settings	49
5. Linear Heat Generation Rate	75
6. Control Rod Block Setpoints	83
7. Stability Protection Setpoints	84
8. Modes of Operation.....	85
9. Methodology.....	88
10. References.....	90

Record of Dresden 2 Cycle 26 COLR Revisions

<u>Revision</u>	<u>Description</u>
0	Initial issuance for D2C26

List of Tables

	Page
Table 3-1: MAPLHGR SLO Multipliers	8
Table 3-2: MAPLHGR for OPTIMA2 Lattices 81 and 89.....	8
Table 3-3: MAPLHGR for OPTIMA2 Lattice 131	9
Table 3-4: MAPLHGR for OPTIMA2 Lattice 132	10
Table 3-5: MAPLHGR for OPTIMA2 Lattice 133	11
Table 3-6: MAPLHGR for OPTIMA2 Lattice 134	12
Table 3-7: MAPLHGR for OPTIMA2 Lattice 135	13
Table 3-8: MAPLHGR for OPTIMA2 Lattice 136	14
Table 3-9: MAPLHGR for OPTIMA2 Lattice 137	15
Table 3-10: MAPLHGR for OPTIMA2 Lattice 138	16
Table 3-11: MAPLHGR for OPTIMA2 Lattice 139	17
Table 3-12: MAPLHGR for OPTIMA2 Lattice 140	18
Table 3-13: MAPLHGR for OPTIMA2 Lattice 141	19
Table 3-14: MAPLHGR for OPTIMA2 Lattice 142	20
Table 3-15: MAPLHGR for OPTIMA2 Lattice 143	21
Table 3-16: MAPLHGR for OPTIMA2 Lattice 144	22
Table 3-17: MAPLHGR for OPTIMA2 Lattice 145	23
Table 3-18: MAPLHGR for OPTIMA2 Lattice 146	24
Table 3-19: MAPLHGR for OPTIMA2 Lattice 147	25
Table 3-20: MAPLHGR for OPTIMA2 Lattice 148	26
Table 3-21: MAPLHGR for OPTIMA2 Lattice 149	27
Table 3-22: MAPLHGR for OPTIMA2 Lattice 150	28
Table 3-23: MAPLHGR for OPTIMA2 Lattice 151	29
Table 3-24: MAPLHGR for OPTIMA2 Lattice 152	30
Table 3-25: MAPLHGR for OPTIMA2 Lattice 153	31
Table 3-26: MAPLHGR for OPTIMA2 Lattice 154	32
Table 3-27: MAPLHGR for OPTIMA2 Lattice 155	33
Table 3-28: MAPLHGR for OPTIMA2 Lattice 156	34
Table 3-29: MAPLHGR for OPTIMA2 Lattice 157	35
Table 3-30: MAPLHGR for OPTIMA2 Lattice 158	36
Table 3-31: MAPLHGR for OPTIMA2 Lattice 159	37
Table 3-32: MAPLHGR for OPTIMA2 Lattice 160	38
Table 3-33: MAPLHGR for OPTIMA2 Lattice 161	39
Table 3-34: MAPLHGR for OPTIMA2 Lattice 162	40
Table 3-35: MAPLHGR for OPTIMA2 Lattice 163	41
Table 3-36: MAPLHGR for OPTIMA2 Lattice 164	42
Table 3-37: MAPLHGR for OPTIMA2 Lattice 165	43
Table 3-38: MAPLHGR for OPTIMA2 Lattice 166	44
Table 3-39: MAPLHGR for OPTIMA2 Lattice 167	45
Table 3-40: MAPLHGR for ATRIUM 10XM	46
Table 4-1: Scram Times	48
Table 4-2: Exposure Basis for Transient Analysis	49
Table 4-3: ATRIUM 10XM TLO MCPR _p Limits for NSS Insertion Times, BOC to NEOC (34,977 MWd/MTU CAVEX).....	50
Table 4-4: ATRIUM 10XM TLO MCPR _p Limits for ISS Insertion Times, BOC to NEOC (34,977 MWd/MTU CAVEX).....	51
Table 4-5: ATRIUM 10XM TLO MCPR _p Limits for TSSS Insertion Times, BOC to NEOC (34,977 MWd/MTU CAVEX).....	52
Table 4-6: ATRIUM 10XM TLO MCPR _p Limits for NSS Insertion Times, NEOC to EOFPLB (37,071 MWd/MTU CAVEX).....	53
Table 4-7: ATRIUM 10XM TLO MCPR _p Limits for ISS Insertion Times, NEOC to EOFPLB (37,071 MWd/MTU CAVEX).....	54

	Page
Table 4-8: ATRIUM 10XM TLO MCPR _p Limits for TSSS Insertion Times, NEOC to EOFPLB (37,071 MWd/MTU CAVEX).....	55
Table 4-9: ATRIUM 10XM TLO MCPR _p Limits for NSS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX).....	56
Table 4-10: ATRIUM 10XM TLO MCPR _p Limits for ISS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX).....	57
Table 4-11: ATRIUM 10XM TLO MCPR _p Limits for TSSS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX).....	58
Table 4-12: OPTIMA2 TLO MCPR _p Limits for NSS Insertion Times, BOC to NEOC (34,977 MWd/MTU CAVEX).....	59
Table 4-13: OPTIMA2 TLO MCPR _p Limits for ISS Insertion Times, BOC to NEOC (34,977 MWd/MTU CAVEX).....	60
Table 4-14: OPTIMA2 TLO MCPR _p Limits for TSSS Insertion Times, BOC to NEOC (34,977 MWd/MTU CAVEX).....	61
Table 4-15: OPTIMA2 TLO MCPR _p Limits for NSS Insertion Times, NEOC to EOFPLB (37,071 MWd/MTU CAVEX).....	62
Table 4-16: OPTIMA2 TLO MCPR _p Limits for ISS Insertion Times, NEOC to EOFPLB (37,071 MWd/MTU CAVEX).....	63
Table 4-17: OPTIMA2 TLO MCPR _p Limits for TSSS Insertion Times, NEOC to EOFPLB (37,071 MWd/MTU CAVEX).....	64
Table 4-18: OPTIMA2 TLO MCPR _p Limits for NSS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX).....	65
Table 4-19: OPTIMA2 TLO MCPR _p Limits for ISS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX).....	66
Table 4-20: OPTIMA2 TLO MCPR _p Limits for TSSS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX).....	67
Table 4-21: ATRIUM 10XM SLO MCPR _p Limits for NSS Insertion Times, All Exposures.....	68
Table 4-22: ATRIUM 10XM SLO MCPR _p Limits for ISS Insertion Times, All Exposures.....	69
Table 4-23: ATRIUM 10XM SLO MCPR _p Limits for TSSS Insertion Times, All Exposures.....	70
Table 4-24: OPTIMA2 SLO MCPR _p Limits for NSS Insertion Times, All Exposures.....	71
Table 4-25: OPTIMA2 SLO MCPR _p Limits for ISS Insertion Times, All Exposures.....	72
Table 4-26: OPTIMA2 SLO MCPR _p Limits for TSSS Insertion Times, All Exposures.....	73
Table 4-27: ATRIUM 10XM and OPTIMA2 MCPR _r Limits.....	74
Table 5-1: LHGR Limits for OPTIMA2 Lattices 137, 138, 139, 143, 144, 145, 146, 147, 148, 156, 157, 158, 159, 163, 164, 165, 166, 167.....	76
Table 5-2: LHGR Limits for OPTIMA2 Lattices 135, 141.....	76
Table 5-3: LHGR Limits for OPTIMA2 Lattices 131, 132, 133, 136, 140, 142.....	77
Table 5-4: LHGR Limits for OPTIMA2 Lattice 134.....	77
Table 5-5: LHGR Limits for OPTIMA2 Lattices 154, 161.....	78
Table 5-6: LHGR Limits for OPTIMA2 Lattices 150, 151, 152, 155, 160, 162.....	78
Table 5-7: LHGR Limits for OPTIMA2 Lattices 149, 153.....	79
Table 5-8: LHGR Limits for OPTIMA2 Lattices 81, 89.....	79
Table 5-9: LHGR Limits for ATRIUM 10XM.....	79
Table 5-10: ATRIUM 10XM LHGRFAC _p Multipliers.....	80
Table 5-11: OPTIMA2 LHGRFAC _p Multipliers.....	81
Table 5-12: ATRIUM 10XM LHGRFAC _r Multipliers.....	82
Table 5-13: OPTIMA2 LHGRFAC _r Multipliers.....	82
Table 6-1: Rod Block Monitor Upscale Instrumentation Setpoints.....	83
Table 7-1: OPRM PBDA Trip Settings.....	84
Table 8-1: Modes of Operation.....	85
Table 8-2: Core Thermal Power Restriction for OOS Conditions.....	87

1. Terms and Definitions

AOO	Anticipated operational occurrence
ASD	Adjustable speed drive
CAVEX	Core average exposure
CPR	Critical power ratio
CRWE	Control rod withdrawal error
CTP	Core thermal power
EFPD	Effective full power day
EFPH	Effective full power hour
EOC	End of cycle
EOCLB	End of cycle licensing basis
EOFPL	End of full power life
EOFPLB	End of full power licensing basis
EOOS	Equipment out of service
FHOOS	Feedwater heater out of service
FWT	Feedwater temperature
ICF	Increased core flow
ISS	Intermediate scram speed
LHGR	Linear heat generation rate
LHGRFAC _f	Flow dependent linear heat generation rate multiplier
LHGRFAC _p	Power dependent linear heat generation rate multiplier
LPRM	Local power range monitor
MAPLHGR	Maximum average planar linear heat generation rate
MCPR	Minimum critical power ratio
MCPR _f	Flow dependent minimum critical power ratio
MCPR _p	Power dependent minimum critical power ratio
MELLLA	Maximum extended load line limit analysis
MSIVOOS	Main steam isolation valve out of service
MWd/MTU	Megawatt days per metric ton Uranium
NEOC	Near end of cycle
NRC	Nuclear Regulatory Commission
NSS	Nominal scram speed
OLMCPR	Operating limit minimum critical power ratio
OOS	Out of service
OPRM	Oscillation power range monitor
PBDA	Period based detection algorithm
PCOOS	Pressure controller out of service
PLUOOS	Power load unbalance out of service
SLMCPR	Safety limit minimum critical power ratio
SLO	Single loop operation
TBV	Turbine bypass valve
TBVOOS	Turbine bypass valves out of service
TCV	Turbine control valve
TIP	Traversing in-core probe
TLO	Two loop operation
TMOL	Thermal mechanical operating limit
TRM	Technical Requirements Manual
TSSS	Technical Specification scram speed
TSV	Turbine stop valve

2. General Information

This report is prepared in accordance with Technical Specification 5.6.5. The D2C26 reload is licensed by AREVA. However, some legacy analyses by Westinghouse are still applicable for OPTIMA2 fuel as described in Reference 12.

Licensed rated thermal power is 2957 MWth. Rated core flow is 98 Mlb/hr. Operation up to 108% rated core flow is licensed for this cycle; however, core flow cannot exceed 103.4% rated core flow due to unit specific limitations. For allowed operating regions, see applicable power/flow map.

The licensing analysis supports full power operation to EOCLB (37,934 MWd/MTU CAVEX). Note that this value includes coastdown, where full power operation is not expected. The transient analysis limits are provided for operation up to specific CAVEX exposures as defined in Section 4.3.

Coastdown is defined as operation beyond EOFPL with the plant power gradually reducing as available core reactivity diminishes. The D2C26 reload analyses do not credit this reduced power during coastdown and the EOCLB limits remain valid for operation up to rated power. The minimum allowed coastdown power level is 40% rated CTP per Reference 1.

Power and flow dependent limits are listed for various power and flow levels. Linear interpolation on power and flow (as applicable) is to be used to find intermediate values. Linear interpolation is also to be used for table items intentionally left blank, as indicated by boxes which are grayed out.

Only $M CPR_p$ varies with scram speed. All other thermal limits are analyzed to remain valid with NSS, ISS, and TSSS.

$LHGRFAC_f$ is independent of feedwater temperature and EOOS conditions.

For thermal limit monitoring above 100% rated core flow, the 100% core flow values can be used unless otherwise indicated in the applicable table.

For thermal limit monitoring above 100% rated power or 108% rated core flow, the 100% rated power or the 108% core flow thermal limit values, respectively, shall be used. Steady state operation is not allowed in this region. Limits are provided for transient conditions only.

3. Average Planar Linear Heat Generation Rate

Technical Specifications Sections 3.2.1 and 3.4.1

Table 3-1 provides the MAPLHGR SLO multipliers for ATRIUM 10XM and OPTIMA2 fuel. For OPTIMA2 natural uranium lattices, TLO and SLO MAPLHGR values are provided in Table 3-2. For all other OPTIMA2 lattices, lattice-specific MAPLHGR values for TLO are provided in Tables 3-3 through 3-39.

For ATRIUM 10XM fuel, the MAPLHGR values applicable for all lattices can be found in Table 3-40.

During SLO, the limits in Tables 3-3 through 3-40 are multiplied by the fuel-specific SLO multiplier listed in Table 3-1. The ATRIUM 10XM multiplier may be applied to OPTIMA2 for SLO conditions, as the ATRIUM10XM multiplier is more limiting.

Table 3-1: MAPLHGR SLO Multipliers
(References 7, 10, and 12)

Fuel Type	Multiplier
ATRIUM 10XM	0.80
OPTIMA2	0.86

Table 3-2: MAPLHGR for OPTIMA2 Lattices 81 and 89
(Reference 6, 7, 9, and 10)

All OPTIMA2 Bundles Lattices 81: Opt2-B0.71 89: Opt2-T0.71	
Average Planar Exposure (MWd/MTU)	TLO and SLO MAPLHGR (kW/ft)
0	7.50
75000	7.50

Table 3-3: MAPLHGR for OPTIMA2 Lattice 131
(References 6 and 7)

Bundle Opt2-4.04-18GZ7.50-14GZ5.50 Lattice 131: Opt2-B4.44-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.21
2500	9.53
5000	9.45
7500	9.38
10000	9.49
12000	9.50
15000	9.55
17000	9.61
20000	9.80
22000	9.89
24000	9.83
30000	9.77
36000	9.71
42000	9.67
50000	9.70
60000	9.81
72000	10.07
75000	10.07

Table 3-4: MAPLHGR for OPTIMA2 Lattice 132
(References 6 and 7)

Bundle Opt2-4.04-18GZ7.50-14GZ5.50 Lattice 132: Opt2-BE4.54-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.34
2500	9.62
5000	9.51
7500	9.43
10000	9.55
12000	9.57
15000	9.64
17000	9.73
20000	9.89
22000	10.02
24000	9.94
30000	9.86
36000	9.81
42000	9.74
50000	9.77
60000	9.80
72000	10.10
75000	10.10

Table 3-5: MAPLHGR for OPTIMA2 Lattice 133
(References 6 and 7)

Bundle Opt2-4.04-18GZ7.50-14GZ5.50 Lattice 133: Opt2-M4.54-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.33
2500	9.62
5000	9.57
7500	9.43
10000	9.56
12000	9.62
15000	9.67
17000	9.75
20000	9.98
22000	9.99
24000	9.93
30000	9.85
36000	9.81
42000	9.74
50000	9.75
60000	9.78
72000	9.90
75000	9.90

Table 3-6: MAPLHGR for OPTIMA2 Lattice 134
 (References 6 and 7)

Bundle Opt2-4.04-18GZ7.50-14GZ5.50 Lattice 134: Opt2-ME4.50-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.46
2500	9.77
5000	9.62
7500	9.52
10000	9.72
12000	9.73
15000	9.83
17000	9.93
20000	10.19
22000	10.19
24000	10.11
30000	10.04
36000	9.97
42000	9.92
50000	9.85
60000	9.88
72000	10.39
75000	10.39

Table 3-7: MAPLHGR for OPTIMA2 Lattice 135
(References 6 and 7)

Bundle Opt2-4.04-18GZ7.50-14GZ5.50 Lattice 135: Opt2-T4.50-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.48
2500	9.76
5000	9.56
7500	9.45
10000	9.55
12000	9.72
15000	9.78
17000	9.94
20000	10.19
22000	10.16
24000	10.11
30000	10.05
36000	9.97
42000	9.93
50000	9.81
60000	9.84
72000	10.25
75000	10.25

Table 3-8: MAPLHGR for OPTIMA2 Lattice 136
(References 6 and 7)

Bundle Opt2-4.04-18GZ7.50-14GZ5.50 Lattice 136: Opt2-T4.52-14G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.21
2500	10.47
5000	10.28
7500	10.05
10000	10.09
12000	10.11
15000	10.22
17000	10.27
20000	10.26
22000	10.29
24000	10.22
30000	10.16
36000	10.09
42000	10.00
50000	9.87
60000	9.90
72000	10.26
75000	10.26

Table 3-9: MAPLHGR for OPTIMA2 Lattice 137
(References 6 and 7)

Bundle Opt2-4.01-16GZ7.50-14GZ5.50 Lattice 137: Opt2-B4.41-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.47
2500	9.76
5000	9.66
7500	9.57
10000	9.64
12000	9.54
15000	9.57
17000	9.60
20000	9.76
22000	9.90
24000	9.84
30000	9.79
36000	9.75
42000	9.70
50000	9.70
60000	9.79
72000	10.07
75000	10.07

Table 3-10: MAPLHGR for OPTIMA2 Lattice 138
(References 6 and 7)

Bundle Opt2-4.01-16GZ7.50-14GZ5.50 Lattice 138: Opt2-BE4.51-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.63
2500	9.85
5000	9.81
7500	9.63
10000	9.70
12000	9.70
15000	9.70
17000	9.75
20000	9.89
22000	10.00
24000	9.95
30000	9.89
36000	9.85
42000	9.77
50000	9.70
60000	9.69
72000	10.02
75000	10.02

Table 3-11: MAPLHGR for OPTIMA2 Lattice 139
(References 6 and 7)

Bundle Opt2-4.01-16GZ7.50-14GZ5.50 Lattice 139: Opt2-M4.51-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.62
2500	9.87
5000	9.91
7500	9.63
10000	9.72
12000	9.74
15000	9.73
17000	9.77
20000	9.91
22000	10.00
24000	9.95
30000	9.88
36000	9.85
42000	9.77
50000	9.68
60000	9.68
72000	10.06
75000	10.06

Table 3-12: MAPLHGR for OPTIMA2 Lattice 140
(References 6 and 7)

Bundle Opt2-4.01-16GZ7.50-14GZ5.50 Lattice 140: Opt2-ME4.46-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.78
2500	10.04
5000	9.96
7500	9.80
10000	9.89
12000	9.89
15000	9.89
17000	9.94
20000	10.17
22000	10.19
24000	10.14
30000	10.08
36000	10.01
42000	9.92
50000	9.80
60000	9.84
72000	10.25
75000	10.25

Table 3-13: MAPLHGR for OPTIMA2 Lattice 141
(References 6 and 7)

Bundle Opt2-4.01-16GZ7.50-14GZ5.50 Lattice 141: Opt2-T4.46-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.80
2500	10.02
5000	9.87
7500	9.76
10000	9.84
12000	9.84
15000	9.83
17000	9.95
20000	10.16
22000	10.15
24000	10.13
30000	10.08
36000	10.00
42000	9.88
50000	9.77
60000	9.71
72000	9.91
75000	9.91

Table 3-14: MAPLHGR for OPTIMA2 Lattice 142
(References 6 and 7)

Bundle Opt2-4.01-16GZ7.50-14GZ5.50 Lattice 142: Opt2-T4.47-14G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.22
2500	10.45
5000	10.32
7500	10.07
10000	10.01
12000	10.11
15000	10.23
17000	10.25
20000	10.23
22000	10.23
24000	10.19
30000	10.14
36000	10.07
42000	9.96
50000	9.84
60000	9.87
72000	10.26
75000	10.26

Table 3-15: MAPLHGR for OPTIMA2 Lattice 143
(References 6 and 7)

Bundle Opt2-4.04-14G5.50-2GZ5.50 Lattice 143: Opt2-B4.44-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.48
2500	9.78
5000	9.79
7500	9.59
10000	9.69
12000	9.63
15000	9.75
17000	9.83
20000	10.01
22000	9.95
24000	9.90
30000	9.84
36000	9.79
42000	9.74
50000	9.72
60000	9.77
72000	9.85
75000	9.79

Table 3-16: MAPLHGR for OPTIMA2 Lattice 144
(References 6 and 7)

Bundle Opt2-4.04-14G5.50-2GZ5.50 Lattice 144: Opt2-BE4.54-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.55
2500	9.87
5000	10.02
7500	9.74
10000	9.78
12000	9.76
15000	9.89
17000	10.00
20000	10.15
22000	10.07
24000	10.02
30000	9.94
36000	9.91
42000	9.87
50000	9.84
60000	9.94
72000	10.19
75000	10.19

Table 3-17: MAPLHGR for OPTIMA2 Lattice 145
(References 6 and 7)

Bundle Opt2-4.04-14G5.50-2GZ5.50 Lattice 145:Opt2-M4.54-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.54
2500	9.87
5000	10.06
7500	9.85
10000	9.80
12000	9.80
15000	9.91
17000	10.04
20000	10.13
22000	10.07
24000	10.02
30000	9.94
36000	9.91
42000	9.87
50000	9.82
60000	9.94
72000	10.19
75000	10.19

Table 3-18: MAPLHGR for OPTIMA2 Lattice 146
(References 6 and 7)

Bundle Opt2-4.04-14G5.50-2GZ5.50 Lattice 146: Opt2-ME4.50-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.70
2500	10.04
5000	10.15
7500	9.87
10000	9.96
12000	9.96
15000	10.18
17000	10.32
20000	10.34
22000	10.26
24000	10.23
30000	10.15
36000	10.09
42000	10.04
50000	9.88
60000	9.88
72000	10.30
75000	10.30

Table 3-19: MAPLHGR for OPTIMA2 Lattice 147
(References 6 and 7)

Bundle Opt2-4.04-14G5.50-2GZ5.50 Lattice 147: Opt2-T4.50-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.74
2500	10.06
5000	10.08
7500	9.84
10000	9.92
12000	9.93
15000	10.14
17000	10.31
20000	10.25
22000	10.24
24000	10.20
30000	10.14
36000	10.07
42000	10.00
50000	9.85
60000	9.87
72000	10.25
75000	10.25

Table 3-20: MAPLHGR for OPTIMA2 Lattice 148
(References 6 and 7)

Bundle Opt2-4.04-14G5.50-2GZ5.50 Lattice 148: Opt2-T4.51-14G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.14
2500	10.42
5000	10.48
7500	10.06
10000	10.08
12000	10.07
15000	10.15
17000	10.27
20000	10.26
22000	10.30
24000	10.23
30000	10.17
36000	10.10
42000	9.98
50000	9.84
60000	9.77
72000	10.39
75000	10.39

Table 3-21: MAPLHGR for OPTIMA2 Lattice 149
(References 9 and 10)

Bundle Opt2-4.02-18GZ7.50-14GZ5.50 Lattice 149: Opt2-B4.31-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.51
2500	9.85
5000	9.92
7500	9.84
10000	10.09
12000	10.18
15000	10.32
17000	10.37
20000	10.43
22000	10.39
24000	10.41
30000	10.24
36000	10.12
42000	9.99
50000	9.89
75000	9.89

Table 3-22: MAPLHGR for OPTIMA2 Lattice 150
(References 9 and 10)

Bundle Opt2-4.02-18GZ7.50-14GZ5.50 Lattice 150: Opt2-B4.44-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.42
2500	9.75
5000	9.65
7500	9.57
10000	9.69
12000	9.72
15000	9.77
17000	9.84
20000	10.04
22000	10.14
24000	10.08
30000	10.02
36000	9.97
42000	9.93
50000	9.97
75000	9.97

Table 3-23: MAPLHGR for OPTIMA2 Lattice 151
(References 9 and 10)

Bundle Opt2-4.02-18GZ7.50-14GZ5.50 Lattice 151: Opt2-BE4.54-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.55
2500	9.83
5000	9.72
7500	9.62
10000	9.75
12000	9.78
15000	9.87
17000	9.96
20000	10.12
22000	10.26
24000	10.19
30000	10.11
36000	10.07
42000	10.01
50000	10.04
75000	10.04

Table 3-24: MAPLHGR for OPTIMA2 Lattice 152
(References 9 and 10)

Bundle Opt2-4.02-18GZ7.50-14GZ5.50 Lattice 152: Opt2-M4.54-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.54
2500	9.84
5000	9.79
7500	9.62
10000	9.75
12000	9.82
15000	9.90
17000	9.98
20000	10.20
22000	10.24
24000	10.17
30000	10.10
36000	10.06
42000	10.00
50000	10.02
75000	10.02

Table 3-25: MAPLHGR for OPTIMA2 Lattice 153
(References 9 and 10)

Bundle Opt2-4.02-18GZ7.50-14GZ5.50 Lattice 153: Opt2-ME4.50-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.67
2500	10.00
5000	9.83
7500	9.72
10000	9.92
12000	9.94
15000	10.05
17000	10.16
20000	10.45
22000	10.43
24000	10.36
30000	10.30
36000	10.23
42000	10.19
50000	10.13
75000	10.13

Table 3-26: MAPLHGR for OPTIMA2 Lattice 154
(References 9 and 10)

Bundle Opt2-4.02-18GZ7.50-14GZ5.50 Lattice 154: Opt2-T4.50-18G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.70
2500	9.98
5000	9.77
7500	9.64
10000	9.75
12000	9.93
15000	10.00
17000	10.16
20000	10.43
22000	10.40
24000	10.35
30000	10.30
36000	10.23
42000	10.19
50000	10.09
75000	10.09

Table 3-27: MAPLHGR for OPTIMA2 Lattice 155
(References 9 and 10)

Bundle Opt2-4.02-18GZ7.50-14GZ5.50 Lattice 155: Opt2-T4.52-14G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.40
2500	10.71
5000	10.55
7500	10.25
10000	10.30
12000	10.32
15000	10.45
17000	10.52
20000	10.51
22000	10.52
24000	10.47
30000	10.41
36000	10.35
42000	10.27
50000	10.16
75000	10.16

Table 3-28: MAPLHGR for OPTIMA2 Lattice 156
(References 9 and 10)

Bundle Opt2-3.98-16GZ7.50-14GZ5.50 Lattice 156: Opt2-B4.27-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.78
2500	10.09
5000	10.14
7500	10.04
10000	10.20
12000	10.25
15000	10.34
17000	10.38
20000	10.41
22000	10.44
24000	10.45
30000	10.19
36000	10.07
42000	9.94
50000	9.84
75000	9.84

Table 3-29: MAPLHGR for OPTIMA2 Lattice 157
(References 9 and 10)

Bundle Opt2-3.98-16GZ7.50-14GZ5.50 Lattice 157: Opt2-B4.41-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.69
2500	9.99
5000	9.88
7500	9.76
10000	9.83
12000	9.76
15000	9.79
17000	9.83
20000	10.00
22000	10.13
24000	10.09
30000	10.04
36000	10.00
42000	9.95
50000	9.95
75000	9.95

Table 3-30: MAPLHGR for OPTIMA2 Lattice 158
 (References 9 and 10)

Bundle Opt2-3.98-16GZ7.50-14GZ5.50 Lattice 158: Opt2-BE4.51-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.84
2500	10.08
5000	10.02
7500	9.82
10000	9.90
12000	9.92
15000	9.92
17000	9.98
20000	10.13
22000	10.24
24000	10.20
30000	10.14
36000	10.10
42000	10.04
50000	9.71
75000	9.71

Table 3-31: MAPLHGR for OPTIMA2 Lattice 159
(References 9 and 10)

Bundle Opt2-3.98-16GZ7.50-14GZ5.50 Lattice 159: Opt2-M4.51-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.84
2500	10.09
5000	10.12
7500	9.83
10000	9.91
12000	9.96
15000	9.95
17000	10.00
20000	10.14
22000	10.24
24000	10.19
30000	10.13
36000	10.10
42000	10.03
50000	9.93
75000	9.93

Table 3-32: MAPLHGR for OPTIMA2 Lattice 160
(References 9 and 10)

Bundle Opt2-3.98-16GZ7.50-14GZ5.50 Lattice 160: Opt2-ME4.46-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.01
2500	10.27
5000	10.19
7500	10.00
10000	10.10
12000	10.11
15000	10.11
17000	10.17
20000	10.42
22000	10.42
24000	10.39
30000	10.33
36000	10.27
42000	10.19
50000	10.08
75000	10.08

Table 3-33: MAPLHGR for OPTIMA2 Lattice 161
(References 9 and 10)

Bundle Opt2-3.98-16GZ7.50-14GZ5.50 Lattice 161: Opt2-T4.46-16G7.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.03
2500	10.26
5000	10.09
7500	9.97
10000	10.04
12000	10.05
15000	10.06
17000	10.18
20000	10.40
22000	10.40
24000	10.37
30000	10.33
36000	10.26
42000	10.15
50000	10.00
75000	10.00

Table 3-34: MAPLHGR for OPTIMA2 Lattice 162
 (References 9 and 10)

Bundle Opt2-3.98-16GZ7.50-14GZ5.50 Lattice 162: Opt2-T4.47-14G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.41
2500	10.69
5000	10.54
7500	10.28
10000	10.20
12000	10.32
15000	10.46
17000	10.49
20000	10.48
22000	10.47
24000	10.44
30000	10.39
36000	10.33
42000	10.22
50000	10.12
75000	10.12

Table 3-35: MAPLHGR for OPTIMA2 Lattice 163
(References 9 and 10)

Bundle Opt2-4.10-14G5.50-2GZ5.50 Lattice 163: Opt2-B4.50-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.47
2500	9.81
5000	9.71
7500	9.58
10000	9.68
12000	9.73
15000	9.89
17000	10.00
20000	10.18
22000	10.21
24000	10.18
30000	10.12
36000	10.07
42000	10.00
50000	10.02
75000	10.02

Table 3-36: MAPLHGR for OPTIMA2 Lattice 164
(References 9 and 10)

Bundle Opt2-4.10-14G5.50-2GZ5.50 Lattice 164: Opt2-BE4.60-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.53
2500	9.89
5000	9.85
7500	9.83
10000	9.76
12000	9.82
15000	10.01
17000	10.16
20000	10.33
22000	10.34
24000	10.31
30000	10.23
36000	10.18
42000	10.14
50000	10.09
75000	10.09

Table 3-37: MAPLHGR for OPTIMA2 Lattice 165
(References 9 and 10)

Bundle Opt2-4.10-14G5.50-2GZ5.50 Lattice 165: Opt2-M4.60-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.51
2500	9.91
5000	9.89
7500	9.85
10000	9.78
12000	9.85
15000	10.02
17000	10.18
20000	10.36
22000	10.36
24000	10.31
30000	10.23
36000	10.18
42000	10.14
50000	10.09
75000	10.09

Table 3-38: MAPLHGR for OPTIMA2 Lattice 166
(References 9 and 10)

Bundle Opt2-4.10-14G5.50-2GZ5.50 Lattice 166: Opt2-ME4.57-16G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	9.68
2500	10.09
5000	10.04
7500	9.93
10000	9.95
12000	10.03
15000	10.31
17000	10.47
20000	10.62
22000	10.56
24000	10.51
30000	10.44
36000	10.37
42000	10.28
50000	10.22
75000	10.22

Table 3-39: MAPLHGR for OPTIMA2 Lattice 167
(References 9 and 10)

Bundle Opt2-4.10-14G5.50-2GZ5.50 Lattice 167: Opt2-T4.58-14G5.50	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	10.13
2500	10.45
5000	10.44
7500	10.17
10000	10.08
12000	10.10
15000	10.29
17000	10.44
20000	10.56
22000	10.56
24000	10.52
30000	10.46
36000	10.39
42000	10.31
50000	10.17
75000	10.17

Table 3-40: MAPLHGR for ATRIUM 10XM
(Reference 12)

All ATRIUM 10XM Lattices	
Average Planar Exposure (MWd/MTU)	TLO MAPLHGR (kW/ft)
0	11.50
20000	11.50
25000	10.70
67000	7.01

4. Operating Limit Minimum Critical Power Ratio

Technical Specification Sections 3.2.2, 3.4.1, and 3.7.7

The OLMCPRs for D2C26 were established so that less than 0.1% of the fuel rods in the core are expected to experience boiling transition during an AOO initiated from rated or off-rated conditions and are based on the Technical Specifications SLMCPR values (Reference 12).

Tables 4-3 through 4-27 include MCPR limits for various specified EOOS conditions. The EOOS conditions separated by "r" in these tables represent single EOOS conditions and not any combination of conditions. Refer to Section 8 for a detailed explanation of allowable combined EOOS conditions.

4.1. Manual Flow Control MCPR Limits

The OLMCPR is determined for a given power and flow condition by evaluating the power-dependent MCPR and the flow-dependent MCPR and selecting the greater of the two.

4.1.1. Power-Dependent MCPR

The OLMCPR as a function of core thermal power ($MCPR_p$) is shown in Tables 4-3 through 4-26. $MCPR_p$ limits are dependent on scram times as described in Section 4.2, exposure as described in Section 4.3, fuel type, FWT, and whether the plant is in TLO or SLO. TLO limits for ATRIUM 10XM fuel are given in Tables 4-3 through 4-11 and SLO limits for ATRIUM 10XM are given in Tables 4-21 through 4-23. TLO limits for OPTIMA2 fuel are given in Tables 4-12 through 4-20 and SLO limits for OPTIMA2 fuel are given in Tables 4-24 through 4-26.

4.1.2. Flow-Dependent MCPR

Table 4-27 gives the OLMCPR limit as a function of the flow ($MCPR_f$) based on the applicable plant condition. These values are applicable to both ATRIUM 10XM and OPTIMA2 fuel.

4.2. Scram Time

TSSS, ISS, and NSS refer to scram speeds. The scram time values associated with these speeds are shown in Table 4-1. The TSSS scram times shown in Table 4-1 are the same as those specified in the Technical Specifications (Reference 2).

To utilize the OLMCPR limits for NSS in Tables 4-3, 4-6, 4-9, 4-12, 4-15, 4-18, 4-21, and 4-24, the average control rod insertion time at each control rod insertion fraction must be equal to or less than the NSS time shown in Table 4-1 below.

To utilize the OLMCPR limits for ISS in Tables 4-4, 4-7, 4-10, 4-13, 4-16, 4-19, 4-22 and 4-25, the average control rod insertion time at each control rod insertion fraction must be equal to or less than the ISS time shown in Table 4-1 below.

The "Average Control Rod Insertion Time" is defined as the sum of the control rod insertion times of all operable control rods divided by the number of operable control rods. Conservative adjustments to the NSS and ISS scram speeds were made to the analysis inputs to appropriately account for the effects of 1 stuck control rod and one additional control rod that is assumed to fail to scram (Reference 12).

To utilize the OLMCPR limits for TSSS in Tables 4-5, 4-8, 4-11, 4-14, 4-17, 4-20, 4-23, and 4-26, the control rod insertion time of each operable control rod at each control rod insertion fraction must be less than or equal to the TSSS time shown in Table 4-1 below. The Technical Specifications allow operation with up to 12 "slow" and 1 stuck control rod. One additional control rod is assumed to fail to scram for the system transient analyses performed to establish MCPR_p limits (Reference 12). Conservative adjustments to the TSSS scram speeds were made to the analysis inputs to appropriately account for the effects of the slow and stuck rods on scram reactivity (Reference 12).

For cases below 38.5% power (P_{bypass}), the results are relatively insensitive to scram speed, and only TSSS analyses were performed (Reference 12).

Table 4-1: Scram Times
(References 2 and 12)

Control Rod Insertion Fraction (%)	NSS (seconds)	ISS (seconds)	TSSS (seconds)
5	0.324	0.36	0.48
20	0.700	0.72	0.89
50	1.510	1.58	1.98
90	2.635	2.74	3.44

4.3. Exposure Dependent MCPR Limits

Exposure-dependent $MCPR_p$ limits were established to support operation from BOC to NEOC (CAVEX of 34,977 MWd/MTU), NEOC to EOFPLB (CAVEX of 37,071 MWd/MTU), and EOFPLB to EOCLB (CAVEX of 37,934 MWd/MTU) as defined by the CAVEX values listed in Table 4-2. Note that the thermal limits are based on CAVEX. The limits at a later exposure range can be used earlier in the cycle as they are the same or more conservative.

Table 4-2: Exposure Basis for Transient Analysis
(Reference 12)

Core Average Exposure (CAVEX) (MWd/MTU)	Description
34,977	Break point for exposure-dependent $MCPR_p$ limits (NEOC)
37,071	Design basis rod patterns to EOFPL + 25 EFPD (EOFPLB)
37,934	EOCLB – Maximum licensing core exposure, including coastdown

4.4. Recirculation Pump ASD Settings

Technical Requirement Manual 2.1.a.1

Dresden 2 Cycle 26 was analyzed with a slow flow excursion event assuming a failure of the recirculation flow control system such that the core flow increases slowly to the maximum flow physically permitted by the equipment, assumed to be 110% of rated core flow (Reference 12); therefore, the recirculation pump ASD must be set to maintain core flow less than 110% (107.8 Mlb/hr) for all runout events.

**Table 4-3: ATRIUM 10XM TLO MCPR_p Limits for NSS Insertion Times,
BOC to NEOC (34,977 MWd/MTU CAVEX)**

(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	1.96		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.01		1.50
	> 60	3.50	3.50	2.78			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.30	1.94	1.47
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.09		1.47
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.10		1.50
	> 60	3.63	3.63	2.88			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.30	1.94	1.47
	> 60	2.76	2.76	2.31			

**Table 4-4: ATRIUM 10XM TLO MCPR_p Limits for ISS Insertion Times,
BOC to NEOC (34,977 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	1.96	[shaded]	1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.01	[shaded]	1.50
	> 60	3.50	3.50	2.78			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.30	1.94	1.47
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.09	[shaded]	1.47
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.11	[shaded]	1.50
	> 60	3.63	3.63	2.88			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.30	1.94	1.47
	> 60	2.76	2.76	2.31			

**Table 4-5: ATRIUM 10XM TLO MCPR_p Limits for TSSS Insertion Times,
BOC to NEOC (34,977 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	2.00		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.03		1.51
	> 60	3.50	3.50	2.78			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.31	1.97	1.49
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.14		1.48
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.14		1.53
	> 60	3.63	3.63	2.88			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.31	1.97	1.49
	> 60	2.76	2.76	2.31			

**Table 4-6: ATRIUM 10XM TLO MCPR_p Limits for NSS Insertion Times,
NEOC to EOFPLB (37,071 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	1.96		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.01		1.50
	> 60	3.50	3.50	2.78			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.30	1.94	1.47
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.09		1.47
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.10		1.50
	> 60	3.63	3.63	2.88			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.30	1.94	1.47
	> 60	2.76	2.76	2.31			

Table 4-7: ATRIUM 10XM TLO MCPR_p Limits for ISS Insertion Times,
NEOC to EOFPLB (37,071 MWd/MTU CAVEX)
(Reference 12)

Nominal FWT							
EOMS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	1.96		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.01		1.50
	> 60	3.50	3.50	2.78			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.30	1.94	1.47
	> 60	2.61	2.61	2.31			
FHOOS							
EOMS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.09		1.47
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.11		1.50
	> 60	3.63	3.63	2.88			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.30	1.94	1.47
	> 60	2.76	2.76	2.31			

**Table 4-8: ATRIUM 10XM TLO MCRP_p Limits for TSSS Insertion Times,
NEOC to EOFPLB (37,071 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	2.00		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.03		1.51
	> 60	3.50	3.50	2.78			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.31	1.97	1.49
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.14		1.48
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.14		1.53
	> 60	3.63	3.63	2.88			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.31	1.97	1.49
	> 60	2.76	2.76	2.31			

**Table 4-9: ATRIUM 10XM TLO MCPR_p Limits for NSS Insertion Times,
EOFLB to EOCLB (37,934 MWd/MTU CAVE)
(Reference 12)**

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	1.96		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.01		1.50
	> 60	3.50	3.50	2.78			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.30	1.94	1.47
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.09		1.47
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.10		1.50
	> 60	3.63	3.63	2.88			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.30	1.94	1.47
	> 60	2.76	2.76	2.31			

Table 4-10: ATRIUM 10XM TLO MCPR_p Limits for ISS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX)
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	1.96		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.01		1.50
	> 60	3.50	3.50	2.78			
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.30	1.94	1.47
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.09		1.47
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.11		1.50
	> 60	3.63	3.63	2.88			
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.30	1.94	1.47
	> 60	2.76	2.76	2.31			

Table 4-11: ATRIUM 10XM TLO MCPR_p Limits for TSSS Insertion Times, EOFPLB to EOCLB (37,934 MWd/MTU CAVEX)
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.55	2.55	2.20	2.00		1.47
	> 60	2.61	2.61	2.31			
TBVOOS	≤ 60	3.50	3.50	2.66	2.03		1.51
	> 60	3.50	3.50	2.78			
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	2.55	2.55	2.31	2.31	1.97	1.49
	> 60	2.61	2.61	2.31			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.74	2.74	2.31	2.14		1.48
	> 60	2.76	2.76	2.31			
TBVOOS	≤ 60	3.63	3.63	2.77	2.14		1.53
	> 60	3.63	3.63	2.88			
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	2.74	2.74	2.31	2.31	1.97	1.49
	> 60	2.76	2.76	2.31			

**Table 4-12: OPTIMA2 TLO MCPR_p Limits for NSS Insertion Times,
BOC to NEOC (34,977 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.97		1.46
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.03		1.49
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.30	1.96	1.47
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.09		1.46
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.14		1.49
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.30	1.96	1.47
	> 60	2.70	2.70	2.32			

**Table 4-13: OPTIMA2 TLO MCPR_p Limits for ISS Insertion Times,
BOC to NEOC (34,977 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.97		1.46
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.03		1.49
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.31	1.96	1.47
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.09		1.46
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.15		1.49
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.31	1.96	1.47
	> 60	2.70	2.70	2.32			

**Table 4-14: OPTIMA2 TLO MCPR_p Limits for TSSS Insertion Times,
BOC to NEOC (34,977 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.99		1.46
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.05		1.51
	> 60	3.40	3.40	2.75			
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.32	2.00	1.49
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.13		1.48
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.17		1.52
	> 60	3.50	3.50	2.82			
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.32	2.00	1.49
	> 60	2.70	2.70	2.32			

**Table 4-15: OPTIMA2 TLO MCPR_p Limits for NSS Insertion Times,
NEOC to EOFPLB (37,071 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.97		1.46
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.03		1.49
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.30	1.96	1.49
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.09		1.46
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.14		1.49
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.30	1.96	1.49
	> 60	2.70	2.70	2.32			

**Table 4-16: OPTIMA2 TLO MCPR_p Limits for ISS Insertion Times,
NEOC to EOFPLB (37,071 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.97		1.46
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.03		1.50
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.31	1.96	1.49
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.09		1.46
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.15		1.50
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.31	1.96	1.49
	> 60	2.70	2.70	2.32			

**Table 4-17: OPTIMA2 TLO MCPR_p Limits for TSSS Insertion Times,
NEOC to EOFPLB (37,071 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.99		1.49
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.05		1.52
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.32	2.00	1.52
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.13		1.49
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.17		1.52
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.32	2.00	1.52
	> 60	2.70	2.70	2.32			

**Table 4-18: OPTIMA2 TLO MCPRp Limits for NSS Insertion Times,
EOFPPLB to EOCLB (37,934 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.97		1.47
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.03		1.50
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.30	1.96	1.49
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.09		1.47
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.14		1.50
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.30	1.96	1.49
	> 60	2.70	2.70	2.32			

**Table 4-19: OPTIMA2 TLO MCPR_p Limits for ISS Insertion Times,
EOFLB to EOCLB (37,934 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.97		1.47
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.03		1.50
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.31	1.96	1.50
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.09		1.47
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.15		1.50
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.31	1.96	1.50
	> 60	2.70	2.70	2.32			

**Table 4-20: OPTIMA2 TLO MCPR_p Limits for TSSS Insertion Times,
EOFP_{LB} to EOCL_B (37,934 MWd/MTU CAVEX)**
(Reference 12)

Nominal FWT							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.46	2.46	2.08	1.99		1.49
	> 60	2.61	2.61	2.32			
TBVOOS	≤ 60	3.24	3.24	2.48	2.05		1.52
	> 60	3.40	3.40	2.75			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.46	2.46	2.32	2.32	2.00	1.53
	> 60	2.61	2.61	2.32			
FHOOS							
EOOS Condition	Core Flow (% rated)	Core Power (% rated)					
		0	25	≤ 38.5	> 38.5	70	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	2.61	2.61	2.18	2.13		1.49
	> 60	2.70	2.70	2.32			
TBVOOS	≤ 60	3.35	3.35	2.55	2.17		1.52
	> 60	3.50	3.50	2.82			
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	2.61	2.61	2.32	2.32	2.00	1.53
	> 60	2.70	2.70	2.32			

Table 4-21: ATRIUM 10XM SLO MCPR_p Limits for NSS Insertion Times, All Exposures
(Reference 12)

Nominal FWT					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.57	2.57	2.22	2.17	2.15
TBVOOS	3.52	3.52	2.68	2.17	2.15
TCV Slow Closure/ PLUOOS/PCOOS	2.57	2.57	2.33	2.32	2.19
FHOOS					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.76	2.76	2.33	2.17	2.15
TBVOOS	3.65	3.65	2.79	2.17	2.15
TCV Slow Closure/ PLUOOS/PCOOS	2.76	2.76	2.33	2.32	2.19

Table 4-22: ATRIUM 10XM SLO MCPR_p Limits for ISS Insertion Times, All Exposures
(Reference 12)

Nominal FWT					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.57	2.57	2.22	2.17	2.15
TBVOOS	3.52	3.52	2.68	2.17	2.15
TCV Slow Closure/ PLUOOS/PCOOS	2.57	2.57	2.33	2.32	2.19
FHOOS					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.76	2.76	2.33	2.17	2.15
TBVOOS	3.65	3.65	2.79	2.17	2.15
TCV Slow Closure/ PLUOOS/PCOOS	2.76	2.76	2.33	2.32	2.19

Table 4-23: ATRIUM 10XM SLO MCPR_p Limits for TSSS Insertion Times, All Exposures
(Reference 12)

Nominal FWT					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.57	2.57	2.22	2.17	2.15
TBVOOS	3.52	3.52	2.68	2.17	2.15
TCV Slow Closure/ PLUOOS/PCOOS	2.57	2.57	2.33	2.33	2.21
FHOOS					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.76	2.76	2.33	2.17	2.15
TBVOOS	3.65	3.65	2.79	2.17	2.15
TCV Slow Closure/ PLUOOS/PCOOS	2.76	2.76	2.33	2.33	2.21

Table 4-24: OPTIMA2 SLO M CPR_p Limits for NSS Insertion Times, All Exposures
(Reference 12)

Nominal FWT					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.48	2.48	2.19	2.19	2.17
TBVOOS	3.26	3.26	2.50	2.19	2.17
TCV Slow Closure/ PLUOOS/PCOOS	2.48	2.48	2.34	2.32	2.20
FHOOS					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.63	2.63	2.20	2.19	2.17
TBVOOS	3.37	3.37	2.57	2.19	2.17
TCV Slow Closure/ PLUOOS/PCOOS	2.63	2.63	2.34	2.32	2.20

Table 4-25: OPTIMA2 SLO MCPR_p Limits for ISS Insertion Times, All Exposures
(Reference 12)

Nominal FWT					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.48	2.48	2.19	2.19	2.17
TBVOOS	3.26	3.26	2.50	2.19	2.17
TCV Slow Closure/ PLUOOS/PCOOS	2.48	2.48	2.34	2.33	2.21
FHOOS					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.63	2.63	2.20	2.19	2.17
TBVOOS	3.37	3.37	2.57	2.19	2.17
TCV Slow Closure/ PLUOOS/PCOOS	2.63	2.63	2.34	2.33	2.21

Table 4-26: OPTIMA2 SLO MCPR_p Limits for TSSS Insertion Times, All Exposures
(Reference 12)

Nominal FWT					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.48	2.48	2.19	2.19	2.17
TBVOOS	3.26	3.26	2.50	2.19	2.17
TCV Slow Closure/ PLUOOS/PCOOS	2.48	2.48	2.34	2.34	2.23
FHOOS					
EOOS Condition (all include SLO)	Core Power (% rated)				
	0	25	≤ 38.5	> 38.5	50
Base/TCV Stuck Closed/MSIVOOS	2.63	2.63	2.20	2.19	2.17
TBVOOS	3.37	3.37	2.57	2.19	2.17
TCV Slow Closure/ PLUOOS/PCOOS	2.63	2.63	2.34	2.34	2.23

Table 4-27: ATRIUM 10XM and OPTIMA2 MCPR_f Limits
(Reference 12)

EOOS Condition*	Core Flow (% rated)	MCPR _f Limit
Base Case / FHOOS / PCOOS / PLUOOS / TCV Slow Closure / PLUOOS + PCOOS in TLO and SLO	0	1.70
	35	1.70
	108	1.19
Any Scenario** with One MSIVOOS	0	1.88
	35	1.88
	108	1.19
Any Scenario** with TBVOOS	0	1.90
	35	1.90
	108	1.35
Any Scenario** with 1 Stuck Closed TCV/TSV	0	1.70
	35	1.70
	108	1.19

* See Section 8 for further operating restrictions.

** "Any Scenario" implies any other combination of allowable EOOS conditions that is not otherwise covered by this table.

Note that the MCPR_f limits for any scenario with 1 stuck closed TCV/TSV are identical to base case MCPR_f limits. This is reflected in the thermal limit sets presented in Table 8-1.

5. Linear Heat Generation Rate

Technical Specification Sections 3.2.3, 3.4.1, and 3.7.7

The TMOL at rated conditions for the OPTIMA2 and ATRIUM 10XM fuel is established in terms of the maximum LHGR as a function of peak pellet (rod nodal) exposure. The LHGR limits for OPTIMA2 fuel are presented in Tables 5-1 through 5-8. The limits in Table 5-1 apply to OPTIMA2 lattices that do not require Gadolinia set down penalties. The limits in Tables 5-2 through 5-7 apply to OPTIMA2 lattices that do require Gadolinia set down penalties. The limits in Table 5-8 apply to the OPTIMA2 natural U blankets in lattices 81 and 89. The LHGR limits for ATRIUM 10XM fuel are presented in Table 5-9.

The power- and flow-dependent LHGR multipliers ($LHGRFAC_p$ and $LHGRFAC_f$) are applied directly to the LHGR limits to protect against fuel melting and overstraining of the cladding during an AOO (Reference 12). In all conditions, the margin to the LHGR limits is determined by applying the lowest multiplier from the applicable $LHGRFAC_p$ and $LHGRFAC_f$ multipliers for the power/flow statepoint of interest to the steady state LHGR limit (Reference 12).

$LHGRFAC_p$ and $LHGRFAC_f$ multipliers were established to support base case and all EOOS conditions for all Cycle 26 exposures and scram speeds. The $LHGRFAC_p$ multipliers for ATRIUM 10XM and OPTIMA2 are presented in Table 5-10 and Table 5-11, respectively. The $LHGRFAC_f$ multipliers for ATRIUM 10XM and OPTIMA2 are presented in Table 5-12 and Table 5-13, respectively.

Table 5-1: LHGR Limits for OPTIMA2 Lattices 137, 138, 139, 143, 144, 145, 146, 147, 148, 156, 157, 158, 159, 163, 164, 165, 166, 167
 (References 6, 8, 9, and 11)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	13.72
14,000	13.11
23,000	12.22
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-2 LHGR Limits for OPTIMA2 Lattices 135, 141
 (References 6 and 8)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	13.72
14,000	13.11
22,000	12.32
22,001	12.20
23,000	12.10
35,000	10.93
35,001	11.04
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-3: LHGR Limits for OPTIMA2 Lattices 131, 132, 133, 136, 140, 142
(References 6 and 8)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	13.72
14,000	13.11
14,001	12.85
23,000	11.98
46,000	9.75
46,001	9.95
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-4: LHGR Limits for OPTIMA2 Lattice 134
(References 6 and 8)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	13.72
14,000	13.11
14,001	12.72
23,000	11.85
35,000	10.71
35,001	11.04
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-5: LHGR Limits for OPTIMA2 Lattices 154, 161
(References 9 and 11)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	13.72
14,000	13.11
23,000	12.22
23,001	12.10
33,000	11.12
33,001	11.23
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-6: LHGR Limits for OPTIMA2 Lattices 150, 151, 152, 155, 160, 162
(References 9 and 11)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	13.72
14,000	13.11
14,001	12.85
23,000	11.98
46,000	9.75
46,001	9.95
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-7: LHGR Limits for OPTIMA2 Lattices 149, 153
(References 9 and 11)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	13.72
14,000	13.11
15,000	13.01
15,001	12.62
23,000	11.85
33,000	10.90
33,001	11.23
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-8: LHGR Limits for OPTIMA2 Lattices 81, 89
(References 6, 9, and 11)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	11.96
14,000	11.43
23,000	10.66
57,000	8.87
62,000	8.38
75,000	3.43

Table 5-9: LHGR Limits for ATRIUM 10XM
(Reference 12)

Peak Pellet Exposure (MWd/MTU)	LHGR Limit (kW/ft)
0	14.1
18,900	14.1
74,400	7.4

Table 5-10: ATRIUM 10XM LHGRFAC_p Multipliers
(Reference 12)

Nominal FWT								
EOOS Condition	Core Flow (% rated)	Core Power (%rated)						
		0	25	≤ 38.5	> 38.5	60	90	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	0.51	0.51	0.61	0.63	0.72	0.93	1.00
	> 60	0.51	0.51	0.61				
TBVOOS	≤ 60	0.39	0.39	0.54	0.63	0.72	0.93	0.96
	> 60	0.39	0.39	0.50				
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	0.51	0.51	0.61	0.63	0.72	0.93	1.00
	> 60	0.51	0.51	0.61				
FHOOS								
EOOS Condition	Core Flow (% rated)	Core Power (%rated)						
		0	25	≤ 38.5	> 38.5	60	90	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	0.47	0.47	0.55	0.63	0.72	0.93	1.00
	> 60	0.46	0.46	0.55				
TBVOOS	≤ 60	0.37	0.37	0.50	0.63	0.72	0.93	0.96
	> 60	0.36	0.36	0.48				
TCV Slow Closure/ PLUOOS/PCOOS	≤ 60	0.47	0.47	0.55	0.63	0.72	0.93	1.00
	> 60	0.46	0.46	0.55				

Table 5-11: OPTIMA2 LHGRFAC_p Multipliers
(Reference 12)

Nominal FWT										
EOOS Condition	Core Flow (% rated)	Core Power (%rated)								
		0	25	≤ 38.5	> 38.5	50	60	70	80	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	0.55	0.55	0.64	0.68	0.72	0.75		0.88	1.00
	> 60	0.55	0.55	0.64						
TBVOOS	≤ 60	0.42	0.42	0.53	0.68	0.72	0.75		0.84	0.98
	> 60	0.42	0.42	0.52						
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	0.55	0.55	0.64	0.64	0.69		0.74	0.88	1.00
	> 60	0.55	0.55	0.64						
FHOOS										
EOOS Condition	Core Flow (% rated)	Core Power (%rated)								
		0	25	≤ 38.5	> 38.5	50	60	70	80	100
Base/TCV Stuck Closed/MSIVOOS	≤ 60	0.51	0.51	0.59	0.64	0.71	0.75		0.85	1.00
	> 60	0.51	0.51	0.59						
TBVOOS	≤ 60	0.40	0.40	0.52	0.64	0.71	0.75		0.84	0.98
	> 60	0.40	0.40	0.49						
TCV Slow Closure/PLUOOS/PCOOS	≤ 60	0.51	0.51	0.59	0.64	0.69		0.74	0.85	1.00
	> 60	0.51	0.51	0.59						

Table 5-12: ATRIUM 10XM LHGRFAC_f Multipliers
(Reference 12)

Core Flow (% rated)	LHGRFAC _f
0.0	0.57
35.0	0.57
80.0	1.00
108.0	1.00

Table 5-13: OPTIMA2 LHGRFAC_f Multipliers
(Reference 12)

Core Flow (% rated)	LHGRFAC _f
0.0	0.27
20.0	0.43
40.0	0.60
60.0	0.80
80.0	1.00
100.0	1.00
108.0	1.00

6. Control Rod Block Setpoints

Technical Specification Sections 3.3.2.1 and 3.4.1

The Rod Block Monitor Upscale Instrumentation Setpoints are determined from the relationships shown in Table 6-1:

Table 6-1: Rod Block Monitor Upscale Instrumentation Setpoints
(Reference 3)

ROD BLOCK MONITOR UPSCALE TRIP FUNCTION	ALLOWABLE VALUE
Two Recirculation Loop Operation	$0.65 W_d + 55\%$
Single Recirculation Loop Operation	$0.65 W_d + 51\%$

W_d – percent of recirculation loop drive flow required to produce a rated core flow of 98.0 Mlb/hr.

The setpoint may be lower/higher and will still comply with the CRWE analysis because CRWE is analyzed unblocked (Reference 12).

7. Stability Protection Setpoints

Technical Specification Section 3.3.1.3

The OPRM PBDA Trip Settings are provided in Table 7-1.

Table 7-1: OPRM PBDA Trip Settings
(Reference 12)

PBDA Trip Amplitude Setpoint (Sp)	Corresponding Maximum Confirmation Count Setpoint (Np)
1.12	14

The PBDA is the only OPRM setting credited in the safety analysis as documented in the licensing basis for the OPRM system (Methodology 2).

The OPRM PBDA trip settings are based, in part, on the cycle specific OLMCPR and the power/flow dependent MCPR limits. Any change to the OLMCPR values and/or the power/flow dependent MCPR limits should be evaluated for potential impact on the OPRM PBDA trip settings.

The OPRM PBDA trip settings are applicable when the OPRM system is declared operable and the associated Technical Specifications are implemented.

8. Modes of Operation

The allowed modes of operation with combinations of EOOS are as described in Table 8-1. The EOOS conditions separated by “/” in these tables represent single EOOS conditions and not combinations of conditions.

Note that the following EOOS options have operational restrictions: all SLO, all EOOS options with 1 TCV/TSV stuck closed, and MSIVOOS. See Table 8-2 for specific restrictions.

Table 8-1: Modes of Operation
(Reference 12)

EOOS Option	Thermal Limit Set
Base Case	BASE CASE > TLO or SLO > Nominal FWT or FHOOS
TBVOOS	TBVOOS > TLO or SLO > Nominal FWT or FHOOS
1 TCV/TSV Stuck Closed	BASE CASE > TLO or SLO > Nominal FWT or FHOOS
One MSIVOOS	MSIVOOS > TLO or SLO > Nominal FWT or FHOOS
TCV Slow Closure	PLUOOS/TCV SLOW C > TLO or SLO > Nominal FWT or FHOOS
PLUOOS	PLUOOS/TCV SLOW C > TLO or SLO > Nominal FWT or FHOOS
PCOOS	PLUOOS/TCV SLOW C > TLO or SLO > Nominal FWT or FHOOS
PLUOOS and 1 TCV/TSV Stuck Closed	PLUOOS/TCV SLOW C > TLO for Nominal FWT or FHOOS > SLO for Nominal FWT*
PCOOS and PLUOOS	PLUOOS/TCV SLOW C > TLO for Nominal FWT or FHOOS > SLO for Nominal FWT*
PCOOS and 1 TCV/TSV Stuck Closed	PLUOOS/TCV SLOW C > TLO for Nominal FWT or FHOOS > SLO for Nominal FWT*

* FHOOS cannot be applied to SLO for the cases of PLUOOS and 1 TCV/TSV Stuck Closed, for the case of PCOOS and PLUOOS, and for the case of PCOOS and 1 TCV/TSV Stuck Closed.

Common Notes:

1. All modes are allowed for operation at MELLLA, ICF (up to 108% rated core flow but subject to the restrictions in Section 2), and coastdown subject to the power restrictions in Table 8-2 (Reference 12). The licensing analysis supports full power operation to EOCLB (37,934 MWd/MTU CAVEX). Note that this value includes coastdown, where full power operation is not expected. The minimum coastdown power level cannot exceed 40% per Reference 1. Each OOS Option may be combined with each of the following conditions (Reference 12):
 - a. Up to 40% of the TIP channels OOS or the equivalent number of TIP channels, using the guidance in Reference 4 for startup with TIP machines OOS
 - b. Up to 50% of the LPRMs OOS
 - c. An LPRM calibration frequency of up to 2500 EFPH
2. Nominal FWT results are valid for application within a +10°F/-30°F temperature band around the nominal FWT curve (Reference 12). For operation outside of nominal FWT, a FWT reduction of between 30°F and 120°F is supported for all FHOOS conditions listed in Table 8-1 for cycle operation through EOCLB (Reference 12). At lower power levels, the feedwater temperature reduction is less (Reference 12). Per Reference 5, there is a restriction which requires that for a FWT reduction greater than 100°F, operation needs to be restricted to less than the 100% rod line. For a feedwater temperature reduction of between 30°F and 120°F, the FHOOS limits should be applied.
3. The base case and EOOS limits and multipliers support operation with 8 of 9 turbine bypass valves operational (i.e., one bypass valve out of service) with the exception of the TBVOOS condition in which all bypass valves are inoperable (Reference 12). Use of the response curve in TRM Appendix H supports operation with any single TBV OOS. TRM Appendix H facilitates analysis with one valve OOS in that the capacity at 0.5 seconds from start of TSV closure is equivalent to the total capacity with eight out of the nine valves in service (References 13 and 15). The analyses also support Turbine Bypass flow of 29.8% of vessel rated steam flow (References 13 and 15), equivalent to one TBV OOS (or partially closed TBVs equivalent to one closed TBV), if the assumed opening profile for the remaining TBVs is met. If the opening profile is NOT met, or if the TBV system CANNOT pass an equivalent of 29.8% of vessel rated steam flow, utilize the TBVOOS condition.
4. TBVOOS assumes that ALL the TBVs do not trip open on TCV fast closure or TSV closure and that ALL the TBVs are not capable of opening via the pressure control system (Reference 14). Steam relief capacity is defined in References 13 and 15.
5. Between 25% and 50% of rated thermal power, the PLUOOS/TCV Slow Closure thermal limit set ensures that the AOO acceptance criteria are met for a load rejection event if the 86 Device is OOS (Reference 12). Therefore, use the PLUOOS/TCV Slow Closure thermal limit set between 25% and 50% of rated thermal power if the 86 Device is OOS.

Table 8-2: Core Thermal Power Restriction for OOS Conditions
(Reference 12)

EOOS Condition	Core Flow (% of Rated)	Core Thermal Power (% of Rated Power)	Rod Line (%)
1 TCV/TSV Stuck Closed PCOOS and 1 TCV/TSV Stuck Closed PLUOOS and 1 TCV/TSV Stuck Closed	N/A	< 75	< 80
One MSIVOOS	N/A	< 75	N/A
SLO	< 51	< 50	N/A

All requirements for all applicable conditions listed in Table 8-2 MUST be met.

9. Methodology

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

1. GE Topical Report NEDE-24011-P-A, Revision 15, "General Electric Standard Application for Reactor Fuel (GESTAR)," September 2005.
2. GE Topical Report NEDO-32465-A, Revision 0, "Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications," August 1996.
3. Westinghouse Topical Report CENPD-300-P-A, Revision 0, "Reference Safety Report for Boiling Water Reactor Reload Fuel," July 1996.
4. Westinghouse Report WCAP-15682-P-A, Revision 0, "Westinghouse BWR ECCS Evaluation Model: Supplement 2 to Code Description, Qualification and Application," April 2003.
5. Westinghouse Report WCAP-16078-P-A, Revision 0, "Westinghouse BWR ECCS Evaluation Model: Supplement 3 to Code Description, Qualification and Application to SVEA-96 Optima2 Fuel," November 2004.
6. Westinghouse Report WCAP-16865-P-A, Revision 1, "Westinghouse BWR ECCS Evaluation Model Updates: Supplement 4 to Code Description, Qualification and Application," October 2011.
7. Westinghouse Report WCAP-16081-P-A, Revision 0, "10x10 SVEA Fuel Critical Power Experiments and CPR Correlation: SVEA-96 Optima2," March 2005.
8. Westinghouse Topical Report WCAP-15836-P-A, Revision 0, "Fuel Rod Design Methods for Boiling Water Reactors – Supplement 1," April 2006.
9. Westinghouse Topical Report WCAP-15942-P-A, Revision 0, "Fuel Assembly Mechanical Design Methodology for Boiling Water Reactors, Supplement 1 to CENPD-287," March 2006.
10. Westinghouse Topical Report CENPD-390-P-A, Revision 0, "The Advanced PHOENIX and POLCA Codes for Nuclear Design of Boiling Water Reactors," December 2000.
11. Exxon Nuclear Company Report XN-NF-81-58(P)(A), Revision 2 and Supplements 1 and 2, "RODEX2 Fuel Rod Thermal-Mechanical Response Evaluation Model," March 1984.
12. Advanced Nuclear Fuels Corporation Report ANF-89-98(P)(A), Revision 1 and Supplement 1, "Generic Mechanical Design Criteria for BWR Fuel Designs," May 1995.
13. Siemens Power Corporation Report EMF-85-74(P), Revision 0 Supplement 1 (P)(A) and Supplement 2 (P)(A), "RODEX2A (BWR) Fuel Rod Thermal-Mechanical Evaluation Model," February 1998.
14. AREVA NP Topical Report BAW-10247PA, Revision 0, "Realistic Thermal-Mechanical Fuel Rod Methodology for Boiling Water Reactors," February 2008.
15. Exxon Nuclear Company Topical Report XN-NF-80-19(P)(A), Volume 1 Revision 0 and Supplements 1 and 2, "Exxon Nuclear Methodology for Boiling Water Reactors – Neutronic Methods for Design and Analysis," March 1983.

16. Exxon Nuclear Company Topical Report XN-NF-80-19(P)(A), Volume 4 Revision 1, "Exxon Nuclear Methodology for Boiling Water Reactors: Application of the ENC Methodology for BWR Reloads," June 1986.
17. Exxon Nuclear Company Topical Report XN-NF-80-19(P)(A), Volume 3 Revision 2, "Exxon Nuclear Methodology for Boiling Water Reactors, THERMEX: Thermal Limits Methodology Summary Description," January 1987.
18. Siemens Power Corporation Topical Report EMF-2158(P)(A), Revision 0, "Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2," October 1999.
19. Siemens Power Corporation Report EMF-2245(P)(A), Revision 0, "Application of Siemens Power Corporation's Critical Power Correlations to Co-Resident Fuel," August 2000.
20. AREVA NP Report EMF-2209(P)(A), Revision 3, "SPCB Critical Power Correlation," September 2009.
21. AREVA Topical Report ANP-10298P-A, Revision 1, "ACE/ATRIUM 10XM Critical Power Correlation," March 2014.
22. AREVA NP Topical Report ANP-10307PA, Revision 0, "AREVA MCPR Safety Limit Methodology for Boiling Water Reactors," June 2011.
23. Exxon Nuclear Company Report XN-NF-84-105(P)(A), Volume 1 Revision 0 and Volume 1 Supplements 1 and 2, "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis," February 1987.
24. Advanced Nuclear Fuels Corporation Report ANF-913(P)(A), Volume 1 Revision 1 and Volume 1 Supplements 2, 3, and 4, "COTRANSA2: A Computer Program for Boiling Water Reactor Transient Analyses," August 1990.
25. Framatome ANP Report EMF-2361(P)(A), Revision 0, "EXEM BWR-2000 ECCS Evaluation Model," May 2001.
26. Siemens Power Corporation Report EMF-2292(P)(A), Revision 0, "ATRIUM™-10: Appendix K Spray Heat Transfer Coefficients," September 2000.
27. Framatome ANP Topical Report ANF-1358(P)(A), Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water Reactors," September 2005.
28. Siemens Power Corporation Topical Report EMF-CC-074(P)(A), Volume 4 Revision 0, "BWR Stability Analysis: Assessment of STAIF with Input from MICROBURN-B2," August 2000.

10. References

1. Exelon Generation Company, LLC, Docket No. 50-237, Dresden Nuclear Power Station, Unit 2 Renewed Facility Operating License, License No. DPR-19.
2. Exelon Technical Specifications for Dresden 2 and 3, Table 3.1.4-1, "Control Rod Scram Times."
3. Exelon Design Analysis GE DRF C51-00217-01, "Instrument Setpoint Calculation Nuclear Instrumentation Rod Block Monitor," July 30, 2012.
4. FANP Letter, NJC:04:031/FAB04-496, "Startup with TIP Equipment Out of Service," April 20, 2004. (Exelon EC 348897-000)
5. Exelon Letter, NF-MW:02-0081, "Approval of GE Evaluation of Dresden and Quad Cities Extended Final Feedwater Temperature Reduction," Carlos de la Hoz to Doug Wise and Alex Misak, August 27, 2002.
6. Westinghouse Document NF-BEX-13-66, Revision 0, "Bundle Design Report for Dresden 2 Cycle 24," May 3, 2013.
7. Westinghouse Document NF-BEX-13-111-NP, Revision 0, "Dresden Nuclear Power Station Unit 2 Cycle 24 MAPLHGR Report," September 2013.
8. Westinghouse Document NF-BEX-15-12, Revision 0, "Linear Heat Generation Rate Limits for Fresh and Once-Burned Fuel Loaded in Dresden Unit 2 Cycle 24," January 14, 2015.
9. Westinghouse Document NF-BEX-15-72, Revision 0, "Bundle Design Report for Dresden 2 Cycle 25," April 17, 2015.
10. Westinghouse Document NF-BEX-15-101-NP, Revision 0, "Dresden Nuclear Power Station Unit 2 Cycle 25 MAPLHGR Report," September 2015.
11. Westinghouse Document NF-BEX-15-157, Revision 0, "Linear Heat Generation Rate Limits for Fresh Fuel Loaded in Dresden Unit 2 Cycle 25," October 28, 2015.
12. AREVA Report ANP-3605P, Revision 0, "Dresden Unit 2 Cycle 26 Reload Safety Analysis," September 2017.
13. Exelon TODI ES1700005, Revision 1, "Dresden Unit 2 Cycle 26 Plant Parameters Document," March 17, 2017.
14. Exelon TODI ES1500011, Revision 0, "Equipment Out of Service Description for Transition to AREVA Fuel – Dresden," May 20, 2015.
15. Exelon TODI ES1700017, Revision 0, "AREVA Input Request for Dresden Units 2 and 3 Reload Analysis," August 29, 2017.