

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8212170179 DOC. DATE: 82/12/09 NOTARIZED: NO DOCKET #
 FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 HUNTER, R.S. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Application for amend to License DPR-74, consisting of proposed changes to Tech Specs allowing Cycle 4 operation w/Exxon fuel at reactor thermal power level of 3,411 Mwt.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+20
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
	NRR	ORB1 BC 01	7	7				
INTERNAL:	ELD/HDS3		1	0	NRR/DL DIR		1	1
	NRR/DL/ORAB		1	0	NRR/DSI/RAB		1	1
	<u>REG FILE</u>	04	1	1	RGN3		1	1
EXTERNAL:	ACRS	09	6	6	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 21



(BIBO) 1008 1008 1008 1008 1008 1008 1008 1008 1008 1008

REGULATED POWER SUPPLY: The power supply is a regulated power supply with a maximum output of 100W and a regulation of 0.1%.

The power supply is a regulated power supply with a maximum output of 100W and a regulation of 0.1%. It is designed to provide a constant output voltage over a wide range of load conditions.

The power supply is a regulated power supply with a maximum output of 100W and a regulation of 0.1%. It is designed to provide a constant output voltage over a wide range of load conditions.

The power supply is a regulated power supply with a maximum output of 100W and a regulation of 0.1%. It is designed to provide a constant output voltage over a wide range of load conditions.

COILS	COILS	COILS	COILS	COILS	COILS	COILS	COILS
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1

INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

December 9, 1982
AEP:NRC:0637G

Donald C. Cook Nuclear Plant, Unit No. 2
Docket No. 50-316
License No. DPR-74
ECCS ANALYSIS TECHNICAL SPECIFICATION

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Denton:

Attachments 1 and 2 to this letter contain the remaining Unit 2 Appendix A Technical Specification (T/S) changes necessary to permit Cycle 4 operation with Exxon Nuclear Company (ENC) fuel at the reactor thermal power level of 3411 MWt. Attachment 1 contains a description of the proposed T/S changes. Attachment 2 contains the revised T/S pages. All changes from the current Unit 2 T/S are indicated by a vertical line on the right hand margin of the page. The T/S changes contained in Attachment 2 to this letter have been reviewed and approved by the Plant Nuclear Safety Review Committee (PNSRC) and by the AEPSC Nuclear Safety and Design Review Committee (NSDRC).

As noted in our letter No. AEP:NRC:0637E dated September 30, 1982, the proposed T/S changes have been updated to reflect an F_0 value of 2.04, obtained from the Emergency Core Cooling System (ECCS) reanalysis utilizing maximum safeguards, as modeled by ENC's evaluation model EXEM/PWR. This reanalysis is summarized in ENC's Report No. XN-NF-82-35, Supplement 1, "Donald C. Cook Unit 2 Cycle 4 Limiting Break LOCA-ECCS Analysis Using EXEM/PWR," dated November 1982.

ENC has recently transmitted to the NRC twenty-five (25) copies of Reports No. XN-NF-82-35, Supplement 1 ("Donald C. Cook Unit 2 Cycle 4 Limiting Break LOCA-ECCS Analysis Using EXEM/PWR"), No. XN-NF-82-32, Revision 1 ("Plant Transient Analysis for the Donald C. Cook Unit 2 Reactor at 3425 MWt"), and No. XN-NF-82-90 ("Donald C. Cook Unit 2 Potential Radiological Consequences of Incidents Involving High Exposure Fuel"). We request incorporation of the above-mentioned reports into Docket No. 50-316 for Unit No. 2 of the Donald C. Cook Nuclear Plant.

8212170179 821209
PDR ADDCK 05000316
P PDR

Asol



THE UNIVERSITY OF CHICAGO
LIBRARY

Payment for NRC processing of this information has previously accompanied our "Application for Cycle 4 Reload and Uprate License Amendment" contained in our letter No. AEP:NRC:0637A wherein we interpreted this application for a license amendment to constitute a Class IV Amendment as defined in 10 CFR 170.22.

This document has been prepared following Corporate Procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



R. S. Hunter
Vice President

cc: John E. Dolan
M. P. Alexich
R. W. Jurgensen
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Charnoff
NRC Resident Inspector at Cook Plant - Bridgman

