

MAY 10 1983

Docket Nos. 50-315  
and 50-316

Mr. John Dolan, Vice President  
Indiana and Michigan Electric Company  
Post Office Box 18  
Bowling Green Station  
New York, New York 10004

DISTRIBUTION  
Docket File ✓  
NRC PDR  
Local PDR  
ORB 1 File  
D. Eisenhut  
OELD  
E. Jordan  
D. Wigginton  
C. Parrish  
NSIC  
J. Taylor  
ACRS (10)  
E. Conner

Dear Mr. Dolan:

We have completed our review of the information provided by the Indiana and Michigan Electric Company (IMECo) letters dated November 5, 1982 and December 14, 1982, on the TMI Action Items II.F.1.1 and II.F.1.2 on particulate monitors. That information resolved our concerns on deviations and is acceptable.

Our Confirmatory Order on March 14, 1983, listed II.F.1.2 schedule of completion as April 1982, however, in the IMECo letter dated April 29, 1983, the system described as in place to meet the intent of II.F.1.2 is a separate system from the one we reviewed and portions are listed as temporary. While we may agree that the "separate" system is sufficient to satisfy II.F.1.2 requirements, we believe you should correct the problems with the moisture in sampling lines and establish your original system as the primary system.

The IMECo letter dated April 29, 1983, also brought to our attention the error on II.F.1.3 schedule. Since this item is also not complete and we do not have the current schedules for either II.F.1.2 or II.F.1.3, IMECo is requested to provide this information, along with sufficient details and justification, within two weeks of receipt of this letter.

Sincerely,

Original signed by:  
S. A. Varga

Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
Division of Licensing

cc: See next page

8305180838 830510  
PDR ADDCK 05000315  
P PDR

OFFICE	ORB 1	ORB #4	ORB 1				
SURNAME	DWigginton/rs	JFSuermann	SVarga				
DATE	5/6/83	5/9/83	5/10/83				



Mr. John Dolan  
Indiana and Michigan Electric Company

cc: Mr. M. P. Alexich  
Assistant Vice President  
for Nuclear Engineering  
American Electric Power  
Service Corporation  
2 Broadway  
New York, New York 10004

Gerald Charnoff, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

W. G. Smith Jr., Plant Manager  
Donald C. Cook Nuclear Plant  
P. O. Box 458  
Bridgman, Michigan 49106

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
7700 Red Arrow Highway  
Stevensville, Michigan 49127

William J. Scanlon, Esquire  
2034 Pauline Boulevard  
Ann Arbor, Michigan 48103

The Honorable Tom Corcoran  
United States House of Representatives  
Washington, D. C. 20515

James G. Keppler  
Regional Administrator - Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137