

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8305310088. DOC. DATE: 83/05/27 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 : 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 HUNTER, R.S. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Discusses plant-specific evaluation of relief & safety valves & related discharge piping analysis per 820709 ltr. Teledyne analysis revealed that discharge piping sys will be overloaded & supports stressed beyond allowable limits.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL
	NRR	ORB1 BC 01	7	7					
INTERNAL:	ELD/HDS3		1	0	IE/DEPER DIR	33	1		
	IE/DEPER/EPB		3	3	IE/DEPER/IRB		1		
	NRR PAWLSON, W.		1		NRR/DHFS/DEPY29		1		
	NRR/DL DIR	14	1		NRR/DL/ADL	16	1		
	NRR/DL/ORAB	18	3	3	NRR/DSI/ADRS	27	1		
	NRR/DSI/AEB		1	1	NRR/DSI/ASB		1		
	NRR/DSI/RAB		1	1	NRR/DST DIR	30	1		
	REG FILE	04	1	1	RGN3		1		
EXTERNAL:	ACRS	34	10	10	INPO, J. STARNES		1		
	LPDR	03	2	2	NRC PDR	02	1		
	NSIC	05	1		NTIS		1		

TOTAL NUMBER OF COPIES REQUIRED: LTR 43 ENCL 42

INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

May 27, 1983
AEP:NRC:0585F

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
NUREG-0737, ITEM II.D.1
PWR RELIEF AND SAFETY VALVE TEST PROGRAM

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Reference: (1) Letter No. AEP:NRC:0585C dated July 9, 1982
(2) Letter No. AEP:NRC:0585E dated February 25, 1983
(3) Letter from Mr. S. A. Varga, NRC dated March 14, 1983

Dear Mr. Denton:

This letter concerns the plant specific evaluation of the Relief and Safety Valves and the related discharge piping analysis for the Donald C. Cook Nuclear Plant detailed in Reference (1). Teledyne Engineering Services (TES) is performing the analyses of the as-built piping system using the thermal-hydraulic code RELAP-5/MOD 1. While we have not yet received the final report, early notification from TES indicates that during the loop seal water discharge, the discharge piping system will be overloaded and the piping/supports will be stressed beyond the allowable stress limits. To eliminate this concern AEPSC proposes to drain the water in the Safety Valve loop seals in both Units at their next respective refueling outages. The preliminary analysis show that the thermal-hydraulic forces are substantially lower for the case when there is no water in the loop seal. The qualification of the as-built piping system will be performed without the loop seal water and, if necessary, the supports will be modified. The method to perform the seal water drainage is currently being evaluated.

In reference (2) we committed to submit the plant Specific Evaluation Report for the Donald C. Cook Nuclear Plant by July 1, 1983.

8305310088 830527
PDR ADOCK 05000315
P PDR

A046
1/0

Faint, illegible text at the top of the page, possibly a header or title.

Second block of faint, illegible text, appearing as a separate paragraph.

Third block of faint, illegible text, continuing the document's content.

Fourth block of faint, illegible text, possibly a transition or separator.

A large, dense block of faint, illegible text, likely the main body of the document.


Fifth block of faint, illegible text, possibly a concluding paragraph or footer.

Final block of faint, illegible text at the bottom of the page.

This date was incorporated into the confirmatory order attached to Reference (3). We are hereby requesting an extension to the submittal date of the Plant Specific Evaluation of the Relief and Safety Valves and associated piping system from July 1, 1983, to September 15, 1983, to perform the additional work which we now anticipate as being required to qualify the discharge piping system.

This document has been prepared following Corporate Procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



R. S. Hunter
Vice President

/md

cc: John E. Dolan
M. P. Alexich
R. W. Jurgensen
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Charnoff
NRC Resident Inspector at Cook Plant - Bridgman

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Small block of faint text, possibly a sub-header or a specific section title.

Small block of faint text, possibly a signature or a reference.

Small block of faint text on the right side of the page, possibly a list or a set of notes.

Small block of faint text at the bottom center of the page, possibly a footer or a concluding statement.