

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8401130292 DOC.DATE: 84/01/06 NOTARIZED: NO DOCKET #  
 FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH.NAME AUTHOR AFFILIATION  
 ALEXICH,P. Indiana & Michigan Electric Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 DENTON,H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Responds to Generic Ltr 83-41, "Fast Cold Starts of Diesel Generators." Maint of preheat & prelubrication eliminates engine stresses caused by cold starts.Fast start engine stress mitigated only by reducing frequency of starts.

DISTRIBUTION CODE: A056S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3  
 TITLE: OR Submittal:Fast Cold Starts of Diesel Generators GL-83-41

NOTES:

	RECIPIENT			RECIPIENT		
	ID CODE/NAME	COPIES		ID CODE/NAME	COPIES	
	NRR ORB1 BC 01	LTTR	ENCL		LTTR	ENCL
INTERNAL:	AEOD 07	1	1	IE/DEPER/EAB 08	1	1
	NRR/DL/ORAB 09	1	1	NRR/DSI/PSB 10	1	1
	NRR/DST/SPEB 11	1	1	<del>REG-FILE</del> 04	1	1
	RES/DRA/RRB 12	1	1	RGN3 06	1	1
EXTERNAL:	ACRS 13	6	6	LPDR 03	2	2
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 22

... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

Notes:

RECIPER IN CODE UNIT	COPPER LIP	RECEPT TO CANTAWAY	UNIT	INTERNAL	
				NO	YES
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...
...	...	...	...	...	...

# INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631  
COLUMBUS, OHIO 43216

January 6, 1984

AEP:NRC:0862

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
FAST COLD STARTS OF DIESEL GENERATORS  
(Generic Letter 83-41)

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Denton:

This letter is in response to your request for information in Generic Letter 83-41, "Fast Cold Starts of Diesel Generators". In response to item (1) of that letter please note that we do not start our diesels in the "cold" condition. Nevertheless, we have had several fast starts over the specified period, principally due to surveillance/technical requirements. These starts are listed on Table 1, by category as you requested.

In response to Item (2), our assessment of fast and cold starts is presented below.

The diesel engines at D. C. Cook Plant are always started fast from the Control Room, except for maintenance operations following certain inspections or overhaul. (These "slow" starts are not included in Table 1.) However, the diesel engines are never started entirely cold or unlubricated because of the following preventive maintenance policies. 1) The cooling jacket water is heated to about 160F and circulated through the engine to maintain the engine at its approximate operating temperature. 2) The crankshaft and lower engine is continuously pressure lubricated by oil maintained at about 140F. and 3) The upper valve gear assembly is intermittently lubricated to assure an ample supply of lube oil for fast starting of the engine.

The diesel engine manufacturer recommends operation of the auxiliary lube oil pump for several minutes before starting the diesel engine and a slow and controlled acceleration with limited fuel injection to rated speed if maximum service life is to be expected from the engine. Operation of unloaded diesel engines for extended periods of time is not recommended by the manufacturers. This is an additional reason for not starting the engines unless necessary.

8401130292 840106  
PDR ADOCK 05000315  
PDR

A056  
11

1. The first part of the document discusses the general principles of the proposed system. It outlines the objectives and the scope of the project, which is to develop a comprehensive framework for the management of resources in the field of environmental protection. This section also touches upon the importance of sustainable development and the role of government in ensuring that natural resources are used responsibly.

2. The second part of the document provides a detailed description of the proposed system's architecture. It details the various components and their interactions, including data collection, processing, and reporting mechanisms. This section is crucial for understanding how the system will be implemented and how it will integrate with existing infrastructure.

3. The third part of the document discusses the implementation and evaluation of the proposed system. It outlines the steps involved in the deployment of the system and the methods used to assess its effectiveness. This section also addresses potential challenges and provides strategies to overcome them.

4. The fourth part of the document discusses the future work and conclusions. It identifies areas for further research and development, as well as the overall impact of the proposed system. The conclusion emphasizes the need for continued collaboration between government, academia, and industry to achieve the goals of sustainable development and environmental protection.

5. The fifth part of the document discusses the funding and resources required for the proposed system. It outlines the budget and the sources of funding, including government grants, private industry contributions, and international organizations. This section also discusses the human resources and expertise needed for the successful implementation of the system.

The diesel fuel injector is timed to inject before top dead center to allow time for ignition to occur when the piston is at top dead center while operating at rated speed. The expanding products of combustion force the piston down at a time when the crankshaft has turned far enough to be rotated by the downward force. During starting, the crankshaft rotation is much slower than rated and the fuel injection timing is early enough to permit combustion to occur while the piston is still approaching top dead center (up stroke). This, coupled with the injection of a full fuel charge to achieve maximum acceleration for fast starting, results in the piston being forced down by the combustion of the full fuel charge at the same time the piston is being forced up by the engine cranking power. This produces more stress on the connecting rod bearing and main bearing at the crankshaft than any other operating condition. Therefore, even though we run the auxiliary lube oil pump continuously, numerous fast starts will result in less service life than can be achieved in following the manufacturers slow and controlled acceleration recommendations.


During the initial reliability tests of the Unit 1 diesel generators we found that intermittent lubrication was inadequate to prevent engine crankshaft, bedplate and connecting rod bearing damage. One engine was badly damaged. The engine was rebuilt and the lubrication system revised to provide continuous lubrication for the crankshaft and connecting rod bearings.

We believe that by maintaining pre-heat and pre-lubrication we have eliminated the engine stresses caused by cold starts as much as possible. The stresses caused by "fast starts" can only be mitigated by reducing the frequency of starts.

The monthly surveillance tests provide the necessary exercise to assure operability. In addition, the refueling surveillance tests demonstrate the ability of the engines to perform their intended function. The remaining surveillance tests such as those required to demonstrate operability of the redundant engine when one engine is removed from service or one offsite power source is de-energized are examples of requirements that could be deleted without deleteriously affecting the Diesel Generator Safety function.

This letter has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,

  
M. P. Alexich  
Vice President

MPA/cam

cc: John E. Dolan  
W. G. Smith, Jr. - Bridgman  
R. C. Callen  
G. Charnoff  
E. R. Swanson, NRC Resident Inspector - Bridgman

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Second block of faint, illegible text.

Third block of faint, illegible text.

Fourth block of faint, illegible text.

Fifth block of faint, illegible text.

Yours truly,  
[Illegible signature]

[Illegible address or contact information]

[Illegible text in the bottom right corner, possibly a footer or reference code]

TABLE 1

## NUMBER OF FAST DIESEL ENGINE STARTS

December 1, 1982 thru December 1, 1983

Number of Fast Starts <sup>(1)</sup>

REASON FOR START/TEST	UNIT 1		UNIT 2		TOTAL
	Generators		Generators		
	AB	CD	AB	CD	
SURVEILLANCE					
Monthly Surveillance	11	12	12	12	47
18 Month Surveillance	4	4	7	7	22
Other Tech Spec Requirements	11	8	19	21	59
MAINTENANCE					
Maintenance Runs	10	3	5	7	25
Post Maint. Runs To Prove Operability	5	4	1	2	12
ACTUAL DEMAND <sup>(2)</sup>	0	3	2	4	9
TOTAL STARTS	<u>41</u>	<u>34</u>	<u>46</u>	<u>53</u>	<u>174</u>

(1) The diesel engines at D. C. Cook Plant are never started cold.

(2) The D. C. Cook Plant did not experience Offsite Power Loss. Actual Demand was caused by Safety Injection Initiation or bus switching.

THE UNIVERSITY OF CHICAGO  
DEPARTMENT OF CHEMISTRY  
5301 S. DICKINSON DRIVE  
CHICAGO, ILLINOIS 60637

TO: [Illegible Name]  
FROM: [Illegible Name]  
SUBJECT: [Illegible Subject]

[Illegible text block containing several lines of text, possibly a letter or report header]

[Illegible text block at the bottom of the page, possibly a signature or footer]



January 5, 1984

DISTRIBUTION  
~~Docket File~~  
ORB#1Rdg  
CParrish

DOCKET NO(S). 50-315/316

Mr. John Dolan, Vice President  
Indiana and Michigan Electric Company  
E/oOAmBrican Electric Power Service Corporation  
1 Riverside Plaza  
Columbia, Ohio 43215

SUBJECT:

DONALD C. COOK NUCLEAR PLANT UNITS 1 AND 2

The following documents concerning our review of the subject facility are transmitted for your information.


- Notice of Receipt of Application.
- Draft/Final Environmental Statement, dated \_\_\_\_\_.
- Notice of Availability of Draft/Final Environmental Statement, dated \_\_\_\_\_.
- Safety Evaluation Report, or Supplement No. \_\_\_\_\_, dated \_\_\_\_\_.
- Notice of Hearing on Application for Construction Permit.
- Notice of Consideration of Issuance of Facility Operating License.
- Application and Safety Analysis Report, Volume \_\_\_\_\_.
- Amendment No. \_\_\_\_\_ to Application/SAR dated \_\_\_\_\_.
- Construction Permit No. CPPR- \_\_\_\_\_, Amendment No. \_\_\_\_\_, dated \_\_\_\_\_.
- Facility Operating License No. \_\_\_\_\_, Amendment No. \_\_\_\_\_, dated \_\_\_\_\_.
- Order Extending Construction Completion Date, dated \_\_\_\_\_.
- Other (Specify) Monthly Notice covering period through December 21, 1983.  
Expiration date for hearing requests and comments January 20, 1984.

Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosures:  
As stated

CC: w/enclosure

OFFICE▶	ORB#1;DL CP						
SURNAME▶	CParrish:PS						
DATE▶	1/5/84						





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

January 5, 1984

DOCKET NO(S). 50-315/316

Mr. John Dolan, Vice President  
Indiana and Michigan Electric Company  
c/o American Electric Power Service Corporation  
1 Riverside Plaza  
Columbus, Ohio 43215

SUBJECT:

DONALD C. COOK NUCLEAR PLANT UNITS 1 AND 2

The following documents concerning our review of the subject facility are transmitted for your information.

- Notice of Receipt of Application.
- Draft/Final Environmental Statement, dated \_\_\_\_\_.
- Notice of Availability of Draft/Final Environmental Statement, dated \_\_\_\_\_.
- Safety Evaluation Report, or Supplement No. \_\_\_\_\_, dated \_\_\_\_\_.
- Notice of Hearing on Application for Construction Permit.
- Notice of Consideration of Issuance of Facility Operating License.
- Application and Safety Analysis Report, Volume \_\_\_\_\_.
- Amendment No. \_\_\_\_\_ to Application/SAR dated \_\_\_\_\_.
- Construction Permit No. CPPR- \_\_\_\_\_, Amendment No. \_\_\_\_\_, dated \_\_\_\_\_.
- Facility Operating License No. \_\_\_\_\_, Amendment No. \_\_\_\_\_, dated \_\_\_\_\_.
- Order Extending Construction Completion Date, dated \_\_\_\_\_.
- Other (Specify) Monthly Notice covering period through December 21, 1983.  
Expiration date for hearing requests and comments January 20, 1984.

*Clarrissal*  
Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosures:  
As stated

cc: w/enclosure

Indiana and Michigan Electric Company

Donald C. Cook Nuclear  
Plant, Units 1 and 2

cc: Mr. M. P. Alexich  
Vice President  
Nuclear Engineering  
American Electric Power Service  
Corporation  
1 Riverside Plaza  
Columbus, Ohio 43215

Mr. William R. Rustem (2)  
Office of the Governor  
Room 1 - Capitol Building  
Lansing, Michigan 48913

Mr. Wade Schuler, Supervisor  
Lake Township  
Baroda, Michigan 49101

W. G. Smith, Jr., Plant Manager  
Donald C. Cook Nuclear Plant  
Post Office Box 458  
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
7700 Red Arrow Highway  
Stevensville, Michigan 49127

Gerald Charnoff, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, DC 20036

Honorable Jim Catania, Mayor  
City of Bridgman, Michigan 49106

U.S. Environmental Protection Agency  
Region V Office  
ATTN: EIS COORDINATOR  
230 South Dearborn Street  
Chicago, IL 60604

Maurice S. Reizen, M.D.  
Director  
Department of Public Health  
Post Office Box 30035  
Lansing, Michigan 48109

The Honorable Tom Corcoran  
United States House of Representatives  
Washington, DC 20515

James G. Keppler  
Regional Administrator - Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137