

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8412030401 DOC. DATE: 84/11/28 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M. P. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director.

SUBJECT: Requests NRC judgement re compliance of listed plant procedures w/requirements of Tech Spec 4.7.1.2.a, 2.b for turbine driven auxiliary feedwater pump. Tech Specs in Rev 4 to NUREG-0452 (STS) do not address assumed water temp.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES: 05000315
 OL: 10/25/74
 05000316
 OL: 12/23/72

	RECIPIENT ID CODE/NAME		COPIES LTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTR ENCL
	NRR ORB1 BC	01	7				
INTERNAL:	ACRS	09	6		ADM/LFMB		1 0
	ELD/HDS3		1		NRR/DE/MTEB		1 1
	NRR/DL DIR		1		NRR/DL/ORAB		1 0
	NRR/DSI/METB		1		NRR/DSI/RAB		1 1
	REG. FILE	04	1		RGN3		1 1
EXTERNAL:	LPDR	03	2		NRC PDR	02	1 1
	NSIC	05	1		NTIS		1 1

TOTAL NUMBER OF COPIES REQUIRED: LTR 27 ENCL ~~24~~ 0

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Large block of faint, illegible text in the middle of the page, possibly a main body of text or a list.

Bottom section of the page containing faint, illegible text, possibly a footer or concluding paragraph.

INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631
COLUMBUS, OHIO 43216

November 28, 1984
AEP:NRC:0906A

Donald C. Cook Nuclear Plant
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
INTERPRETATION OF THE TECHNICAL SPECIFICATION SURVEILLANCE
REQUIREMENTS FOR THE TURBINE DRIVEN AUXILIARY FEEDWATER PUMP (TDAFP)

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

Pursuant to our conversations with members of your staff and the NRC Region III staff, this letter is a request for you to provide an interpretation as to whether or not the D. C. Cook Plant procedures, as described below, properly implement the requirements of Technical Specification (T/S) 4.7.1.2.a.2.b.

It is our current understanding that the basis of the Technical Specification requirement for the TDAFP (T.S. 4.7.1.2.a.2.b; "The steam turbine driven pump develops a discharge pressure of 1285 psig at a flow of 700 gpm when the secondary steam pressure is greater than 310 psig.") was developed by degrading the manufacturer's pump performance curve (flow vs. differential head) by 5 percent. This degraded differential head in feet was utilized in calculating the discharge pressure in psig, based on the specific gravity of water at 60°F. The current plant procedure adjusts the Technical Specification required discharge pressure by establishing a minimum discharge pressure associated with the actual condensate temperature. This correction allows a true comparison of pump performance to that required in the Technical Specification. A review of past 2 years performance data was made and the maximum correction was found to be 6 psi.

The results of our examination show that the T/S, T/S Bases, and the Standard Technical Specifications for Westinghouse Pressurized Water Reactors (NUREG-0452, Revision 4) do not address an assumed water temperature for the specified surveillance pressure of the TDAFP. Further, it is our belief that the methodology described above provides an engineering rationale that prudently addresses the safety basis of the plant.


8412030401 841128
PDR ADDCK 05000315
P PDR

A001
/10

1954

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,



M. P. Alexich
Vice President

RIBK
11/28/84

MPA/cm

cc: John E. Dolan
W. G. Smith, Jr. - Bridgman
G. Bruchmann
R. C. Callen
G. Charnoff
NRC Resident Inspector - Bridgman



Handwritten marks and scribbles in the top right corner.

Faint, illegible text or markings across the upper middle section of the page.

A small, faint line of text or a signature.

A small, faint cluster of markings or a signature.

A faint, illegible block of text or markings on the right side of the page.

A small, dark mark or signature at the bottom left corner.