

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8505160134 DOC. DATE: 85/05/10 NOTIFIED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME: AUTHOR AFFILIATION
 ALEXICH, M.P. Indiana & Michigan Electric Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Responds to DL Wigginton 850326 ltr. Relief requested from Section XI of ASME Boiler & Pressure Vessel Code for certain valve & testing requirements. Rev 1 to valve summary sheets for inservice testing program encl.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 200
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES: *see Drawings* 05000315
 OL: 10/25/74 05000316
 OL: 12/23/72

	RECIPIENT			COPIES				RECIPIENT			COPIES		
	ID	CODE/NAME		LTR	ENCL.			ID	CODE/NAME		LTR	ENCL.	
	NRR	ORB1	BC	01	7	7							
INTERNAL:	ACRS			16	10	10		ADM/LFMB			1	0	
	ELD/HDS3				1	0		NRR/DE/MEB	15		1	1	
	NRR/DE/MTEB			14	1	1		NRR/DL/TAPMG			1	1	
	<u>REG FILE</u>			04	1	1		RGN3			1	1	
EXTERNAL:	LPDR			03	2	2		NRC PDR	02		1	1	
	NSIC			05	1	1							

Aperture Card Dist.



1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for the proper management of the organization's finances and for ensuring compliance with applicable laws and regulations.

2. The second part of the document outlines the specific procedures that must be followed when recording transactions. This includes the requirement that all entries be supported by appropriate documentation, such as invoices, receipts, and contracts.

3. The third part of the document addresses the issue of internal controls. It states that a robust system of internal controls is necessary to prevent errors and fraud, and to ensure that the organization's assets are protected.

4. The fourth part of the document discusses the role of the accounting department in providing accurate and timely financial information to management. It notes that this information is critical for management's decision-making and for the overall success of the organization.

5. The fifth part of the document concludes by reiterating the importance of the accounting function and the need for all employees to understand their role in maintaining accurate financial records.

6. The sixth part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for the proper management of the organization's finances and for ensuring compliance with applicable laws and regulations.

7. The seventh part of the document outlines the specific procedures that must be followed when recording transactions. This includes the requirement that all entries be supported by appropriate documentation, such as invoices, receipts, and contracts.

8. The eighth part of the document addresses the issue of internal controls. It states that a robust system of internal controls is necessary to prevent errors and fraud, and to ensure that the organization's assets are protected.

9. The ninth part of the document discusses the role of the accounting department in providing accurate and timely financial information to management. It notes that this information is critical for management's decision-making and for the overall success of the organization.

10. The tenth part of the document concludes by reiterating the importance of the accounting function and the need for all employees to understand their role in maintaining accurate financial records.

INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631
COLUMBUS, OHIO 43216

May 10, 1985
AEP:NRC:0730G

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
INSERVICE TESTING PROGRAM-CODE RELIEFS

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

- Reference: 1) Letter from Mr. David L. Wigginton, NRC, dated
March 26, 1985
- 2) Our Letter No. AEP:NRC:0730F dated May 10, 1985

Dear Mr. Denton:

This letter and its Attachments are in response to the above referenced letter from Mr. D. L. Wigginton of your staff and provide the revised pages for the Inservice Testing Program (IST) for the Donald C. Cook Nuclear Plant. This submittal is made pursuant to 10 CFR Section 50.55a(g)(6)(i) and requests code relief from section XI of the ASME Boiler and Pressure Vessel Code for certain valve and pump testing requirements. Attachment 1 to this letter is a complete revision to the IST Pump Program for the D. C. Cook Nuclear Plant. The code relief requests discussed at the March 6 and 7, 1985 meeting between our staff and the NRC are detailed in Tables B, D and E. Attachments 2 and 3 contain the request for code relief for the valve testing programs for Units 1 and 2 respectively. For your convenience these attachments are submitted as revised pages to the IST Valve Program which was submitted in our earlier letter AEP:NRC:0730C dated October 2, 1984. For your information those code reliefs which were discussed at the March meeting are marked as "C-1" in the margin. In addition, the revised pages include valve program changes that were agreed upon between the NRC and our staff at that meeting. These revisions are marked as "M-1" in the margin. Other changes identified by us during the preparation of this submittal, which are either minor or editorial in nature, are marked as "E-1".

Attachments 1, 2 and 3 replace the corresponding pages of the IST program submitted in our earlier letter no. AEP:NRC:0730C dated October 2, 1984.

8505160134 850510
PDR ADDCK 05000315
P PDR



AOA7
11

*Aperture
Card Dist*

1947

1947

1947

1947

1947

1947


1947

1947

1947

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,


M. P. Alexich
Vice President 10/25

cm

Attachments

- cc: John E. Dolan (w/o attachment)
- W. G. Smith, Jr. - Bridgman (w/attachment)
- R. C. Callen (w/o attachment)
- G. Bruchmann (w/o attachment)
- G. Charnoff (w/o attachment)
- NRC Resident Inspector - Bridgman (w/attachment)
- R. Lyon - EG&G

... ..

...

...

...

...

ATTACHMENT NO. 1
TO
AEP:NRC:0730G

DONALD C. COOK NUCLEAR PLANT - UNITS NO. 1 AND 2

ASME B & PV CODE SECTION XI

PUMP INSERVICE TEST PROGRAM

- A. The pump test program shall be conducted in accordance with Subsection IWP of Section XI of the 1974 Edition of the ASME Boiler and Pressure Vessel Code through Summer 1975 Addenda, except for specific relief requested in accordance with 10 CFR 50.55a(g)(5)(iii) which is identified in Tables B, C, D and E.
- B. The period for which the pump inservice test program is applicable is the period beginning December 23, 1978 for Unit 1 and the period beginning July 1, 1978 for Unit 2.
- C. The pump test program was developed employing the classification guidelines contained in Regulatory Guide 1.26, Revision 2 for Quality Groups B and C, and the definition of the reactor coolant system boundary contained in 10 CFR 50.2 (v) for Group A. (Quality Groups A, B, and C are the same as ASME Class 1, 2, and 3, respectively). Using these guidelines and IWP-1100, the pump list attached as Table A was developed. Table A identifies the following:
- i. The pump number and service it performs along with the drawing identification number on which it is found.
 - ii. The applicable test parameters:
 - 1. Speed
 - 2. Inlet Pressure
 - 3. Differential Pressure
Determined as the difference between measured discharge and suction pressures
 - 4. Flow Rate
 - 5. Vibration Amplitude
 - 6. Bearing Temperature
 - iii. The test frequency required.

DONALD C. COOK NUCLEAR PLANT - UNITS NO. 1 AND 2
PUMP INSERVICE TEST PROGRAM

TABLE A
PROGRAM SUMMARY

PUMP SERVICE DWG. NO.	PUMP NUMBER	TEST PARAMETERS						TEST FREQUENCY (1)
		SPEED N	INLET PRESSURE P _i	DIFFERENTIAL PRESSURE P	FLOW RATE Q	VIBRATION AMPLITUDE V (4)	BEARING TEMPERATURE T _b	
AUXILIARY FEEDWATER (5106A)	PP-3W PP-3E PP-4	NO NO YES	YES YES YES	YES YES YES	YES* YES* YES*	YES YES YES	YES YES YES	MONTHLY MONTHLY MONTHLY
ESSENTIAL SERVICE WATER (5113)	PP-7W PP-7E	NO NO	YES (3) YES (3)	YES YES	YES YES	YES YES	YES (5) YES (5)	MONTHLY MONTHLY
CENTRIFUGAL CHARGING (5129)	PP-50W PP-50E	NO NO	YES YES	YES YES	NO** NO**	YES YES	YES YES	MONTHLY MONTHLY
BORIC ACID TRANSFER (5131)	PP-46-1 PP-46-2 PP-46-3 PP-46-4	NO NO NO NO	YES (3) YES (3) YES (3) YES (3)	YES YES YES YES	NO* NO* NO* NO*	YES YES YES YES	YES YES YES YES	MONTHLY MONTHLY MONTHLY MONTHLY
COMPONENT COOLING WATER (5135A)	PP-10W PP-10E	NO NO	YES YES	YES YES	YES YES	YES YES	YES YES	MONTHLY MONTHLY
SAFETY INJECTION (5142)	PP-26N PP-26S	NO NO	YES YES	YES YES	NO** NO**	YES YES	YES YES	MONTHLY MONTHLY
RESIDUAL HEAT REMOVAL (5143)	PP-35W PP-35E	NO NO	YES YES	YES YES	YES* YES*	YES YES	YES YES	MONTHLY MONTHLY
CONTAINMENT SPRAY (5144)	PP-9W PP-9E	NO NO	YES YES	YES YES	YES* YES*	YES YES	YES YES	MONTHLY MONTHLY
DIESEL FUEL OIL TRANSFER PUMPS (5151)	QT-106 AB1 QT-106 AB2 QT-106 CD1 QT-106 CD2	NO NO NO NO	YES YES YES YES	YES YES YES YES	YES (6) YES (6) YES (6) YES (6)	YES YES YES YES	NO (5) NO (5) NO (5) NO (5)	QUARTERLY (2) QUARTERLY (2) QUARTERLY (2) QUARTERLY (2)

(1) Bearing Temperature will be measured annually - per Section XI Code Subarticle IWP - 3300, except for the Diesel Fuel Oil Transfer Pumps.

(2) Refer to TABLE B.

(3) Inlet Pressure Measurement is in Head of Liquid.

(4) Refer to TABLE C.

(5) Refer to TABLE D.

(6) Refer to TABLE E

ATTACHMENT NO. 1
AEP:NRC:0730G

DONALD C. COOK NUCLEAR PLANT - UNITS NO. 1 AND 2
PUMP INSERVICE TEST PROGRAM

TABLE A
(CONTINUED)

PROGRAM SUMMARY

- * Pumps are tested on by-pass (test) loops since it is impractical to test in regular circuits - per Section XI Code Subarticle IWP - 1400
- ** Pumps are tested on recirculation (minimum flow) paths to prevent unsafe operating conditions (impractical to align system for full flow test) - per Section XI Code Subarticle IWP - 1400

DONALD C. COOK NUCLEAR PLANT - UNITS NO. 1 AND 2

PUMP INSERVICE TEST PROGRAM

TABLE B

CODE RELIEF REQUEST

Test Frequency

Request that frequency of testing for the Diesel Fuel Oil Transfer Pumps be established on a quarterly basis. *

Operation of both pumps during a monthly test is restricted by the limited capacity of the diesel generator fuel oil day tank. Two pump testing will cause excessive and unnecessary operation of the emergency diesel generators in order to keep the level in the tank from overflowing. Constant draining of the tank to maintain tank level without running the diesel generators is a potential fire and utility hazard. A potential for overflowing the tank is present in either case.

Single pump testing will be conducted during monthly emergency diesel generator operation. Each pump will be tested on a staggered basis (every other month) during a quarterly period.

* Note: This quarterly test frequency is in accordance with the 1980 Edition of Section XI, Subarticle IWP-3400.

DONALD C. COOK NUCLEAR PLANT- UNITS NO. 1 AND 2
PUMP INSERVICE TEST PROGRAM

TABLE C

CODE RELIEF REQUEST

Vibration Measurement

Request that vibration amplitude, as specified in Section XI Subarticle IWP-4510, be measured in terms of velocity, inches per second peak instead of peak to peak displacement.

The major characteristics of vibration are displacement and frequency. Velocity provides a better indication of vibration severity because it includes both displacement and the frequency of displacement.

Since velocity is directly related to displacement, the velocity acceptance criteria for vibration amplitude is consistent to the acceptance criteria for displacement as specified in Table IWP - 3100-2.

DONALD C. COOK NUCLEAR PLANT - UNITS NO. 1 AND 2

PUMP INSERVICE TEST PROGRAM

TABLE D

CODE RELIEF REQUEST

Bearing Temperature Measurement

- a. Request that the pump bearing temperature requirements, per Section XI Subarticle IWP-4310, be amended for the Essential Service Water Pumps.

Except for one bearing assembly located within the motor stand, the remaining shaft bearings are located below the main pump flange and are inaccessible.


In addition to measuring the pump bearing, temperatures will be measured on the motor bearing blocks.

- b. Request that the Diesel Fuel Oil Transfer Pumps be exempt from bearing temperature requirements as stated Section XI Subarticle IWP-3300.

The inboard and outboard sleeve bearings on these 2 HP gear pumps are lubricated and cooled by the pumped fluid. Temperature readings are therefore inconclusive since bearing measurement points are not responsive to the changes in bearing temperature.

Bearing problems on gear pumps can be more readily identified by degradation of pump capacity. Flow rate deterioration indicates the existence of excessive clearances due to bearing wear and problems.

In addition, the code required pump running time for yearly bearing temperature measurement can not be met due to the limited capacity of the diesel generator fuel oil day tank.



DONALD C. COOK NUCLEAR PLANT - UNITS NO. 1 AND 2
PUMP INSERVICE TEST PROGRAM

TABLE E

CODE RELIEF REQUEST

Request that the duration of pump operation for testing, per Section XI Subarticle IWP-3500, be amended for the Diesel Fuel Oil Transfer Pumps.

These pumps supply the diesel generator fuel oil day tank. A conservative level is maintained in the tank to meet the minimum capacity per Technical Specification requirements. Due to the limited capacity of this tank, the pump operating test range is restricted. It is requested to record test parameters immediately after pump operation has stabilized.

