



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

INDIANA AND MICHIGAN ELECTRIC COMPANY

DOCKET NO. 50-315

DONALD C. COOK NUCLEAR PLANT UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 85
License No. DPR-58

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana and Michigan Electric Company (the licensee) dated March 29, 1982, as supplemented by letters dated April 18, 1983, November 29, 1983, and February 12, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-58 is hereby amended to read as follows:


8508150461 850805
PDR ADDCK 05000315
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 85, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The change in Technical Specifications is to become effective within 30 days of issuance of the amendment.
4. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 5, 1985



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

INDIANA AND MICHIGAN ELECTRIC COMPANY

DOCKET NO. 50-316

DONALD C. COOK NUCLEAR PLANT UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 71
License No. DPR-74


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana and Michigan Electric Company (the licensee) dated March 29, 1982, as supplemented by letters dated April 18, 1983, November 29, 1983, and February 12, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-74 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 71, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The change in Technical Specifications is to become effective within 30 days of issuance of the amendment.
4. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 5, 1985

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 85 FACILITY OPERATING LICENSE NO. DPR-58

AMENDMENT NO. 71 FACILITY OPERATING LICENSE NO. DPR-74

DOCKET NOS. 50-315 AND 50-316

Revise Appendix A as follows:

Remove Pages

Insert Pages

Unit 1

3/4 3-9
3/4 3-10*

3/4 3-9
3/4 3-10*

Unit 2

3/4 3-8

3/4 3-8

*No changes - Page provided for convenience.

TABLE 3:3-1 (Continued)

<u>DESIGNATION</u>	<u>CONDITION AND SETPOINT</u>	<u>FUNCTION</u>
P-7	With 2 of 4 Power Range Neutron Flux Channels \geq 11% of RATED THERMAL POWER or 1 of 2 Turbine First Stage Pressure : channels \geq 37 psig.	P-7 prevents or defeats the automatic block of reactor trip on: Low flow in more than one primary coolant loop, reactor coolant pump under-voltage and under-frequency, turbine trip, pressurizer low pressure, and pressurizer high level.
P-8	With 2 of 4 Power Range Neutron Flux channels \geq 51% of RATED THERMAL POWER.	P-8 prevents or defeats the automatic block of reactor trip on low coolant flow in a single loop.
P-10	With 3 of 4 Power range neutron flux channels < 9% of RATED THERMAL POWER.	P-10 prevents or defeats the manual block of: Power range low setpoint reactor trip, Intermediate range reactor trip, and intermediate range rod stops. Provides input to P-7.

TABLE 3.3-2

REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES

<u>FUNCTIONAL UNIT</u>	<u>RESPONSE TIME</u>
1. Manual Reactor Trip	NOT APPLICABLE
2. Power Range, Neutron Flux	≤ 0.5 seconds*
3. Power Range, Neutron Flux, High Positive Rate	NOT APPLICABLE
4. Power Range, Neutron Flux, High Negative Rate	≤ 0.5 seconds*
5. Intermediate Range, Neutron Flux	NOT APPLICABLE
6. Source Range, Neutron Flux	NOT APPLICABLE
7. Overtemperature ΔT	≤ 6.0 seconds*
8. Overpower ΔT	NOT APPLICABLE
9. Pressurizer Pressure--Low	≤ 1.0 seconds
10. Pressurizer Pressure--High	≤ 1.0 seconds
11. Pressurizer Water Level--High	NOT APPLICABLE

* Neutron detectors are exempt from response time testing. Response time shall be measured from detector output or input of first electronic component in channel.

D. C. COOK-UNIT 1

3/4 3-10

TABLE 3.3-1 (Continued)

<u>DESIGNATION</u>	<u>CONDITION AND SETPOINT</u>	<u>FUNCTION</u>
P-7	With 2 of 4 Power Range Neutron Flux Channels \geq 11% of RATED THERMAL POWER or 1 of 2 Pressure Before the First Stage channels \geq 66 psia.	P-7 prevents or defeats the automatic block of reactor trip on: Low flow in more than one primary coolant loop, reactor coolant pump under-voltage and under-frequency, turbine trip, pressurizer low pressure, and pressurizer high level.
P-8	With 2 of 4 Power Range Neutron Flux channels \geq 31% of RATED THERMAL POWER.	P-8 prevents or defeats the automatic block of reactor trip on low coolant flow in a single loop.
P-10	With 3 of 4 Power range neutron flux channels $<$ 9% of RATED THERMAL POWER.	P-10 prevents or defeats the manual block of: Power range low setpoint reactor trip, Intermediate range reactor trip, and intermediate range rod stops. Provides input to P-7.