

SAFETY EVALUATION REPORT
FOR
D. C. COOK UNIT 1
LARGE BREAK LOCA RE-ANALYSIS
USING BART-WREFLOOD


In reference 1, the licensee submitted a LOCA analysis for D. C. Cook Unit 1 to support the current technical specification value of $F_q = 2.10$. This analysis used BART-WREFLOOD for thermal hydraulic analysis during the reflood phase of the LOCA. The corrected and revised input methodology was used. The worst case identified in reference 1 was the so-called Max SI case with $C_d = 0.6$. No other break sizes, were presented for Max SI. At the NRC's request, the licensee requested Westinghouse to perform Max SI analyses for $C_d = 0.4$ and 0.8 . This was done and the results are as follows.


LOCA Analysis Results
Max SI

<u>BREAK C_d</u>	<u>PCT(°F)</u>
0.4	2107
0.6	2154
0.8	2046

Thus it was confirmed that $C_d=0.6$ was the worst case.

The staff also questioned the impact on $K(z)$ of using BART-WREFLOOD. The licensee and Westinghouse reviewed "spot-check" analyses with BART-WREFLOOD for top-peaked cases and determined that the existing $K(z)$ curves would not be adversely affected.





- 2 -

Based on these results the staff finds the new analyses using BART-WREFLOOD to support an $F_q = 2.10$ to be acceptable.

Dated: August 26, 1985

Principal Contributor:

N. Eauben