

Docket Nos. 50-315
and 50-316

November 13, 1985

DISTRIBUTION

Docket File

LPDR
Gray File
OELD
B. Grimes
ACRS 10
G. Holahan

NRC PDR
ORB#1 Rdg
H. Thompson
E. Jordan
J. Partlow
D. Wigginton
C. Parrish

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

By letter dated October 1, 1985 (AEP:NRC 0856M), the Indiana and Michigan Electric Company (IMEC) responded to Generic Letter No. 83-37, Item II.F.1.4 of NUREG-0737. This item concerns the need for containment pressure indication in the control room. The IMEC response is that the current Technical Specifications are adequate and meet the requirements of the Generic Letter and NUREG-0737. We have completed our review of your response and find it acceptable.

In our review we have determined that the D. C. Cook Nuclear Plant, Unit Nos. 1 and 2 has the requisite two channels and the surveillance requirements. The limiting conditions for operation (including the required actions) are similar in that action is required within 30 days if less than the two channels are operable and 1 hour (Technical Specification 3.0.3) if both channels are inoperable. While our Standard Technical Specifications require action in seven days for one channel inoperable or 48 hours for both channels inoperable, the IMEC response is nevertheless consistent with our requirement that the action statements should be similar to other accident monitoring instrumentation included in the present Technical Specifications.

This completes the review for NUREG-0737 Item II.F.1.4 "Containment Pressure Monitor", for the D. C. Cook Nuclear Plant, Unit Nos. 1 and 2.

Sincerely,

/s/Steven A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

ORB#1:DL
CParrish
10/19/85

ORB#1:DL
DWigginton;ps
10/14/85

ORB#1:DL
GHolahan
10/6/85

BC-ORB#1:DL
SVarga
10/19/85

Mr. John Dolan
Indiana and Michigan Electric Company

Donald C. Cook Nuclear Plant

cc:

Mr. M. P. Alexich
Vice President
Nuclear Operations
American Electric Power Service
Corporation
1 Riverside Plaza
Columbus, Ohio 43215

The Honorable John E. Grotberg
United States House of Representatives
Washington, DC 20515-

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

J. Feinstein
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgman, Michigan 49106

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106


U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Mayor, City of Bridgeman
Post Office Box 366
Bridgman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909



100-1000