


ATTACHMENT 2 TO AEP:NRC:0972

PROPOSED REVISED

TECHNICAL SPECIFICATION PAGES

8601220485 860117
PDR ADOCK 05000315
P PDR





PLANT SYSTEMS

3/4.7.4 ESSENTIAL SERVICE WATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.4.1 At least two independent essential service water loops shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With only one essential service water loop OPERABLE, restore at least two loops to OPERABLE status within 72* hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.4.1 At least two essential service water loops shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by:
 1. Starting (unless already operating) each pump from the control room.
 2. Verifying that each pump develops at least 93% of the discharge pressure for the applicable flow rate as determined from the manufacturer's Pump Performance Curve.
 3. Verifying that each pump operates for at least 15 minutes.
 4. Cycling each testable power operated or automatic valve servicing safety related equipment through at least one complete cycle of full travel.
 5. Verifying that each valve (manual, power operated or automatic) servicing safety related equipment that is not locked, sealed, or otherwise secured in position, is in its correct position.

* Power operation may continue indefinitely provided that the three remaining essential service water pumps (one pump from the affected unit and two from the opposite unit) are OPERABLE and connected through the Unit 1 and Unit 2 cross-tie valves. Should one of the two OPERABLE essential service water loops or pumps on the opposite unit become inoperable, restore one of the inoperable essential service water loops or pumps on either unit to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

NOTE: The cross-tie valves may be closed to permit surveillance testing of individual pumps.

PLANT SYSTEMS

BASES

3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION

The limitation on steam generator pressure and temperature ensures that the pressure induced stresses in the steam generators do not exceed the maximum allowable fracture toughness stress limits. The limitations of 70°F and 200 psig are based on average steam generator impact values taken at +10°F and are sufficient to prevent brittle fracture.

3/4.7.3 COMPONENT COOLING WATER SYSTEM

The OPERABILITY of the component cooling water system ensures that sufficient cooling capacity is available for continued operation of safety related equipment during normal and accident conditions. The redundant cooling capacity of this system, assuming a single failure, is consistent with the assumptions used in the accident analyses.

3/4.7.4 ESSENTIAL SERVICE WATER SYSTEM

The OPERABILITY of the essential service water system ensures that sufficient cooling capacity is available for continued operation of safety related equipment during normal and accident conditions. The redundant cooling capacity of this system, assuming a single failure, is consistent with the assumptions used in the accident conditions within acceptable limits. Three pumps (shared between the two units via ESW cross-tie valves) are required to be OPERABLE only after the initial 72 hours for ESW pump out-of-service time has expired (the cross-tie valves may be closed to permit surveillance testing of individual pumps). This ensures the requirements specified in Section 9.8 of the FSAR are maintained if it is necessary to remove one ESW pump from service for an extended period of time for repair or replacement activities.

PLANT SYSTEMS

3/4.7.4 ESSENTIAL SERVICE WATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.4.1 At least two independent essential service water loops shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With only one service water loop OPERABLE, restore at least two loops to OPERABLE status within 72* hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.4.1 At least two essential service water loops shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power operated or automatic) servicing safety related equipment that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 18 months during shutdown, by verifying that each automatic valve servicing safety related equipment actuates to its correct position on a Safety Injection test signal.

* Power operation may continue indefinitely provided that the three remaining essential service water pumps (one pump from the affected unit and two from the opposite unit) are OPERABLE and connected through the Unit 1 and Unit 2 cross-tie valves. Should one of the two OPERABLE essential service water loops or pumps on the opposite unit become inoperable, restore one of the inoperable essential service water loops or pumps on either unit to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

NOTE: The cross-tie valves may be closed to permit surveillance testing of individual pumps.

3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION

The limitation on steam generator pressure and temperature ensures that the pressure induced stresses in the steam generators do not exceed the maximum allowable fracture toughness stress limits. The limitations of 70°F and 200 psig are based on average steam generator impact values taken at +10°F and are sufficient to prevent brittle fracture.

3/4.7.3 COMPONENT COOLING WATER SYSTEM

The OPERABILITY of the component cooling water system ensures that sufficient cooling capacity is available for continued operation of safety related equipment during normal and accident conditions. The redundant cooling capacity of this system, assuming a single failure, is consistent with the assumptions used in the accident analyses.

3/4.7.4 ESSENTIAL SERVICE WATER SYSTEM

The OPERABILITY of the essential service water system ensures that sufficient cooling capacity is available for continued operation of safety related equipment during normal and accident conditions. The redundant cooling capacity of this system, assuming a single failure, is consistent with the assumptions used in the accident conditions within acceptable limits. Three pumps (shared between the two units via ESW cross-tie valves) are required to be OPERABLE only after the initial 72 hours for ESW pump out-of-service time has expired (the cross-tie valves may be closed to permit surveillance testing of individual pumps). This ensures the requirements specified in Section 9.8 of the FSAR are maintained if it is necessary to remove one ESW pump from service for an extended period of time for repair or replacement activities.

3/4.7.5 CONTROL ROOM EMERGENCY VENTILATION SYSTEM

The OPERABILITY of the control room emergency ventilation system ensures that 1) the ambient air temperature does not exceed the allowable temperature for continuous duty rating for the equipment and instrumentation cooled by this system and 2) the control room will remain habitable for operations personnel during and following all credible accident conditions. The OPERABILITY of this system in conjunction with control room design provisions is based on limiting the radiation exposure to personnel occupying the control room to 5 rem or less whole body, or its equivalent. This limitation is consistent with the requirements of General Design Criteria 19 of Appendix "A", 10 CFR 50.