



REVISIONS				
NO	DATE	DESCRIPTION	BY	CHK
5	7-24-95	REVISED TO SHOW 2998-G-078 SH 169	CLG	

- NOTES
- PUMP STOPS ON HIGH PRIMARY WATER STORAGE TANK LEVEL.
 - LOCAL ALARMS ARE PROVIDED ON SEVERAL LOCAL PANELS. EACH PANEL HAS AN ANNUNCIATOR IN THE CONTROL ROOM.

- REFERENCE DRAWINGS
- PIPE, VALVE & INSTRUMENT SYMBOLS 2998-G-078 SH 100
 - VALVE LIST 2998-A-051
 - LINE LIST 2998-B-052
 - VALVE OPERATIONAL NUMBER INDEX 2998-B-057A
 - INSTRUMENT INSTALLATION DETAILS 2998-B-231
 - INSTRUMENT LIST 2998-B-270C

NOTE:
THIS DRAWING IS MADE FROM REV. 4
OF DRAWING 2998-G-078 SH 169

REVISION OF THIS DRAWING MAY REQUIRE UPDATE OF THE FOLLOWING DOCUMENT: FSAR FIGURE 11.2-9

FLORIDA POWER & LIGHT COMPANY
ST. LUCIE PLANT
1983 - 890 MWE EXTENSION - UNIT 2
FLOW DIAGRAM
WASTE MANAGEMENT SYSTEM

RAYTHEON ENGINEERS & CONSTRUCTORS, INC.

SCALE: NONE	APPROVAL	DATE:
DR: MESH		2998-G-078
DR: C. SLATT		SHEET
DR: QUINN/DAM		169

2998-G-078 SH.169

9607170092-66

D