NFORMATION DISTRIBUTION ST TEM (RIDS) REGULATORY

ACCESSION NBR: 8505060101 DUC. DATE: 86/05/01 NOTARIZED: NO DOCKET # FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316

AUTH. NAME AUTHOR AFFILIATION

ALEXICH, M. P. Indiana & Michigan Electric Co.

RECIP. NAME RECIPIENT AFFILIATION

DENTON, H, R. Office of Nuclear Reactor Regulation, Director (post 851125

SUBJECT: Forwards revised proposed Cycle 6 Tech Specs 3/4.1.2.7 &

3/4.1.2.8 re borated water sources - shutdown & operating,

respectivelu.

TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL	
	PWR-A ADTS		1	0	PWR-A EB		1	1
	PWR-A EICSB		2	2	PWR-A FOB		1	1
	PWR-A PD4 PD	01	5	5	WIGGINGTON, D		1	1
	PWR-A PSB		1	1	PWR-A RSB		1	1
INTERNAL:	ADM/LFMB		1	0	ELD/HDS3		1	0
_	NRRADHET/TSCE	3	1	1	NRR/ORAS		1	0
	REG FILE	04	1	1	RGN3		1	1
EXTERNAL:	24X		1	1	EG&G BRUSKE,	3	1	1
	LPDR	03	1	1	NRC PDR	02	1	1
	NSIC	05	1	1				

REGULATORY NFORMATION DISTRIBUTION SECENTION (RIDS)

SCHESTON VER ECOSTONIA DEC DATE: BESTONIA NOTANISTO SET DECEMBLE SASSING NOTANISTO SET DECEMBLE.

FAMIL: 50-3ks Denald (fook Nuclear Power First) this of the cola & Obcooling Schild ATION

ALFERCARD P IN I IN SERVICE AFFILIATION

RECIP. NEWS RECIPIED AFFILIATION

THE CIP. NEWS RECIPIED AFFILIATION

DENTED HELD AFFILIAT

SUBJECT: For ends revised proposed Cycloch Spec. 174 t.2.7 % 374 i 2.8 no bonated water sources - ciridawn & operaing recording.

CORRECTION CUDE: ADOID COPIES RECEIVED OR LEMON 5178:____

:23 TOM

ES	raa	PECIALL	ស៊ីធី	27333	1'	RECIPIEN	
ENGL	ATT I	MANNIGO, GI	引いる	5 T	111A	ID CODE/A	
K	Ī	મધાદ- એ સહ	O	į		PUR-A ADTS	
Ĭ	Ł	ac∙a ⊰∴awa	2	43	3	PHR-H FICSE	
t	ì	wiceinctum, d	2	Ų.	to or	मधाप्त के स्थाप	
ŗ	R	PWR - A RISB	1	,		PWR & PSB	
O	Ĺ	El.D/18092	0	Į		ADMAL PRIB	ZETEKNAL:
O	Ę	NRR/WRAD	1	ľ	11.)2	NERZECTAGE	
ĵ	•	CNOS	1	¥	NO	BEG FILE	
ž.	ţ	EGRO BRUCKERO	1	1		ZAX	EX (CRIVAL)
1	İ	NRC POP OP	t	į	60	भवन् ।	
			ì	Ř	80	NSTC	

INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631 COLUMBUS, OHIO 43216

> May 1, 1986 AEP:NRC:0916S

Donald C. Gook Nuclear Plant Unit No. 2 Docket No. 50-316 License No. DPR-74 REVISION OF PROPOSED CYCLE 6 BORATED WATER SOURCES TECHNICAL SPECIFICATIONS

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U.S. Nulcear Regulatory Commission Washington, D.C. 20555

Dear Mr. Denton:

The purpose of this letter is to transmit revised versions of our proposed Unit 2 Cycle 6 Technical Specifications (T/Ss) 3/4.1.2.7 and 3/4.1.2.8 (Borated Water Sources -- Shutdown and Operating, respectively). Proposed versions of these T/Ss were originally transmitted to you in our letter AEP:NRC:0916P, dated March 27, 1986. In that submittal, we proposed to increase the borated water volumes required for the Refueling Water Storage Tank (RWST) and the Boric Acid Storage Tank (BAST), because of new analyses performed by Exxon Nuclear Company (ENC) in support of the Cycle 6 reload. These analyses were extremely conservative, assuming that the Reactor Coolant System (RCS) was at 0 ppm boron prior to borated water addition to achieve the desired shutdown margin. Because of the operational difficulties posed by the drastically increased tank volumes, ENC reanalyzed the tank requirements using more realistic assumptions concerning initial RCS boron concentrations. evaluation, which has been included as Attachment 1 to this letter, concluded that our present T/S 3.1.2.8 requirements on the BAST and RWST volumes are conservative. Therefore, we propose to maintain our present T/S and therefore wish to withdraw our proposed version. For T/S 3.1.2.7, ENC determined that a BAST volume of 4,300 gallons, rather than the proposed 8,750 gallons, is sufficient. Likewise, they recommended an RWST volume of 90,000 gallons, as opposed to the proposed 190,000 gallons. The volumes cited are usable They will be adjusted administratively to account for water not available because of discharge line locations and other physical characteristics, as necessary.

These changes have been discussed with members of your staff. At their instruction, we are submitting revised versions of T/Ss 3/4.1.2.7 and 3/4.1.2.8, which contain the changes described above. We are also submitting a revised T/S Bases page B 3/4 1-3, which has been revised to reflect the new ENC analyses. Changes to our previous submittal are indicated by a double bar in the right hand margin of the affected pages. Because these changes represent revisions to our previous submittal, we believe no additional fees are required per 10 CFR 170.12.

Hool I

8605060101 860501 PDR ADDCK 05000316 P PDR

.

incorporate a reasonable set of controls to insure its accuracy and

completeness prior to signature by the undersigned.

Very truly yours,

M. P. Alexich Vice President

MPA/rjn

cc: John E. Dolan

W. G. Smith, Jr. - Bridgman

G. Bruchmann R. C. Callen

G. Charnoff

NRC Resident Inspector - Bridgman

Attachment 1 to AEP:NRC:0916S

ENC Evaluation of Required Tank Volumes

Attachment

This attachment is provided in response to a request for an evaluation of the D. C. Cook Unit 2 Technical Specification limits on borated water source contained volumes. The request was made due to the increased shutdown margin requirement for operation on the residual heat removal (RHR) system. The results obtained from the evaluation are provided below.

For modes 1-4, the minimum contained volumes for the boric acid storage tank (BAST) and the refueling water storage tank (RWST) was found to be 3700 gallons and 118000 gallons, respectively. These volumes, at the minimum boric acid concentrations, will allow boration of the primary coolant from HFP, critical, equilibrium Xenon conditions to a boron concentration sufficient to provide the shutdown margin required for Mode 4 RHR operation. Because these values are smaller than those currently specified in the Technical Specifications, it is recommended that the current Technical Specification 3.1.2.8 applicable to modes 1-4 remain unchanged. The current values have been established per criteria which are different from that of attaining required shutdown margin which is used in this evaluation.

For Mode 5 minimum contained volumes of 2400 gallons for the BAST and 90000 gallons for the RWST are required. These volumes are sufficient to allow boration of the primary coolant from the boron concentration required in mode 4, while one or more primary coolant pumps are operating, to a boron concentration which provides the shutdown margin required for mode 5 RHR operation. Furthermore, this calculation indicates that the BAST volume required to borate from mode 4 to mode 6 is 4300 gallons. This assumes a boron concentration of 2000 ppm for mode 6 (Technical Specification 3.9.1). It is recommended that these values (4300 gallons for the BAST and 90000 gallons for the RWST) be included in the Technical Specifications for modes 5 and 6.

The volumes cited above are usable tank volumes. They should be incremented by appropriate allowances for line locations and other physical characteristics for operational use.

PAGE 4 OF 4