



INDIANA & MICHIGAN ELECTRIC COMPANY
 ONE SUMMIT SQUARE, P.O. BOX 60, FORT WAYNE, IN. 46801
 Telephone (219) 425-2111

PRIORITY ROUTING

First	
RA	
DRA	
DRP	
DRS	SS?
DRSS	HL
DRMA	OL
	OI
	PAO

FILE

D413

orig 2

July 14, 1986

JACK F. STARK
 Senior Vice President

Paul D. Zugger, Executive Secretary
 Michigan Water Resources Commission
 Stevens D. Mason Building, Box 30026
 Lansing, Michigan 48909

Dear Mr. Zugger:

RE: Donald C. Cook Nuclear Plant
 NPDES Permit No. MI 0005827
 Steam Generator Blowdown

On July 9, 1986, during preparation of the NPDES Monthly Operating Report, it was discovered that a grab sample for a suspended solids on the Unit 2 Steam Generator blowdown was not obtained on June 29 during startup.

On June 29, when Unit 2 startup was in progress, the blowdown system was used to reduce reactor coolant temperature for a period of one hour and forty-five minutes. This period was the only use made of the blowdown system during the weekly sampling period frequency.

By copy of this letter, the Nuclear Regulatory Commission is notified pursuant to the requirements of Appendix B, Part II, Nonradiological Environmental Protection Plan, Section 3.2.

Very truly yours,

Jack F. Stark
 Senior Vice President

JFS/df

c: J. G. Keppler -- NRC, Region III
 W. G. Smith, Jr.

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Jack F. Stark

8608010250 860714
 PDR ADOCK 05000316
 S PDR

IEW
 10 JUL 16 1986

c: M. P. Alexich - Columbus
H. B. Brugger - Columbus
J. E. Dolan - Columbus
R. W. Jurgensen - Columbus
R. F. Kroeger - Columbus
K. D. Mack - Columbus
R. W. Reeves/C. E. Hawk - Columbus

A. A. Blind - Cook Plant
T. A. Kriesel - Cook Plant
NRC Resident Inspector - Cook Plant
PNSRC - Cook Plant
J. F. Stietzel - Cook Plant

G. Charnoff, Esq. -- Shaw, Pittman, Potts & Trowbridge
R. E. Zahler, Esq. - Shaw, Pittman, Potts & Trowbridge

R. C. Callen - Michigan Public Service Commission

D. R. Hahn - Michigan Department of Public Health

H. R. Denton - Nuclear Reactor Regulations

Dottie Sherman - ANI Library

INPO - Records Center

