



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

December 6, 2017

Ms. Tanya Hamilton
Site Vice President
Shearon Harris Nuclear Power Plant
Duke Energy
5413 Shearon Harris Road
New Hill, NC 27562-0165

SUBJECT: SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 – CORRECTION TO LICENSE AMENDMENT NO. 127 REGARDING CHANGES TO THE INSERVICE INSPECTION AND TESTING REQUIREMENTS AND ESTABLISHMENT OF A TECHNICAL SPECIFICATIONS BASES CONTROL PROGRAM (CAC NO. MD5802)

Dear Ms. Hamilton:

By letter dated June 12, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML081430111), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 127 to Renewed Facility Operating License No. NPF-63 for the Shearon Harris Nuclear Power Plant, Unit 1 (Harris). The amendment relocated the Inservice Testing requirements to the administrative section of the Technical Specifications (TSs), removed the Inservice Inspection requirements from the TSs, and established a TSs Bases Control Program. These changes were in response to the Duke Energy Progress, LLC (previously Carolina Power and Light Company) (the licensee) license amendment request dated June 15, 2007, as supplemented by letter dated March 6, 2008 (ADAMS Accession Nos. ML071800018 and ML080720337).

This year, while performing the acceptance review on a license amendment request submitted November 7, 2017, (ADAMS Accession No. ML17312A362), the NRC staff identified an error on TS pages 6-19g and 6-19h associated with Amendment No. 127. Specifically, the TS pages 6-19g and 6-19h were issued without the applicable headings, "ADMINISTRATIVE CONTROLS" and "PROCEDURES AND PROGRAMS (Continued)."


It appears that this error was introduced when the licensee submitted its markup and clean TS pages for Amendment No. 127, and because TS pages 6-19g and 6-19h were new pages to be added to the TS. The licensee submitted the markup pages as "inserts" without headings, while the clean pages were submitted with correct headings that were consistent with the Administrative Controls section of the Harris TS. The NRC inadvertently issued the pages without the headings. The corrected pages are enclosed.

T. Hamilton

- 2 -

If you have any questions, please contact me at (301) 415-6256 or by e-mail at Dennis.Galvin@nrc.gov.

Sincerely,

A handwritten signature in cursive script that reads "Dennis J. Galvin".

Dennis J. Galvin, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-400

Enclosure:
Corrected TS Pages 6-19g and 6-19h

cc: Listserv

CORRECTION TO LICENSE AMENDMENT NO. 127
SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1
RENEWED FACILITY OPERATING LICENSE NO. NPF-63
DOCKET NO. 50-400

Replace the following pages of the Appendix A Technical Specifications with the attached corrected pages.

Remove
6-19g
6-19h

Insert
6-19g
6-19h

ADMINISTRATIVE CONTROLS

PROCEDURES AND PROGRAMS (Continued)

m. Inservice Testing Program

This program provides controls for inservice testing of ASME Code Class 1, 2, and 3 components. The program shall include the following:

1. Testing frequencies specified in the ASME Code for Operation and Maintenance of Nuclear Power Plants and applicable Addenda as follows:

ASME Code for Operation and Maintenance of Nuclear Power Plants and applicable Addenda terminology for inservice testing activities	Required Frequencies for performing inservice testing activities
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days
Biennially or every 2 years	At least once per 731 days

2. The provisions of SR 4.0.2 are applicable to the above required Frequencies and to other normal and accelerated Frequencies specified as 2 years or less in the Inservice Testing Program for performing inservice testing activities,
3. The provisions of SR 4.0.3 are applicable to inservice testing activities, and
4. Nothing in the ASME Code for Operation and Maintenance of Nuclear Power Plants shall be construed to supersede the requirements of any Technical Specification.

ADMINISTRATIVE CONTROLS

PROCEDURES AND PROGRAMS (Continued)

n. Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

1. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews.
2. Licensees may make changes to Bases without prior NRC approval provided the changes do not require either of the following:
 - a. A change in the TS incorporated in the license, or
 - b. A change to the FSAR or Bases that requires NRC approval pursuant to 10 CFR 50.59.
3. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the FSAR.
4. Proposed changes that meet the criteria of Specification 6.8.4.n.2 above shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

SUBJECT: SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 – CORRECTION TO LICENSE AMENDMENT NO. 127 REGARDING CHANGES TO THE INSERVICE INSPECTION AND TESTING REQUIREMENTS AND ESTABLISHMENT OF A TECHNICAL SPECIFICATIONS BASES CONTROL PROGRAM (CAC NO. MD5802) DATED DECEMBER 6, 2017

DISTRIBUTION:

PUBLIC

PM Reading File

RidsRgn2MailCenter Resource

RidsACRS_MailCTR Resource

RidsNrrLABClayton Resource

RidsNrrDorLpl2-2 Resource

RidsNrrPMShearonHarris Resource

ADAMS Accession Nos.:**Package: ML17340B389****Letter: ML17324B048****Correction Pages: ML17324B129**

OFFICE	DORL/LPL2-2/PM	DORL/LPL2-2/LA	DORL/LPL2-2/PM	DORL/LPL2-2/BC	DORL/LPL2-2/PM
NAME	DGalvin	BClayton	MBarillas	UShoop (PBuckberg for)	DGalvin
DATE	12/01/17	11/30/17	12/04/17	12/05/17	12/06/17

OFFICIAL RECORD COPY