

Docket Nos.: 50-315
and 50-316

MAR 06 1987

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

During the review of the Indiana and Michigan Electric Company submittal dated July 30, 1986, on the relief valve and safety valve testing, we have identified two areas where additional information is needed. The attached questions were developed by our contractor and pertain to verification of the REPIPE code and stresses on pipe supports in a faulted condition. It is requested that IMEC provide the information or identify the submittal if the information has been provided.

If there are any questions on this matter, please let us know.

Sincerely,

151

Dave L. Wigginton, Project Manager
PWR Project Directorate #4
Division of PWR Licensing-A

Enclosures: As stated

cc: See next page

DISTRIBUTION:

Docket File ←
Local PDR
NRC PDR
PWR#4 Reading
BJYoungblood Reading
MDuncan
DWigginton
EJordan
JPartlow
BGrimes
NThompson
ACRS(10)

8703110118 870306
PDR ADOCK 05000315
PDR

PWR#4/DPWR-A
DWigginton/rad
02/24/87

PWR#4/DPWR-A
MDuncan
02/24/87

PWR#4/DPWR-A
BJYoungblood
02/25/87



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 06 1987

Docket Nos.: 50-315
and 50-316

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

During the review of the Indiana and Michigan Electric Company submittal dated July 30, 1986, on the relief valve and safety valve testing, we have identified two areas where additional information is needed. The attached questions were developed by our contractor and pertain to verification of the REPIPE code and stresses on pipe supports in a faulted condition. It is requested that IMEC provide the information or identify the submittal if the information has been provided.

If there are any questions on this matter, please let us know.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. Wigginton".

Dave L. Wigginton, Project Manager
PWR Project Directorate #4
Division of PWR Licensing-A

Enclosures: As stated

cc: See next page

Mr. John Dolan
Indiana and Michigan Electric Company

Donald C. Cook Nuclear Plant

CC:

Mr. M. P. Alexich
Vice President
Nuclear Operations
American Electric Power Service
Corporation
1 Riverside Plaza
Columbus, Ohio 43215

The Honorable John E. Grotberg
United States House of Representatives
Washington, DC 20515

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgeman, Michigan 49106

J. Feinstein
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mayor, City of Bridgeman
Post Office Box 366
Bridgeman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909

11
12
13
14
15

UNRESOLVED QUESTIONS ON D.C. COOK, UNITS 1 AND 2

1. The licensee was previously requested to provide verification that the REPIPE program produces accurate fluid forces when used in conjunction with RELAP for discharge transients of the type occurring in a PWR overpressure protection system. The licensee responded by stating that verification of REPIPE's capacity to generate force histories is provided by the Control Data Corporation. This statement does not in itself provide evidence of verification for the program. Therefore, provide a verification of this program by comparing calculated forces with measured forces from the EPRI test data or other similar verification.
2. The licensee has provided load combinations that were used to evaluate adequacy of the piping and pipe supports for normal, upset, and emergency conditions. The load combinations used for these three service conditions are in accordance with FSAR requirements and recommendations of the EPRI PWR Safety and Relief Valve Test Program Guide for Application of Valve Test Program Results to Plant-Specific Evaluations, July 1982. The licensee submittals do not, however, provide a load combination for a faulted condition whereby loads for a worst case blowdown are combined with loads for a worst case seismic event. Such a load combination is specified in the FSAR (Chapter 4, Section 4.3.1) and in the EPRI Guide. Based on the stress values presented in the Teledyne reports included in the licensee submittals, a load combination of Deadweight + Design + Design Basis Earthquake + Safety Valve Discharge $\leq 2.4 S_h$ can be performed for pipe stresses and the resulting stresses for this faulted condition are acceptable.

The information supplied by the licensee, though, does not permit performing a similar load combination for a faulted condition on the pipe supports. Therefore, determine an allowable stress for pipe support components for a faulted condition and perform a load combination such as Normal + Design Basis Earthquake + Safety Valve Discharge in which the resulting stresses are compared to the established allowables.