

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8709210274 DOC. DATE: 87/09/14 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 MENGE, R. C. Indiana & Michigan Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Michigan, State of

SUBJECT: NPDES noncompliance notification: on 870901, spill from turbine room sump, outfall OOD occurred. Approx 9,000 gallons of water overflowed to Lake Michigan. Grab sample indicated pH of 6.57 & no trace of oil & grease. Caused by repairs.

DISTRIBUTION CODE: IE23D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Environmental Event Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA	1 0	PD3-3 PD	1 1
	WIGGINGTON, D	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	AEOD/PTB	1 1	NRR/DEST/ADE	1 1
	NRR/DOEA/EAB	1 1	NRR/DREP/EPB	1 1
	NRR/DREP/RPB	1 1	NRR/PMAS/ILRB	1 1
	NRR/PMAS/PTSB	1 1	OGC/HDS1	1 1
	REG FILE	1 1	RGN3 FILE 01	1 1
	RGN2/DRSS/EPRPB	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 0

Indiana Michigan
Power Company
One Summit Square
P.O. Box 60
Fort Wayne IN 46801
219 425 2111

INDIANA
MICHIGAN
POWER

Paul D. Zugger, Executive Secretary
Michigan Water Resources Commission
Stevens T. Mason Building, Box 30026
Lansing, Michigan 48909

September 14, 1987

Richard C. Menge
Vice President
219 425 2103

Dear Mr. Zugger:

RE: Donald C. Cook Nuclear Plant
NPDES Permit No. MI0005827
Outfall 00D

This letter confirms our September 2, 1987 telephone notification of a spill from the Donald C. Cook Plant. The notification made to your Plainwell office followed a spill from the turbine room sump, outfall 00D, which occurred on September 1, 1987, 0845 hours to 0915 hours. An estimated 9000 gallons of water from the sump overflowed to Lake Michigan. A grab sample indicated a pH of 6.57 and no trace of oil and grease.

The spill occurred due to repairs being made to the high level alarm at the time of the overflow.

By copy of this letter, the Nuclear Regulatory Commission is notified pursuant to the requirements of Appendix B, Part II, Nonradiological Environmental Protection Plan, Section 3.2.

Very truly yours,

Richard C. Menge
Richard C. Menge
Vice President

RCM/df

c: W. G. Smith, Jr.
A. B. Davis, NRC, Region III

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Richard C. Menge
Richard C. Menge

8709210274 870914 EF
PDR ADECK 05000315
PDR S

1523
1/10

c: M. P. Alexich - Columbus
H. B. Brugger - Columbus
J. E. Dolan - Columbus
R. W. Jurgensen - Columbus
R. F. Kroeger - Columbus
K. D. Mack - Columbus
R. W. Reeves/T. E. Webb/C. E. Hawk - Columbus
A. A. Blind - Cook Plant
T. A. Kriesel/D. Fitzgerald-Stuart - Cook Plant
NRC Resident Inspector - Cook Plant
PNSRC - Cook Plant
J. F. Stietzel - Cook Plant

G. Charnoff, Esq. - Shaw, Pittman, Potts & Trowbridge
R. E. Zahler, Esq. - Shaw, Pittman, Potts & Trowbridge

R. C. Callen - Michigan Public Service Commission

D. R. Hahn - Michigan Department of Public Health

H. R. Denton - Nuclear Reactor Regulations

Dottie Sherman - ANI Library

INPO - Records Center