

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8710160130 DOC. DATE: 87/10/06 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH. NAME AUTHOR AFFILIATION  
 SMITH, W. G. Indiana Michigan Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DAVIS, A. B. Region 3, Office of Director

SUBJECT: Informs of number of steam generator tubes plugged as result of eddy current exam activities performed during Sept 1987 surveillance outage. Total number of tubes examined in each steam generator listed.

DISTRIBUTION CODE: IEO1D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD3-3 PD	1	WIGGINGTON, D	2
INTERNAL:	AEOD	1	DEDRO	1
	NRR MORISSEAU, D	1	NRR/DOEA DIR	1
	NRR/DREP/EPB	1	NRR/DREP/RPB	2
	NRR/DRIS DIR	1	NRR/PMAS/ILRB	1
	DE LIEBERMAN, J	1	OGC/HDS1	1
	<del>REG FILE</del>	1	RES DEPY GI	1
	RGNS FILE 01	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		



Mr. A.B. Davis  
October 5, 1987  
Page 2

Applying the conservative evaluation criteria resulted in plugging a total of 78 tubes. The number of tubes plugged per steam generator was 14 tubes in S/G 21, 17 tubes in S/G 22, 17 tubes in S/G 23, and 30 tubes in S/G 24.

Respectfully,

  
W.G. Smith, Jr.  
Plant Manager

/cbm

cc: A.A. Blind - INFO  
L.S. Gibson - INFO  
J.E. Rutkowski - INFO  
M.P. Alexich - INFO  
J.G. Feinstein - INFO  
S.H. Steinhart - INFO  
M. Marrocco/D.R. Hafer/J.R. Jensen - INFO  
R.F. Kroeger - INFO  
J.R. Sampson - INFO  
NRC Resident Inspectors - INFO  
R.T. Rickman - INFO  
File