



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

INDIANA AND MICHIGAN POWER COMPANY

DOCKET NO. 50-315

DONALD C. COOK NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 112
License No. DPR-58

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana and Michigan Power Company (the licensee) dated May 19, 1986 and revised July 16, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public;
and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8712210175 871210
PDR ADDCK 05000315
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-58 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 112, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The Technical Specifications are to become effective before startup following the refueling outage currently scheduled in February 1989.
4. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Kenneth E. Perkins, Jr. Director
Project Directorate III-3
Division of Reactor Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 10, 1987

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 112 FACILITY OPERATING LICENSE NO. DPR-58

DOCKET NO.50-315

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

REMOVE

INSERT

Unit 1

3/4 3-55
3/4 3-56
3/4 4-15
3/4 4-16
B 3/4 3-4

3/4 3-55**
3/4 3-56**
3/4 4-15
3/4 4-16*
B 3/4 3-4**

*Included for convenience only.

**Effective before start up following the refueling outage currently scheduled in February 1989.

TABLE 3.3-11
POST-ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>
1. Containment Pressure	2
2. Reactor Coolant Outlet Temperature - T _{HOT} (Wide Range)	2
3. Reactor Coolant Inlet Temperature - T _{COLD} (Wide Range)	2
4. Reactor Coolant Pressure - Wide Range	2
5. Pressurizer Water Level	2
6. Steam Line Pressure	2/Steam Generator
7. Steam Generator Water Level - Narrow Range	1/Steam Generator
8. Refueling Water Storage Tank Water Level	2
9. Boric Acid Tank Solution Level	1
10. Auxiliary Feedwater Flow Rate	1/Steam Generator*
11. Reactor Coolant System Subcooling Margin Monitor	1**
12. PORV Position Indicator - Limit Switches***	1/Valve
13. PORV Block Valve Position Indicator - Limit Switches	1/Valve
14. Safety Valve Position Indicator - Acoustic Monitor	1/Valve
15. Incore Thermocouples (Core Exit Thermocouples)	2/Core Quadrant
16. Reactor Coolant Inventory Tracking System (Reactor Vessel Level Indication)	One Train (3 channels/Train)
17. Containment Sump Level	1****
18. Containment Water Level	2****

* Steam Generator Water Level Channels can be used as a substitute for the corresponding auxiliary feedwater flow rate channel instrument

** PRODAC 250 subcooling margin readout can be used as a substitute for the subcooling monitor instrument.

*** Acoustic monitoring of PORV position (1 channel per three valves - headered discharge) can be used as a substitute for the PORV Indicator - Limit Switches instruments.

**** The requirements for these instruments will become effective after the level transmitters are modified or replaced and become operational. The schedule for modification or replacement of the transmitters is described in the Bases.

Amendment No. 106, 112 (Effective before start up following refueling outage currently scheduled in 2/89)

TABLE 4.3-7
POST-ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Containment Pressure	M	R*
2. Reactor Coolant Outlet Temperature - T _{HOT} (Wide Range)	M	R
3. Reactor Coolant Inlet Temperature - T _{COLD} (Wide Range)	M	R
4. Reactor Coolant Pressure - Wide Range	M	R
5. Pressurizer Water Level	M	R*
6. Steam Line Pressure	M	R*
7. Steam Generator Water Level - Narrow Range	M	R*
8. RWST Water Level	M	R
9. Boric Acid Tank Solution Level	M	R
10. Auxiliary Feedwater Flow Rate	M	R
11. Reactor Coolant System Subcooling Margin Monitor	M	R
12. PORV Position Indicator - Limit Switches	M	R*
13. PORV Block Valve Position Indicator - Limit Switches	M	R*
14. Safety Valve Position Indicator - Acoustic Monitor	M	R*
15. Incore Thermocouples (Core Exit Thermocouples)	M	R(1)
16. Reactor Coolant Inventory Tracking System (Reactor Vessel Level Indication)	M(2)	R(3)
17. Containment Sump Level**	M	R
18. Containment Water Level**	M	R

(1) Partial range channel calibration for sensor to be performed below P-12 in MODE 3.

(2) With one train of Reactor Vessel Level Indication inoperable, Subcooling Margin Indication and Core Exit Thermocouples may be used to perform a CHANNEL CHECK to verify the remaining Reactor Vessel Indication train OPERABLE.

(3) Completion of channel calibration for sensors to be performed below P-12 in MODE 3.

* The provisions of Specification 4.0.6 are applicable.

** The requirements for these instruments will become effective after the level transmitters are modified or replaced and become operational. The schedule for modification or replacement of the transmitters is described in the Bases.

Amendment No. 107, 112 (Effective before start up following the refueling outage currently scheduled in 8/89)

D. C. COOK - UNIT 1...

3/4 3-56

112

112

THIS PAGE INTENTIONALLY LEFT BLANK

REACTOR COOLANT SYSTEM

OPERATIONAL LEAKAGE

LIMITING CONDITION FOR OPERATION

3.4.6.2 Reactor Coolant System leakage shall be limited to:


- a. No PRESSURE BOUNDARY LEAKAGE,
- b. 1 GPM UNIDENTIFIED LEAKAGE,
- c. 1 GPM total primary-to-secondary leakage through all steam generators and 500 gallons per day through any one steam generator,
- d. 10 GPM IDENTIFIED LEAKAGE from the Reactor Coolant System, and
- e. 52 GPM CONTROLLED LEAKAGE.
- f. 1 GPM leakage from any reactor coolant system pressure isolation valve specified in Table 3.4-0.

APPLICABILITY: MODES 1, 2, 3 and 4

ACTION:

- a. With any PRESSURE BOUNDARY LEAKAGE, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With any Reactor Coolant System leakage greater than any one of the above limits, excluding PRESSURE BOUNDARY LEAKAGE, reduce the leakage rate to within limits within 4 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With any reactor coolant system pressure isolation valve(s) leakage greater than the above limit, except when:
 1. The leakage is less than or equal to 5.0 gpm, and
 2. The most recent measured leakage does not exceed the previous measured leakage* by an amount that reduces the

*To satisfy ALARA requirements, measured leakage may be measured indirectly (as from the performance of pressure indicators) if accomplished in accordance with approved procedures and supported by computations showing that the method is capable of demonstrating valve compliance with the leakage criteria.



INSTRUMENTATION

BASES

3/4.3.3.7 FIRE DETECTION INSTRUMENTATION

OPERABILITY of the fire detection instrumentation ensures that adequate warning capability is available for the prompt detection of fires. This capability is required in order to detect and locate fires in their early stages. Prompt detection of fires will reduce the potential for damage to safety related equipment and is an integral element in the overall facility fire protection program.

In the event that a portion of the fire detection instrumentation is inoperable, the establishment of frequent fire patrols in the affected areas is required to provide detection capability until the inoperable instrumentation is restored to OPERABILITY. Use of containment temperature monitoring is allowed once per hour if containment fire detection is inoperable.

3/4.3.3.8 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident.

The containment water level and containment sump level transmitters will be modified or replaced and OPERABLE by the end of the refueling outage scheduled to begin in February 1989.

112

D. C. COOK - UNIT 1

B 3/4 3-4

Amendment No. 79, 112 (Effective before start up following refueling outage currently scheduled in 2/89)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

INDIANA AND MICHIGAN POWER COMPANY

DOCKET NO. 50-316

DONALD C. COOK NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 95
License No. DPR-74

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana and Michigan Power Company (the licensee) dated May 19, 1986 and revised July 17, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public;
and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-74 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 95 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The Technical Specifications are to become effective before startup following the refueling outage currently scheduled to begin in early 1988.
4. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Kenneth E. Perkins, Jr., Director
Project Directorate III-3
Division of Reactor Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 10, 1987

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO 95 FACILITY OPERATING LICENSE NO. DPR-74

DOCKET NO.50-316

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

REMOVE

INSERT

Unit 2

3/4 3-46
3/4 3-47
B 3/4 3-2

3/4 3-46
3/4 3-47
B 3/4 3-2

Effective before startup following refueling outage currently scheduled to begin in early 1988.

TABLE 3.3-10
POST-ACCIDENT MONITORING INSTRUMENTATION

D. C. COOK - UNIT 2

3/4 3-46

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>
1. Containment Pressure	2
2. Reactor Coolant Outlet Temperature - T _{HOT} (Wide Range)	2
3. Reactor Coolant Inlet Temperature - T _{COLD} (Wide Range)	2
4. Reactor Coolant Pressure - Wide Range	2
5. Pressurizer Water Level	2
6. Steam Line Pressure	2/Steam Generator
7. Steam Generator Water Level - Narrow Range	1/Steam Generator
8. Refueling Water Storage Tank Water Level	2
9. Boric Acid Tank Solution Level	1
10. Auxiliary Feedwater Flow Rate	1/Steam Generator*
11. Reactor Coolant System Subcooling Margin Monitor	1**
12. PORV Position Indicator - Limit Switches***	1/Valve
13. PORV Block Valve Position Indicator - Limit Switches	1/Valve
14. Safety Valve Position Indicator - Acoustic Monitor	1/Valve
15. Incore Thermocouples (Core Exit Thermocouples)	2/Core Quadrant
16. Reactor Coolant Inventory Tracking System (Reactor Vessel Level Indication)	One Train (3 channels/Train)
17. Containment Sump Level	1****
18. Containment Water Level	2****

* Steam Generator Water Level Channels can be used as a substitute for the corresponding auxiliary feedwater flow rate channel instrument

** PRODAC 250 subcooling margin readout can be used as a substitute for the subcooling monitor instrument.

*** Acoustic monitoring of PORV position (1 channel per three valves - headered discharge) can be used as a substitute for the PORV Indicator - Limit Switches instruments.

**** The requirements for these instruments will become effective after the level transmitters are modified or replaced and become operational. The schedule for modification or replacement of the transmitters is described in the Bases.

Amendment No. 92, 95 (Effective before start up following refueling outage currently scheduled in early 1988)

TABLE 4.3-10
POST-ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL</u> <u>CHECK</u>	<u>CHANNEL</u> <u>CALIBRATION</u>
1. Containment Pressure	M	R
2. Reactor Coolant Outlet Temperature - T _{HOT} (Wide Range)	M	R
3. Reactor Coolant Inlet Temperature - T _{COLD} (Wide Range)	M	R
4. Reactor Coolant Pressure - Wide Range	M	R
5. Pressurizer Water Level	M	R
6. Steam Line Pressure	M	R
7. Steam Generator Water Level - Narrow Range	M	R
8. RWST Water Level	M	R
9. Boric Acid Tank Solution Level	M	R
10. Auxiliary Feedwater Flow Rate	M	R
11. Reactor Coolant System Subcooling Margin Monitor	M	R
12. PORV Position Indicator - Limit Switches	M	R
13. PORV Block Valve Position Indicator - Limit Switches	M	R
14. Safety Valve Position Indicator - Acoustic Monitor	M	R
15. Incore Thermocouples (Core Exit Thermocouples)	M	R(1)
16. Reactor Coolant Inventory Tracking System (Reactor Vessel Level Indication)	M(2)	R(3)
17. Containment Sump Level*	M	R
18. Containment Water Level*	M	R

- (1) Partial range channel calibration for sensor to be performed below P-12 in MODE 3.
 (2) With one train of Reactor Vessel Level Indication inoperable, Subcooling Margin Indication and Core Exit Thermocouples may be used to perform a CHANNEL CHECK to verify the remaining Reactor Vessel Indication train OPERABLE.

(3) Completion of channel calibration for sensors to be performed below P-12 in MODE 3.

* The requirements for these instruments will become effective after the level transmitters are modified or replaced and become operational. The schedule for modification or replacement of the transmitters is described in the Bases.


Amendment No. 92, 95 (Effective before start up following refueling outage currently scheduled in early 1988)

D. C. COOK - UNIT 2

3/4 3-47

5

95



3/4.3 INSTRUMENTATION

BASES

3/4.3.3 MONITORING INSTRUMENTATION

3/4.3.3.1 RADIATION MONITORING INSTRUMENTATION

The OPERABILITY of the radiation monitoring channels ensures that 1) the radiation levels are continually measured in the areas served by the individual channels and 2) the alarm or automatic action is initiated when the radiation level trip setpoint is exceeded.

3/4.3.3.2 MOVABLE INCORE DETECTORS

The OPERABILITY of the movable incore detectors with the specified minimum complement of equipment ensures that the measurements obtained from use of this system accurately represent the spatial neutron flux distribution of the reactor core. The OPERABILITY of this system is demonstrated by irradiating each detector used and normalizing its respective output.

3/4.3.3.3 SEISMIC INSTRUMENTATION

The OPERABILITY of the seismic instrumentation ensures that sufficient capability is available to promptly determine the magnitude of a seismic event and evaluate the response of those features important to safety. This capability is required to permit comparison of the measured response to that used in the design basis for the facility.

3/4.3.3.4 METEOROLOGICAL INSTRUMENTATION

The OPERABILITY of the meteorological instrumentation ensures that sufficient meteorological data is available for estimating potential radiation doses to the public as a result of routine or accidental release of radioactive materials to the atmosphere. This capability is required to evaluate the need for initiating protective measures to protect the health and safety of the public.

3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the remote shutdown instrumentation ensures that sufficient capability is available to permit shutdown and maintenance of HOT STANDBY of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criteria 19 of 10 CFR 50.

3/4.3.3.6 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident.

The containment water level and containment sump level transmitters will be modified or replaced and OPERABLE by the end of the outage currently scheduled to begin in May 1988.