





Indiana Michigan  
Power Company  
P.O. Box 16631  
Columbus, OH 43216



AEP:NRC:0969K

Donald C. Cook Nuclear Plant Units 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
INSERVICE TEST (IST) - WITHDRAWAL OF REQUEST FOR  
CODE RELIEF OF CONTAINMENT SPRAY HEAT EXCHANGER

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Attn: T. E. Murley

December 16, 1987

Dear Dr. Murley:

The purpose of this letter is to withdraw our request for temporary code relief for the Donald C. Cook Nuclear Plant Units 1 and 2 containment spray heat exchangers.

In our letter, AEP:NRC:0969J, dated October 29, 1987, we requested this temporary code relief to be granted until we could pressure test the heat exchangers in accordance with the ASME Boiler and Pressure Vessel Code Section XI, 1983 Edition, Subsection IWD, Article IWD-5000. At that time we were planning to test the heat exchangers during the next scheduled outages, which are April 1988 for Unit 1 and May 1988 for Unit 2

In November 1987 the heat exchangers were pressure tested at the 1983 Code required value of 165 psig, which is 110% of the lowest safety valve setting (150 psig). Therefore, the request for temporary code relief for the Cook Nuclear Plant Units 1 and 2 containment spray heat exchangers is being withdrawn.

8712230059 871216  
PDR ADOCK 05000315  
P DCD

A047  
1/0

1950

100

100

100

100

100

100

100

Dr. T. E. Murley

-2-

AEP:NRC:0969K

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,



M. P. Alexich  
Vice President

cm

cc: John E. Dolan  
W. G. Smith, Jr. - Bridgman  
R. C. Callen  
G. Bruchmann  
G. Charnoff  
NRC Resident Inspector - Bridgman  
A. B. Davis - Region III