

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8802220363 DOC. DATE: 88/02/18 NOTARIZED: NO DOCKET #
 FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M. P. American Electric Power Co., Inc.
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T. E. Document Control Branch (Document Control Desk)

SUBJECT: Discusses reactor vessel matl surveillance rept re
 Capsule X Tech Spec heat-up & cooldown curves. Difference in
 data between test results of Capsule X & Y negligible.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD3-3 LA		1	0		PD3-3 PD		5	0
	WIGGINGTON, D		1						
INTERNAL:	ARM/DAF/LFMB		1	0		NRR/DEST/ADS7E4		1	0
	NRR/DEST/CEB8H7		1			NRR/DEST/MTB 9H		1	0
	NRR/DEST/RSB 8E		1			NRR/DOEA/TSB11F		1	0
	NRR/PMA5/ILRB12		1			OGC 15-B-18		1	0
	<u>REG FILE</u> 01		1			RES/DE/EIB		1	0
EXTERNAL:	LPDR		1			NRC PDR		1	0
	NSIC		1						

1

○

Vertical line

Vertical line

American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, OH 43215
614 223 1000



AEP:NRC:0894J

Donald C. Cook Nuclear Plant Unit 2
Docket No. 50-316
License No. DPR-74
REACTOR VESSEL MATERIAL SURVEILLANCE REPORT -
CAPSULE X T/S HEAT-UP AND COOLDOWN CURVES

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Attn: T. E. Murley

February 18, 1988

Dear Dr. Murley:

In our submittal AEP:NRC:0894I dated June 26, 1987 we submitted the Reactor Vessel Material Surveillance Reports for the Donald C. Cook Nuclear Plant Unit No. 2. That report was prepared by Southwest Research Institute (SWRI) based on the test results for Capsule X. The current T/S heat-up and cooldown curves are based on Capsule Y test results. As shown in Figures 11 and 12 of the SWRI report, the difference in data between the test results of Capsule X and Capsule Y is negligible. Since the Capsule Y results are slightly more conservative than the Capsule X results, we intend to operate the plant within the bounds of the existing technical specification curves and are not planning to seek a technical specifications change.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,

A handwritten signature in cursive script, appearing to read 'M. P. Alexich'.

M. P. Alexich
Vice President

cm

cc: D. H. Williams, Jr.
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Bruchmann
G. Charnoff
A. B. Davis, NRC Region III
NRC Resident Inspector - Bridgman

*Appl
1/10*

8802220363 880218
PDR ADDCK 05000316
P PDR

