

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8806280211 DOC. DATE: 88/05/16 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 MENGE, R. C. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 ZUGGER, P. D. Michigan, State of
 MURLEY, T. E. NRC - No Detailed Affiliation Given

SUBJECT: NPDES noncompliance notification: on 880602 oil spill
 estimated about 300 gallons discovered. 150 gallons recovered
 & 42 cubic yards of contaminated removed. Investigation in
 progress to locate leak area for repairs to be done.

DISTRIBUTION CODE: IE23D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
 TITLE: Environmental Event Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES L TTR ENCL	RECIPIENT ID CODE/NAME	COPIES L TTR ENCL
	PD3-1 LA	1	PD3-1 PD	1
	STANG, J	1		
INTERNAL:	AEOD/DOA	1	AEOD/DSP/TPAB	1
	AEOD/PTB	1	NRR/DEST/ADE 8H	1
	NRR/DOEA/EAB 11	1	NRR/DREP/EPB 10	1
	NRR/DREP/RPB 10	1	NRR/PMAS/ILRB12	1
	NRR/PMAS/PTSB12	1	NUDGS-ABSTRACT	1
	OGC 15-B-18	1	REG FILE	1
	RGN3 FILE 01	1	RGN2/DRSS/EPRPB	1
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

TOTAL NUMBER OF COPIES REQUIRED: L TTR .20 ENCL 10

Indiana Michigan
Power Company
One Summit Square
P.O. Box 60
Fort Wayne, IN 46801
219 425 2111



Paul D. Zugger, Executive Secretary
Michigan Water Resources Commission
Stevens T. Mason Building, Box 30026
Lansing, Michigan 48909

June 15, 1988

Dear Mr. Zugger:

Richard C. Menge
Senior Vice President
219 425 2103

RE: Donald C. Cook Nuclear Plant
NPDES Permit No. MI 0005827

On June 2, 1988 at 1655 hours, an oil spill was discovered at the Cook Nuclear Plant and was reported to the Pollution Emergency Alert System shortly afterward. The latest estimate is that 300 gallons of No. 2 diesel oil was discharged from an underground storage tank to the ground.

The spill became apparent after the associated tank piping was overfilled during tank testing then lost oil dramatically. Cleanup and recovery measures began immediately and 150 gallons of oil has been recovered from a dry well located in the immediate vicinity of the discharge. Forty-two cubic yards of contaminated soil have been removed as of June 13, 1988. Cleanup measures are still underway, and investigations continue to locate the leak area. Repairs will be made immediately to the leak area. It is expected that the cleanup will be completed by June 17, 1988.

By copy of this letter, the Nuclear Regulatory Commission is notified pursuant to the requirements of Appendix B, Part II, Nonradiological Environmental Protection Plan, Section 3.2.

If you have any questions about this matter, please call Donald L. Baker, Environmental Affairs Manager at 219/425-2118.

Very truly yours,

Richard C. Menge
Senior Vice President

RCM/df

c: A. B. Davis - NRC, Region III
Fred Morley - MDNR, Plainwell

8806280211 880516
PDR ADOCK 05000315
S PDR

IE23
/0

June 15, 1988
Mr. Paul D. Zuger
Page 2

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.


Richard C. Menge

June 15, 1988
Mr. Paul D. Zugger
Page 3

DISTRIBUTION LIST

bc: M. P. Alexich/R. W. Jurgensen - Columbus
P. A. Barrett - Columbus
C. E. Hawk - Columbus
K. D. Mack - Columbus
R. W. Reeves/T. E. Webb/M. R. Robida - Columbus
W. E. Walters/D. L. Baker/J. L. Hughey - Fort Wayne

A. A. Blind/J. R. Sampson - Cook Plant
NRC Resident Inspector - Cook Plant
PNSRC - Cook Plant
W. G. Smith, Jr. - Cook Plant
J. T. Wojcik/D. M. Fitzgerald - Cook Plant

G. Charnoff/R. E. Zahler - Shaw, Pittman, Potts & Trowbridge
T. E. Murley - Nuclear Reactor Regulations ✓