

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SESSION NBR: 8811180246 DOC. DATE: 88/11/04 NOTARIZED: NO DOCKET #
 CIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 SMITH, W.G. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 HOLTZMAN, R.B. Region 3, Ofc of the Director

SUBJECT: Responds to Open Items 50-315/87-30-03 & 50-316/87-30-03 re reactor coolant samples.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL	
	PD3-1 PD		1	1		SCOTT, W		1	1	
INTERNAL:	AEOD		1	1		DEDRO		1	1	
	NRR MORISSEAU, D		1	1		NRR/DLPQ/PEB 11		1	1	
	NRR/DLPQ/QAB 10		1	1		NRR/DOEA DIR 11		1	1	
	NRR/DREP/EPB 10		1	1		NRR/DREP/RPB 10		2	2	
	NRR/DRIS DIR 9A		1	1		NRR/PMAS/ILRB12		1	1	
	NUDOCS-ABSTRACT		1	1		GE LIEBERMAN, J		1	1	
	OGC/HDS1		1	1		<u>REG FILE</u> 02		1	1	
	RGN3 FILE 01		1	1						
EXTERNAL:	LPDR		1	1		NRC PDR		1	1	
	NSIC		1	1		RESL MARTIN, D		1	1	

*Add: R.B. Holtzman
RGN 3*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL ~~22~~ 0

R
I
D
S
/
A
D
D
S
/
A
D
D
S
/
A
D
D
S

Indiana Michigan
Power Company
Cook Nuclear Pl.
P.O. Box 458
Bridgman, MI 49106
616 465 5901



November 4, 1988

R. B. Holtzman
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Dr. Holtzman:

Response to Open Items No. 50-315/87030-03 and No. 50-316/87030-03


A sample of Unit 1 Reactor Coolant was analyzed by an offsite vendor to ratio SR-89, SR-90, and Y-90 to CS-137. The results are listed below:

<u>Nuclide</u>	<u>Activity</u>	<u>Ratio</u>
SR-89	8.56E-7 μ ci/ml \pm 10%	SR-89/CS-137 - 2.8E-3 (.28%)
SR-90	\angle 2.3E-8 μ ci/ml	SR-90/CS-137 - \angle 8.2E-3 (.82%)
CS-137	3.04E-4 μ ci/ml \pm 10%	
Y-90	\angle 2.3E-8 μ ci/ml	Y-90/CS-137 - \angle 8.2E-3 (.82%)

As can be seen from these results the contribution to the E-BAR calculation from SR-89, SR-90, and Y-90 would be extremely small. We will continue sending reactor coolant samples, to an offsite vendor, to determine these ratios, twice yearly. These factors will be figured into our E-BAR calculations.

If additional information is required, please contact me.

Very truly yours,


W. G. Smith, Jr.

c: M. P. Alexich
P. A. Barrett
H. B. Brugger
NRC Resident Inspectors
R. C. Callen, MPSC
G. Charnoff, Esq.
D. Hahn
INPO Records Center
PNSRC
D. Sherman, ANI Library
J. T. Wojcik
K. M. Haglund
Chemical Section Files

ADD: R. B. HOLTZMAN
RGN 3

IE 01
1/0

8811180246 881104
PDR ADDCK 05000315
FDC