

NOTICE OF VIOLATION

American Electric Power  
Service Corporation

Docket No. 50-316

As a result of the inspection conducted on October 20 through November 16, 1988, and in accordance with the General Policy and Procedures for NRC Enforcement Actions (10 CFR Part 2, Appendix C), the following violation was identified:

Unit 2 Technical Specification 6.8.1.f requires procedures to be implemented covering the Fire Protection Program. Safety Procedure SP-03.00, "Hot Work Permits" is such a procedure. It requires that fire watches shall be present, with a fire extinguisher in their possession, during and for 30 minutes after any hot work for which the Permit specifies a fire watch.

Contrary to the above, at approximately 11:00 a.m. on October 28, 1988, no fire watch was present covering welding of a Unistrut attachment on steam generator No. 21, under Hot Work Permit No. 1247, even though the Permit specified a fire watch.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each violation: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

DEC 01 1988

Dated \_\_\_\_\_

  
\_\_\_\_\_  
W. L. Axelson, Chief  
Projects Branch 2

8812140242 881201  
PDR ADOCK 05000315  
Q PDC

